SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 19, 1993

SCHOOL Cohasset Elementary INSPECTOR Ron Jones RJ

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic above 3,4,5,6,7	1-4
A	VFT	5-10	Rms 9,10,11,12,13,6,3,2,1,8	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)