

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 1/24/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	KNOCKDOWN TEXTURE COAT #1 (OLD)	1	NONE DETECTED	7,171 S	100-CONFERENCE ROOM, 104-SRO/PROBATION, CLASSROOMS 106, 123, 124, & 125, 107-HALL, 108-COUNSELOR OFFICE, 112-SDC, AND 127-STORAGE ROOM	(13) SAMPLES ECG-06-133-01A-G COLLECTED ON 3-29-06.	N/A
M	DRYWALL & JOINT COMPOUND	2	NONE DETECTED	17,533 S	100-CONFERENCE ROOM, 101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-HALL (WEST), 106-CLASSROOM, 107-HALL (EAST), 109-SDCM 110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 112-SDC, 115-STORAGE ROOM, 118-KITCHEN, 122-STORAGE ROOM, 123-CLASSROOM, 124-CLASSROOM, 125-CLASSROOM, 126-ELEC/MECH ROOM, 127-STORAGE ROOM, 128-TOILET, AND ATTIC	(13) SAMPLES ECG-06-133-02A-F COLLECTED ON 3-29-06.	N/A
M	DRYWALL & JOINT COMPOUND #2 (NEW)	3	NONE DETECTED	1,308 S	100-CONFERENCE ROOM, 101- OFFICE, 104-SRO/PROBATION, 108-COUNSELOR OFFICE, AND 112-SDC	(13) SAMPLES ECG-06-133-03A & B COLLECTED ON 3-29-06.	N/A
M	2' X 4' LAY-IN CEILING PANELS	4	NONE DETECTED	3,176 S	100-CONFERENCE ROOM, 101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-HALL (WEST), 106-CLASSROOM, 107-HALL (EAST), 108-COUNSELOR OFFICE, 109-SDC, AND 112-SDC	(13) SAMPLES ECG-06-133-04A-C COLLECTED ON 3-29-06.	N/A
S	KNOCKDOWN TEXTURE COAT #2 (NEW)	5	NONE DETECTED	1,288 S	100-CONFERENCE ROOM, 104-SRO/PROBATION, 109-SDC, AND 112-SDC	(13) SAMPLES ECG-06-133-05A-C COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected (14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 1/24/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	BASE COVE ADHESIVE	6	NONE DETECTED	1,004 L	100-CONFERENCE ROOM, 101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-ASSEMBLY ROOM, 106-CLASSROOM, 107-HALL (EAST), 109-SDC, 110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 112-SDC, 115-STORAGE ROOM, 116-STORAGE CLOSET, 120-HALL, 122-STORAGE ROOM, 123-CLASSROOM, 124-CLASSROOM, AND 125-CLASSROOM	(13) SAMPLES ECG-06-133-06A-C COLLECTED ON 3-29-06.	N/A
S	SKIP TROWEL TEXTURE COAT	7	NONE DETECTED	11,673 S	101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-ASSEMBLY ROOM, 110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 113-UNI RESTROOM, 114-ELECTRICAL ROOM, 115-STORAGE ROOM, 116-STORAGE CLOSET, 117-UTILITY ROOM, 118-KITCHEN, 120-HALL, 122-STORAGE ROOM, AND 300- MECHANICAL ROOM MEZZANINE	(13) SAMPLES ECG-06-133-07A-C COLLECTED ON 3-29-06.	N/A
M	FLOOR LEVELING COMPOUND (GREY)	8	NONE DETECTED	10 S	106-CLASSROOM	(13) SAMPLE ECG-06-133-08A COLLECTED ON 3-29-06.	N/A
M	FLOORING ADHESIVE (YELLOW)	9	NONE DETECTED	1,450 S	106-CLASSROOM, 107-HALL (EAST), 109-SDC, AND 112-SDC	(13) SAMPLES ECG-06-133-09A & B COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
(14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 1/24/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	LINOLEUM SHEETING (MOTTLED WHITE)	10	NONE DETECTED	49 S	110-WOMEN'S RESTROOM	(13) SAMPLE ECG-06-133-10A COLLECTED ON 3-29-06.	N/A
M	LINOLEUM SHEETING (GREY W/BBLUE SPECS)	11	NONE DETECTED	304 S	113-UNI RESTROOM, 117-UTILITY ROOM, 118-KITCHEN, AND 120-HALL	(13) SAMPLE ECG-06-133-11A COLLECTED ON 3-29-06.	N/A
M	COVE BASE MASTIC (BROWN)	12	<1% CHRYSOTILE	82 L	114-ELECTRICAL ROOM AND 300-MECHANICAL ROOM MEZZANINE	(1) (4) SAMPLE ECG-06-133-12A COLLECTED ON 3-29-06. (2) NOT COVERED BY COVE BASE.	N
M	12" VFT BEIGE & YELLOW MASTIC	13	1% CHRYSOTILE	256 S	300-MECHANICAL ROOM MEZZANINE	(1) (4) SAMPLE ECG-06-133-13A COLLECTED ON 3-29-06. (2) 12" VFT HAS MINOR DAMAGE.	N
M	12" VFT BEIGE & ADHESIVE	14	NONE DETECTED	256 S	300-MECHANICAL ROOM MEZZANINE	(13) SAMPLE ECG-06-133-14A COLLECTED ON 3-29-06.	N/A
M	CARPET GLUE	15	NONE DETECTED	596 S	121-STORAGE ROOM AND 123-CLASSROOM	(13) SAMPLE ECG-06-133-15A COLLECTED ON 3-29-06.	N/A
M	2' X 4' LAY-IN CEILING PANEL (NEW)	16	NONE DETECTED	1,368 S	123-CLASSROOM, 124-CLASSROOM, AND 125-CLASSROOM	(13) SAMPLE ECG-06-133-16A COLLECTED 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
(14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 1/24/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	LINOLEUM SHEETING (MOTTLED BEIGE)	17	NONE DETECTED	234 L	127-STORAGE AND 128-TOILET	(13) SAMPLE ECG-06-133-17A COLLECTED ON 3-29-06.	N/A
M	DRYWALL & JOINT COMPOUND (ORIGINAL)	27	1-2% CHRYSOTILE	3,598 S	110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 113-UNI RESTROOM, 114-ELECTRICAL ROOM, 116-STORAGE CLOSET, 117-UTILITY ROOM, 119-HALL, 120-HALL, 121-STORAGE ROOM, 122-STORAGE ROOM, 123-CLASSROOM, AND 300-MECHANICAL ROOM MEZZANINE	(1) (4) (3) IN ROOM 300.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
(14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 1/24/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: B - Classrooms

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND	18	NONE DETECTED	10,092 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203A-TOILET HALLWAY, 203B-TOILET (NORTH), 203C-TOILET (SOUTH), 204-TOILET, 205-HALL. 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, 211-CLASSROOM, AND ATTIC	(13) SAMPLES ECG-06-133-18A-G COLLECTED ON 3-29-06.	N/A
S	KNOCKDOWN TEXTURE	19	NONE DETECTED	8,972 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203A-TOILET HALLWAY, 203B-TOILET (NORTH), 203C-TOILET (SOUTH), 204-TOILET, 205-HALL, 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLES ECG-06-133-19A-I COLLECTED ON 3-29-06.	N/A
M	2' X 4' LAY-IN CEILING PANELS	20	NONE DETECTED	3,528 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 205-HALL, 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLES ECG-06-133-20A & B COLLECTED ON 3-29-06.	N/A
M	BASE COVE MASTIC	21	NONE DETECTED	800 L	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203A-TOILET HALLWAY, 204-TOILET, 205-HALL-206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLES ECG-06-133-21A & B COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected (14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 1/24/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: B - Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	LINOLEUM SHEETING (LEAF PATTERN)	22	NONE DETECTED	154 S	203B-TOILET (NORTH) AND 203C-TOILET (SOUTH)	(13) SAMPLE ECG-06-133-22A COLLECTED ON 3-29-06.	N/A
M	LINOLEUM SHEETING (YELLOW/WHITE)	23	NONE DETECTED	20 S	206-DAY ROOM	(13) SAMPLE ECG-06-133-23A COLLECTED ON 3-29-06.	N/A
M	FLOOR LEVELING COMPOUND (WHITE)	24	NONE DETECTED	12 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203B-TOILET (NORTH), 203C-TOILET (SOUTH), AND 207-CONFERENCE ROOM	(13) SAMPLE ECG-06-133-24A COLLECTED ON 3-29-06.	N/A
M	FLOORING ADHESIVE (YELLOW)	25	NONE DETECTED	94 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 205-HALL, 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLE ECG-06-133-25A COLLECTED ON 3-29-06.	N/A
M	LINOLEUM SHEETING (BEIGE W/SPECS)	26	NONE DETECTED	126 S	204-TOILET, 205-HALL, 208-CLASSROOM, AND 209-SPECIAL ED/CONFERENCE ROOM	(13) SAMPLE ECG-06-133-26A COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected (14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 7/14/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	KNOCKDOWN TEXTURE COAT #1 (OLD)	1	NONE DETECTED	7,171 S	100-CONFERENCE ROOM, 104-SRO/PROBATION, CLASSROOMS 106, 123, 124, & 125, 107-HALL, 108-COUNSELOR OFFICE, 112-SDC, AND 127-STORAGE ROOM	(13) SAMPLES ECG-06-133-01A-G COLLECTED ON 3-29-06.	N/A
M	DRYWALL & JOINT COMPOUND	2	NONE DETECTED	17,533 S	100-CONFERENCE ROOM, 101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-HALL (WEST), 106-CLASSROOM, 107-HALL (EAST), 109-SDCM 110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 112-SDC, 115-STORAGE ROOM, 118-KITCHEN, 122-STORAGE ROOM, 123-CLASSROOM, 124-CLASSROOM, 125-CLASSROOM, 126-ELEC/MECH ROOM, 127-STORAGE ROOM, 128-TOILET, AND ATTIC	(13) SAMPLES ECG-06-133-02A-F COLLECTED ON 3-29-06.	N/A
M	DRYWALL & JOINT COMPOUND #2 (NEW)	3	NONE DETECTED	1,308 S	100-CONFERENCE ROOM, 101- OFFICE, 104-SRO/PROBATION, 108-COUNSELOR OFFICE, AND 112-SDC	(13) SAMPLES ECG-06-133-03A & B COLLECTED ON 3-29-06.	N/A
M	2' X 4' LAY-IN CEILING PANELS	4	NONE DETECTED	3,176 S	100-CONFERENCE ROOM, 101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-HALL (WEST), 106-CLASSROOM, 107-HALL (EAST), 108-COUNSELOR OFFICE, 109-SDC, AND 112-SDC	(13) SAMPLES ECG-06-133-04A-C COLLECTED ON 3-29-06.	N/A
S	KNOCKDOWN TEXTURE COAT #2 (NEW)	5	NONE DETECTED	1,288 S	100-CONFERENCE ROOM, 104-SRO/PROBATION, 109-SDC, AND 112-SDC	(13) SAMPLES ECG-06-133-05A-C COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected (14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 7/14/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	BASE COVE ADHESIVE	6	NONE DETECTED	1,004 L	100-CONFERENCE ROOM, 101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-ASSEMBLY ROOM, 106-CLASSROOM, 107-HALL (EAST), 109-SDC, 110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 112-SDC, 115-STORAGE ROOM, 116-STORAGE CLOSET, 120-HALL, 122-STORAGE ROOM, 123-CLASSROOM, 124-CLASSROOM, AND 125-CLASSROOM	(13) SAMPLES ECG-06-133-06A-C COLLECTED ON 3-29-06.	N/A
S	SKIP TROWEL TEXTURE COAT	7	NONE DETECTED	11,673 S	101-OFFICE, 102-SHELLY, 103-SOA, 104-SRO/PROBATION, 105-ASSEMBLY ROOM, 110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 113-UNI RESTROOM, 114-ELECTRICAL ROOM, 115-STORAGE ROOM, 116-STORAGE CLOSET, 117-UTILITY ROOM, 118-KITCHEN, 120-HALL, 122-STORAGE ROOM, AND 300- MECHANICAL ROOM MEZZANINE	(13) SAMPLES ECG-06-133-07A-C COLLECTED ON 3-29-06.	N/A
M	FLOOR LEVELING COMPOUND (GREY)	8	NONE DETECTED	10 S	106-CLASSROOM	(13) SAMPLE ECG-06-133-08A COLLECTED ON 3-29-06.	N/A
M	FLOORING ADHESIVE (YELLOW)	9	NONE DETECTED	1,450 S	106-CLASSROOM, 107-HALL (EAST), 109-SDC, AND 112-SDC	(13) SAMPLES ECG-06-133-09A & B COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
(14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 7/14/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	LINOLEUM SHEETING (MOTTLED WHITE)	10	NONE DETECTED	49 S	110-WOMEN'S RESTROOM	(13) SAMPLE ECG-06-133-10A COLLECTED ON 3-29-06.	N/A
M	LINOLEUM SHEETING (GREY W/BBLUE SPECS)	11	NONE DETECTED	304 S	113-UNI RESTROOM, 117-UTILITY ROOM, 118-KITCHEN, AND 120-HALL	(13) SAMPLE ECG-06-133-11A COLLECTED ON 3-29-06.	N/A
M	COVE BASE MASTIC (BROWN)	12	<1% CHRYSOTILE	82 L	114-ELECTRICAL ROOM AND 300-MECHANICAL ROOM MEZZANINE	(1) (4) SAMPLE ECG-06-133-12A COLLECTED ON 3-29-06. (2) NOT COVERED BY COVE BASE.	N
M	12" VFT BEIGE & YELLOW MASTIC	13	1% CHRYSOTILE	256 S	300-MECHANICAL ROOM MEZZANINE	(1) (4) SAMPLE ECG-06-133-13A COLLECTED ON 3-29-06. (2) 12" VFT HAS MINOR DAMAGE.	N
M	12" VFT BEIGE & ADHESIVE	14	NONE DETECTED	256 S	300-MECHANICAL ROOM MEZZANINE	(13) SAMPLE ECG-06-133-14A COLLECTED ON 3-29-06.	N/A
M	CARPET GLUE	15	NONE DETECTED	596 S	121-STORAGE ROOM AND 123-CLASSROOM	(13) SAMPLE ECG-06-133-15A COLLECTED ON 3-29-06.	N/A
M	2' X 4' LAY-IN CEILING PANEL (NEW)	16	NONE DETECTED	1,368 S	123-CLASSROOM, 124-CLASSROOM, AND 125-CLASSROOM	(13) SAMPLE ECG-06-133-16A COLLECTED 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
(14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 7/14/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: A - Admin. & Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	LINOLEUM SHEETING (MOTTLED BEIGE)	17	NONE DETECTED	234 L	127-STORAGE AND 128-TOILET	(13) SAMPLE ECG-06-133-17A COLLECTED ON 3-29-06.	N/A
M	DRYWALL & JOINT COMPOUND (ORIGINAL)	27	1-2% CHRYSOTILE	3,598 S	*110-WOMEN'S RESTROOM, 111-MEN'S RESTROOM, 113-UNI RESTROOM, 114-ELECTRICAL ROOM, 116-STORAGE CLOSET, 117-UTILITY ROOM, 119-HALL. 120-HALL, 121-STORAGE ROOM, 122-STORAGE ROOM, 123-CLASSROOM, AND 300-MECHANICAL ROOM MEZZANINE	(1) (4) (3) IN ROOM 300.	N

*110=907B 111=907A 113=908B 116=908A
117=908C 121=908 122=905

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
(14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 7/14/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: B - Classrooms

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND	18	NONE DETECTED	10,092 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203A-TOILET HALLWAY, 203B-TOILET (NORTH), 203C-TOILET (SOUTH), 204-TOILET, 205-HALL. 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, 211-CLASSROOM, AND ATTIC	(13) SAMPLES ECG-06-133-18A-G COLLECTED ON 3-29-06.	N/A
S	KNOCKDOWN TEXTURE	19	NONE DETECTED	8,972 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203A-TOILET HALLWAY, 203B-TOILET (NORTH), 203C-TOILET (SOUTH), 204-TOILET, 205-HALL, 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLES ECG-06-133-19A-I COLLECTED ON 3-29-06.	N/A
M	2' X 4' LAY-IN CEILING PANELS	20	NONE DETECTED	3,528 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 205-HALL, 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLES ECG-06-133-20A & B COLLECTED ON 3-29-06.	N/A
M	BASE COVE MASTIC	21	NONE DETECTED	800 L	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203A-TOILET HALLWAY, 204-TOILET, 205-HALL-206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLES ECG-06-133-21A & B COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected (14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 7/14/08

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Academy for Change (FKA Chico Country Day School)

Building: B - Classrooms
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	LINOLEUM SHEETING (LEAF PATTERN)	22	NONE DETECTED	154 S	203B-TOILET (NORTH) AND 203C-TOILET (SOUTH)	(13) SAMPLE ECG-06-133-22A COLLECTED ON 3-29-06.	N/A
M	LINOLEUM SHEETING (YELLOW/WHITE)	23	NONE DETECTED	20 S	206-DAY ROOM	(13) SAMPLE ECG-06-133-23A COLLECTED ON 3-29-06.	N/A
M	FLOOR LEVELING COMPOUND (WHITE)	24	NONE DETECTED	12 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 203B-TOILET (NORTH), 203C-TOILET (SOUTH), AND 207-CONFERENCE ROOM	(13) SAMPLE ECG-06-133-24A COLLECTED ON 3-29-06.	N/A
M	FLOORING ADHESIVE (YELLOW)	25	NONE DETECTED	94 S	200-CLASSROOM, 201-OFFICE, 202-INST. AIDE WORK ROOM, 205-HALL, 206-DAY ROOM, 207-CONFERENCE ROOM, 208-CLASSROOM, 209-SPECIAL ED/CONFERENCE ROOM, 210-CLASSROOM, AND 211-CLASSROOM	(13) SAMPLE ECG-06-133-25A COLLECTED ON 3-29-06.	N/A
M	LINOLEUM SHEETING (BEIGE W/SPECS)	26	NONE DETECTED	126 S	204-TOILET, 205-HALL, 208-CLASSROOM, AND 209-SPECIAL ED/CONFERENCE ROOM	(13) SAMPLE ECG-06-133-26A COLLECTED ON 3-29-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected (14) Non AHERA/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS