

**ENTEK CONSULTING GROUP, INC.
ASSESSMENT OF TSI and/or FRIABLE MATERIAL**

District: Chico Unified School District

Date: July 8, 2010

School: Chico Junior High School

Inspector: Jack DeLay

Building & Location(s): L - (aka Classrooms 500, 502, 504 & 506) (FKA - BLDG. F) - Classroom 506

ECG- % Asbestos-Assumed

Homogeneous Mat. #95

Material description: Pipe Wrap Straight.

Total amount of material this location: Undetermined Amount of friable material this location: Undetermined

Damage	Local		Distributed		Damaged	%
Type of Damage	Air Erosion		Water		Flaking	
	Deterioration		Physical		Delamination	

Probable cause(s) of damage:

POTENTIAL FOR DISTURBANCE			RESPONSE ACTIONS		PREVENTIVE MEASURES	
	H	M	L	Isolate/Restrict		Fix leaks
Accessibility			X	Repair/Cleanup		Prevent water contact
Vibration			X	Enclose		Do not drill, cut, sand, or grind
Air Erosion			X	Remove	X	Do not affix signs
Water			X	Encapsulate		Avoid contact
Occupancy			X	O & M	X	

Assessment of Material Condition

Significantly Damaged
(Poor)

Damaged
(Fair)

Not damaged
(Good)

Potential Damage:

High

High

Mod

Low

High

Mod

Low

Hazard Ranking:

1

2

3

4

5

6

7

								X
--	--	--	--	--	--	--	--	---

Comments & Observations: This material is inaccessible.