

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: July 8, 2010

District: Chico Unified School District

Inspector: Jack DeLay

School: Corporate Yard

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT	2	1-5%	980 S	LOCKERS & ELECTRICIAN OFFICE	(1) FORMERLY MECHANICS OFFICE & MAINTENANCE OFFICE	N
M	12" VFT BEIGE	4	TRACE	60 S	UPSTAIRS RESTROOM	(1) (4) SAMPLE HMS-COP-04 COLLECTED IN 1988.	N
M	12" VFT YELLOW	6	TRACE	200 S	TRANSPORTATION OFFICE, ROLLING CHAIR WEAR-OUT	(2) (4) SAMPLE HMS-COP-06 COLLECTED IN 1988.	N
M	12" ACT - 1/8" HOLE PATTERN	7	NONE DETECTED	680 S	DRIVERS LOUNGE & TRANSPORTATION OFFICE	(13) SAMPLE HMS-COP-07 COLLECTED IN 1988.	N/A
M	12" VFT GREY	8	ASSUMED	260 S	TRANSPORTATION OFFICE	(1) (4)	N
S	TEXTURE	9	ASSUMED	200 S	TRANSPORTATION OFFICE	(1) (4)	N
M	9" VFT PINK	62	ASSUMED	500 S	KEY SMITH SHOP	(1) (4)	N
M	DRYWALL	77	NONE DETECTED	5,000 S	ALL ROOMS	(13) SAMPLE HMS-CUSD-CORP-77A COLLECTED ON 5-20-92.	N/A
M	12" VFT CREAM	78	ASSUMED	100 S	DRIVERS ROOM AT TRANSPORTATION OFFICE	(1) (4)	N
M	GLAZING COMPOUND	79	ASSUMED	50 L	GROUND SHED WINDOWS	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: July 8, 2010

District: Chico Unified School District

Inspector: Jack DeLay

School: Corporate Yard

Building: E - Paint Shop

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL	75	1-5% IN SKIM COAT	2,000 S	PAINT SHOP - ALL AREAS	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: July 8, 2010

District: Chico Unified School District

Inspector: Jack DeLay

School: Corporate Yard

Building: D - Poison Storage

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL	76	NONE DETECTED	500 S	ALL ROOMS	(13)	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS