

RECORD OF FRIABLE AND NON-FRIABLE ACM
(FORM B)

Inspection Date(s) June 30, 2010

THREE-YEAR REINSPECTION

					CDS CODE 04-61424-6003008
SCHOOL Hooker Oak Elementary School					SCHOOL PHONE NUMBER (530) 891-3119
ADDRESS	(NUMBER)	(STREET)	(CITY)	(ZIP)	
1238 Arbutus Avenue			Chico, CA	95926	

-IMPORTANT-

Each building and functional space with friable ACBM or friable assumed ACBM listed on this form requires completion of FORM C (PHYSICAL AND HAZARD ASSESSMENT OF FRIABLE ACBM OR FRIABLE ASSUMED ACBM). Indicate location of material on blueprint, diagram or narrative in square or linear feet, and attach a copy (Sec. 763.93).

LINE	BUILDING NAME & FUNCTIONAL SPACE <small>(Indicate Address if Different From Above)</small>	CHECK ONE			CHECK ONE			
		SUR-FACING	TSI	MISC	ACBM		ASSUMED ACBM	
					FRIABLE	NON-FRIABLE	FRIABLE	NON-FRIABLE
1.	C-TRAIN NO SUSPECT ACBM							
2.	UNIT A - CLASSROOMS 1-5	X		X				X
3.	UNIT B - CLASSROOMS 6-10	X		X				X
4.	UNIT C - CLASSROOMS 13-17	X		X		X		X
5.	UNIT D - PORTABLE LIBRARY & PORTABLE 18			X				X
6.	UNIT E - MPR	X		X		X		X
7.	BOILER ROOM (925)		X		X			
8.	UNIT F - PORTABLES 20-22			X				X
9.	UNIT G - ROOM 19 DISTRICT MUST CERTIFY							
10.								
11.								
12.								
13.								
14.								
15.								
16.								
17.								

See attached "Homogeneous Materials Records" for all materials and their locations by building. On Form B all buildings are listed, and a summary of all non-friable and friable material is provided. Friable materials and their locations are listed separately under each building on Form B.