



Forensic Analytical
Analytical Report

San Francisco • 3777 Depot Road, Suite 409, Hayward, CA 94545 • Phone 510/887-8828 • Fax 510/887-4218
Los Angeles • 2959 Pacific Commerce Drive, Rancho Dominguez, CA 90221 • Phone 310/763-2374 • Fax 310-763-8664

Bulk Material Analysis
Method: 40 CFR 763, Subpart F, Appendix A (AHERA)

Client:
Chico Unified School District
Mr. Ron Jones
2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: 257027
Date Received: 07/31/96

P.O. Num: 97-404
Job ID:
Site: Bidwell

Sample Number	Lab Number	Total Asbestos	Total Fibrous Non-Asbestos	(Breakdown by type)
008 Off-white semifibrous material with brown paint. Asbestos in off-white material (1-5%). Composite reported.	19652724	1-5%	Trace%	Chrysotile (1-5%) Cellulose (Trace%)
009 Off-white semifibrous material with beige paint. Asbestos in off-white material (1-5%). Composite reported.	19652725	1-5%	Trace%	Chrysotile (1-5%) Cellulose (Trace%)

David Kahane

David Kahane, C.I.H., Laboratory Director, Hayward Laboratory

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full with approval from Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Samples submitted to Forensic Analytical are retained for a period of six months and then disposed of according to all state and federal guidelines.



BULK SAMPLE REQUEST FORM

CLIENT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928		PHONE: 916-891-4179 FAX: 916-891-3190	DATE: 7-30-96
		Circle the Method and Turn Around Time 2 hr/12hr/24hr/48hr/Ext	Results Needed: 7-31-96 3:00pm by FAX
		<input checked="" type="checkbox"/> PLM <input type="checkbox"/> Standard / Point Count	Gravimetry Prep
		CONTACT:	
P.O.# 97-404	JOB #	AA/Flame AA/Furnace ICP	METALS:
SITE: Bidwell			

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
008	7-29-96	Rear wall of Gym
009	7-29-96	Rear wall of Gym
		Please separate layers and analyze each layer separately, and report accordingly.

Sampled by: <i>[Signature]</i>	Date: 7-29-96	Time:
Relinquished by: <i>[Signature]</i>	Received By: <i>[Signature]</i>	Date/Time: 7-30-96 / 4:30 PM
Date/Time:	Sealed Condition (circle one) YES / NO	
Relinquished by:	Received By:	
Date/Time:	Date/Time:	
	Sealed Condition (circle one) YES / NO	



Forensic Analytical
Analytical Report

San Francisco • 3777 Depot Road, Suite 409, Hayward, CA 94545 • Phone 510/887-8828 • Fax 510/887-4218
Los Angeles • 2959 Pacific Commerce Drive, Rancho Dominguez, CA 90221 • Phone 310/763 2374 • Fax 310 763-8684

Bulk Material Analysis
Method: 40 CFR 763, Subpart F, Appendix A (AHERA)

Client:
Chico Unified School District
Mr. Ron Jones
2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: 256860
Date Received: 07/26/96

P.O. Num: 97-404
Job ID:
Site: BJHS

Sample Number	Lab Number	Total Asbestos	Total Fibrous Non-Asbestos	(Breakdown by type)
001 Off-white nonfibrous material.	19651839	Non-Det.‡	Trace‡	Cellulose (Trace‡)
002 Beige nonfibrous material.	19651840	1-5‡	Trace‡	Chrysotile (1-5‡) Cellulose (Trace‡)
003 Brown nonfibrous material.	19651841	Non-Det.‡	Trace‡	Cellulose (Trace‡)
004 Brown nonfibrous material.	19651842	Non-Det.‡	Trace‡	Cellulose (Trace‡)
005 Off-white semifibrous material.	19651843	1-5‡	Trace‡	Chrysotile (1-5‡) Cellulose (Trace‡)
006 Brown nonfibrous material.	19651844	Non-Det.‡	Trace‡	Cellulose (Trace‡)
007 Brown nonfibrous material.	19651845	Non-Det.‡	Trace‡	Cellulose (Trace‡)

David Kabane, C.I.H., Laboratory Director, Hayward Laboratory

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full with approval from Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Samples submitted to Forensic Analytical are retained for a period of six months and then disposed of according to all state and federal guidelines.



BULK SAMPLE REQUEST FORM

CLIENT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928		PHONE: 916-891-4179 FAX: 916-891-3190	DATE: 7-25-96
		Circle the Method and Turn Around Time 2 hr/12hr/24hr/48hr/Ext	Results Needed: 7-26-96 3:00pm By FAX
		PLM: <u>Standard</u> Point Count	Gravimetry Prep
CONTACT: Kip Hanson		TEM: QUAL. / QUANT. / WATER	
P.O.# 97-404	JOB #	AA/Flame	AA/Furnace ICP
SITE: BJHS		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
001	7/25/96	Covered walk front of locker Room
002		Covered walk between Gym/Boys locker Exit.
003		Back of locker first layer Against wall
004		Back of locker Room
005		Storage Room (Back) off Gym
006		Kit By Dumpster
007	✓	out of can

Sampled by: Kip Hansen <i>(Signature)</i>	Date: 7-25-96	Time: 4:00pm
Relinquished by: Kip Hanson	Received By: FED EX <i>(Signature)</i>	Date/Time: 7/26/96
Date/Time: 7-25-96 4:30pm	Sealed Condition (circle one) YES / NO	<i>(Signature)</i>
Relinquished by:	Received By:	
Date/Time:	Date/Time:	
	Sealed Condition (circle one) YES / NO	



Forensic Analytical
Analytical Report

San Francisco • 3777 Depot Road, Suite 409, Hayward, CA 94545 • Phone 510/887-8828 • Fax 510/887-4218
Los Angeles • 19443 Laurel Park Road, Suite 101, Rancho Dominguez, CA, 90220 • Phone 310/763-2374 • Fax 310/763-8684

Bulk Material Analysis
Method: 40 CFR 763, Subpart F, Appendix A (AHERA)

Client:
Chico Unified School District
Mr. Ron Jones
2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: 251589
Date Received: 03/15/96

P.O. Num: 96-4122
Job ID:
Site: Bidwell Junior High - Gym

Sample Number	Lab Number	Total Asbestos	Total Fibrous Non-Asbestos	(Breakdown by type)
BJH-406A-1 Grey/white plaster and tan paint.	19620061	Non-Det. %	Trace %	Cellulose (Trace %)
BJH-406A-2 Grey/white plaster and tan paint.	19620062	Non-Det. %	Trace %	Cellulose (Trace %)

Patrick E. Little

Patrick E. Little, Optical Laboratory Supervisor, Hayward Laboratory

Analytical results and reports are generated by Forensic analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full with approval from Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Samples submitted to Forensic Analytical are retained for a period of six months and then disposed of according to all state and federal guidelines.

FORENSIC ANALYTICAL

Page _____ of 2

FAX TRANSMISSION
Summary of Results
Polarized Light Microscopy

To: _____ Date/Time: 3/18/94
Chico Unified School District

Project :
Report #: 251589

Attn: Ron Sender: K. Wentz

If you do not receive all pages, please contact Sender at (510) 887-8328

C: Chrysotile Cr: Crocidolite
A: Amosite ND: No Asbestos detected
P : Preliminary; subject to review

Sample Number	Asbestos %	Asb. Type(s)	Notes
BJH-406A-1	<u>ND</u>	_____	_____
BJH-406A-2	<u>ND</u>	_____	_____

FAXED TO: _____

A hard copy report will follow in the mail. Thank you.

Supervisor Approval: [Signature]