

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 27, 1991

SCHOOL Citrus Elementary INSPECTOR Robert Peters *R.P.*

BLDG.	HOMOG.	ASBESTOS MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	9" VFT	1-5		Classroom & Staff Room	(1) Good (4)
B	9" VFT	1-5		Workroom of Library	(1) Good (4)
B	9" VFT	1-5		Speech Room	(1) Good (4)
B	Vent Duct Connector	35-40		RR Attic	(1) Good (4)
C	PW Str	40-50		Basement & Storage	(7) Removed
D	9" VFT	1-5		MPR (Green)	(5) (7) Removed 5%
D	Vent Duct Connector	35-40		MPR - Stage Office	(7) Removed
D	PW Jnt	Assumed		Kitchen Storage	(5) - (3)
D	PW Str	Assumed		Basement (C&D)	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 27, 1991

SCHOOL Citrus Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	PW Debris	Assumed	Basement (C&D)	(7) Removed
D	9" VFT	1-5	Kitchen & Storage	(1) Good (4)
D	Aircell	Assumed	Old Boiler	(7) Removed
D	PW Black	Assumed	Boiler Room	(7) Removed
D	Mud Jnt	25-35	Boiler Room	(7) Removed
D	PW Str	Assumed	Boiler Room	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 3, 1991

SCHOOL Citrus Elementary INSPECTOR Robert Peters R.P.

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	9" VFT	1-5	Classroom & Staff Room	(1) Good (4)
B	9" VFT	1-5	Workroom of Library	(1) Good (4)
B	9" VFT	1-5	Speech Room	(1) Good (4)
B	Vent Duct Connector	35-40	RR Attic	(1) Good (4)
C	PW Str	40-50	Basement & Storage	(7) Removed
D	9" VFT	1-5	MPR (Green)	(5) (7) Removed
D	Vent Duct Connector	35-40	MPR - Stage Office	(7) Removed
D	PW Jnt	Assumed	Kitchen Storage	(1) Good (4)
D	PW Str	Assumed	Basement (C&D)	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 3, 1991

SCHOOL Citrus Elementary INSPECTOR Robert Peters

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	PW Debris	MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	9" VFT		Assumed	Basement (C&D)	(7) Removed
D	Aircell	1-5	Assumed	Kitchen & Storage	(1) Good (4)
D	PW Black		Assumed	Old Boiler	(7) Removed
D	Mud Jnt		Assumed	Boiler Room	(7) Removed
D	PW Str	25-35	Assumed	Boiler Room	(7) Removed
				Boiler Room	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)