

DISTRICT Chico Unified School District DATE December 11, 1995

SCHOOL Citrus Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	9" VFT	1-5	Classroom & Staff Room	(1) (4)
B	9" VFT	1-5	Workroom of Library	(1) (4) <i>Carpet over all</i>
B	9" VFT	1-5	Speech Room	(1) (4) <i>Carpet over all</i>
B	Vent Duct Connector	35-40	RR Attic	(1) (4)
C	PW Str	40-50	Basement & Storage	(7)
D	9" VFT	1-5	MPR (Green)	(7)
D	Vent Duct Connector	35-40	MPR - Stage Office	(7)
D	PW Jnt	Assumed	Kitchen Storage	(1) (4)
D	PW Str	Assumed	Basement (C&D)	(7)
D	Tran Pipe	Assumed	Kitchen Storage	(1) <del>(4)</del> 5-7
D	Pipewrap	Assumed	Stage Fan Rooms	(1) (4)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 11, 1995

7-15-97

SCHOOL Citrus Elementary INSPECTOR Ron Jones

HOMOG. ASBESTOS MATERIAL LOCATION

CONDITION: CODE & COMMENTS

BLDG.	MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	PW Debris	Assumed	Basement (C&D)	(7)
D	9" VFT	1-5	Kitchen & Storage	(7)
D	Aircell	Assumed	Old Boiler	(7)
D	PW Black	Assumed	Boiler Room	(7)
D	Mud Jnt	25-35	Boiler Room	(7)
D	PW Str	Assumed	Boiler Room	(7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)