

Alan S. Chambers
Architect
Eagle Architect
349 Silver Lake Dr.
Chico CA 95973

Main Gym HVAC Replacement & Re-Roof
Pleasant Valley High School
Chico Unified School District
Chico, CA 95926
DSA File No: 4-12
DSA Application No: 02-115458



Addendum No. 2
February 23, 2017

A. Work described in this addendum is to be of the same quality as specified in the original documents.

B. Addendum Drawings

NONE

C. Project Manual

1. 00 70 00 GENERAL CONDITIONS

- a. Specification 00 70 00 item 16.4.2 states a liquidated damage amount shall be paid to district from contractor for each calendar day past completion date. The amount per calendar day is \$500.

2. 01 76 00 PROTECTING INSTALLED CONSTRUCTION

- a. Remove and replace section 01 76 00 included in this addendum.

D. Drawings

1. Sheet A-5.2 ROOF DETAILS

- a. Details 1, 5 & 9 calls out Dens Deck to be ½” thick. Specification 07 22 00 item 2.02E and 07 54 00 item 2.3B states Dens Deck Prime to be ¼” thick. The specifications is correct- Dens Deck is to be ¼” thick.

E. Additional Information Provided

NONE

E. Bid Inquires and Responses

1. Page A5.2 Detail 9 shows ½” Dens Deck and specifications section 07 22 00 2.02E states ¼” Primed Dens Deck. Which will be used for the fully adhered TPO system?. (Ref. Email RFI).

Response: Details 1, 5 & 9 calls out Dens Deck to be ½” thick. Specification 07 22 00 item 2.02E and 07 54 00 item 2.3B states Dens Deck Prime to be ¼” thick. The specifications is correct- Dens Deck is to be ¼” thick.

2. After reviewing the plans and specifications I have a question regarding the conduit installation on the roof. Is the conduit type GRC, IMC or EMT? Please advise. (Ref Email RFI).

Response: Specification Section 26 05 33, 3.1, A, indicates that EMT conduit may be installed at exposed locations above 8’. Clarification: Conduits installed on top of roof or covered walk structure shall be interpreted to be below 8’ A.F.F. Therefore, conduit installed on top of roof or covered walk structure shall be rigid steel or IMC conduit.

3. Do you have any site electrical drawings for this building and the Center for the Arts building? We need to pull low voltage communication wiring from either the science Classroom Building of the Center for the Arts Building to the West Gym. Please advise. (Ref Email RFI).

Response: The site electrical as-built drawings (if they exist) will be provided by the district after the project is awarded. It is up to each contractor to field verify the existing conditions prior to bidding the project.

END ADDENDUM NO 2

PART 1 – GENERAL

1.01 SUMMARY

- A. Protection for products, including Owner-provided products, after installation.

1.02 RELATED SECTIONS

- A. Section 01 60 00: Protection of products in storage.
- B. Individual Sections: Specific protection of installed products, as applicable.

1.03 PROTECTION AFTER INSTALLATION

- A. Protect installed products and control traffic in immediate area to prevent damage from subsequent operations.
- B. Provide protective covers at walls, projections, corners, jambs, sills, and soffits in and adjacent to traffic areas.
- C. Protect finished floors and stairs from dirt, wear and damage:
 - 1. Secure heavy sheet goods or similar protective materials in place, in areas subject to foot traffic.
 - 2. Lay planking or similar rigid materials in place, in areas subject to movement of heavy objects.
 - 3. Lay planking or similar grid materials in place in areas where storage of products will occur.
 - 4. Distribute loads of heavy stockpile materials, such as gypsum wall board, to prevent floor loading conditions in excess of loading capacity.
- D. Protect waterproofed and roofed surfaces:
 - 1. Restrict use of surfaces for traffic of any kind, and for storage of products.
 - 2. When an activity is mandatory, obtain recommendations for protection of surfaces from installer or manufacturer. Install protection and remove on completion of activity. Restrict use of adjacent unprotected areas.
- E. Restrict traffic of any kind across planted lawn and landscape areas.

PART 2 – PRODUCTS

NOT USED

PART 3 – EXECUTION

NOT USED

END OF SECTION