

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	1	NONE DETECTED	5,735 S	ADMINISTRATION AREA	(13) SAMPLE HMS-CHS-01 COLLECTED ON 3-28-88.	N/A
M	12" VFT BEIGE	2	TRACE	5,700 S	RECEPTION AREA	(1) (4) 1, 4	N
M	12" ACT	3	NONE DETECTED	3,550 S	PRINCIPLES OFFICE, COMPTROLLER, 120, AND CLASSROOMS 102-107	(13) SAMPLE HMS-CHS-03 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	7	5-10%	20 JOINTS	DARK ROOM ATTIC (CLASSROOM 111)	(11)	Y
T	MESH WRAP	8	12-20%	½ L	DARK ROOM ATTIC (CLASSROOM 111)	(11) INACCESSIBLE.	Y
M	TRANSITE PANELS	95	ASSUMED	1,300 S	ALONG WALKWAYS, JANITORS CLOSETS, RESTROOMS, AND STAIRWELLS	(1) (4) PANELS PAINTED WHITE 11/19/03. 1, 4	N
M	DRYWALL & JOINT COMPOUND	166	None Detected	UNDETERMINED	THROUGHOUT INTERIOR WALLS	(13) CUSD sample CHS01 – 05 dated 12/27/06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: A Upstairs

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT BEIGE	2	TRACE	5,800 S	UPSTAIRS CLASSROOMS	(1) (4) 1,4	N
M	2' X 4' FCP	6	NONE DETECTED	10,000 S	UPSTAIRS CLASSROOMS	(13) SAMPLE HMS-CHS-06 COLLECTED ON 3-28-88.	N/A
M	DRYWALL & JOINT COMPOUND	167	ASSUMED	UNDETERMINED	THROUGHOUT INTERIOR WALLS	(1) DISTRICT MUST CERTIFY 1,4	N
M	Elevator addition in 2007		Certified Non-Asbestos			(13) Letter on file	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	13	NONE DETECTED	10,000 S	ALL CLASSROOMS	(13) SAMPLE HMS-CHS-13 COLLECTED ON 3-28-88.	N/A
M	TRANSITE PANELS	95	ASSUMED	1,300 S	ALONG WALKWAYS, JANITORS CLOSETS, RESTROOMS, AND STAIRWAYS	(1) (4) ⁴ PANELS PAINTED WHITE 11/19/03.	N
M	12" VFT TAN	152	CERTIFIED ASBESTOS FREE	9,430 S	THROUGHOUT	(13) CERTIFICATION LETTER ON FILE. MODERNIZATION 2003	N/A
M	DRYWALL & JOINT COMPOUND	168	ASSUMED	UNDETERMINED	THROUGHOUT	(1) DISTRICT MUST CERTIFY ₁	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	14	1-5%	9,513 S	CLASSROOMS 1-11	(7) ABATED IN JUNE, 2003 ACCORDING TO CHICO USD RECORDS. MODERNIZATION 2003	N
M	TRANSITE PANELS	95	ASSUMED	1,300 S	EXTERIOR OF BUILDING	(1) (4) PANELS PAINTED WHITE 11/19/03. <i>4</i>	N
M	12" VFT TAN	150	CERTIFIED ASBESTOS FREE	9,513 S	CLASSROOMS 1-11	(13) LETTER IN FILE AS OF 6/2005. MODERNIZATION 2003	N/A
M	DRYWALL & JOINT COMPOUND	169	ASSUMED	UNDETERMINED	THROUGHOUT	(1) DISTRICT MUST CERTIFY <i>1,4</i>	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: D & H

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	PLASTER	38	1-5%	300 S	934 & 935 (FKA INSTRUMENT STORAGE ROOM & MUSIC STORAGE), AND BAND ROOM OFFICE	(1) (4) TROWELED ON CEILING. <u>14</u>	N
M	9" VFT YELLOW	39	5-10%	1,410 S	MUSIC WING HALL, CHORAL ROOM UNDER RISERS, BAND ROOM OFFICE, & CHORAL ROOM STORAGE	(7)	N/A
M	12" VFT TAN	150	CERTIFIED ASBESTOS FREE	1,200 S	MUSIC WING HALL	(13) CERTIFICATION LETTER ON FILE AS OF 6/2005. MODERNIZATIO 2003	N/A

School: Chico Senior High School

Building: L

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	17	NONE DETECTED	11,155 S	ALL ROOMS	(13) SAMPLE HMS-CHS-17 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	19	5-10%	20 JOINTS	LIBRARY ATTIC	(11)	Y
M	12" VFT MOTTLED	151	CERTIFIED ASBESTOS FREE	850 S	LIBRARY ENTRANCE/OFFICE	(13) CERTIFICATION LETTER ON FILE AS OF 6/2005. MODERNIZATION 2003	N/A
M	DRYWALL & JOINT COMPOUND	170	ASSUMED	UNDETERMINED	THROUGHOUT	(1) <u>1</u>	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: F

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	MUD JOINTS	52	5-10%	125 JOINTS	FINE ARTS	(12)	Y
M	2' X 4' FCP	59	NONE DETECTED	4,500 S	CLASSROOMS 1-5	(13) SAMPLE HMS-CHS-59 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	60	5-10%	12 L	CLASSROOM 1	(12) COULD NOT LOCATE	Y
M	9" VFT	61	TRACE	4,500 S	ALL CLASSROOMS	(7) REMOVED DURING 2004 MODERNIZATION.	N/A
M	TRANSITE PANELS	95	ASSUMED	150 S	2 KILNS	(7) REMOVED DURING 2004 MODERNIZATION.	N/A
M	KILN BRICK, TAN	151	NONE DETECTED	10.5 S	INSIDE OLDER TRANSITE PANELS ENCASED KILN	(13) SAMPLE HMS-R1303-01A COLLECTED ON 4-13-04.	N/A
M	KILN BRICK, WHITE	152	NONE DETECTED	10.5 S	LARGER OLDER TRANSITE PANEL ENCASED KILN	(13) SAMPLE HMS-R1303-02A COLLECTED ON 4-13-04.	N/A
M	KILN BRICK, WHITE	153	NONE DETECTED	10.5 S	METAL ENCASED CRESS ELECTRIC KILN MODEL A-22-H	(13) SAMPLE HMS-R1303-03A COLLECTED ON 4-13-04.	N/A
M	KILN BRICK	154	NONE DETECTED	10.5 S	SMALL KILN APPROXIMATELY 2' HIGH BY 14" SQUARE WITH B-19 ON SIDE	(13) SAMPLE HMS-R1303-04A COLLECTED ON 4-13-04.	N/A
M	KILN BRICK	155	NONE DETECTED	10.5 S	3' SQUARE KILN	(13) SAMPLE HMS-R1303-05A COLLECTED ON 4-13-04.	N/A
S	STUCCO	156	<1% CHRYSOTILE	220 S	EXTERIOR WALL AT SOUTH SIDE OF CERAMICS LAB ROOM 505	(1) (4) <i>14</i> SAMPLE HMS-R1303-06A COLLECTED ON 4-13-04.	N
M	VINYL COVERED TAGBOARD	157	NONE DETECTED	800 S	CERAMICS LAB ROOM 505D	(13) SAMPLE HMS-R1303-07A COLLECTED ON 4-13-04.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: S

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	22	NONE DETECTED	8,000 S	ROOMS 1-7	(13) SAMPLE HMS-CHS-22 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	23	5-10%	40 JOINTS	ROOMS 1-7	(12)	Y
M	9" VFT	24	1-5%	8,100 S	SCIENCE LAB/STORAGE	(1) (4) 4	N
T	PIPE WRAP STRAIGHT	26	65-70%	12 L	ROOM 5 (STORE ROOM)	(7) REMOVED IN 2004.	N/A
M	BLACK COUNTER TOPS	99	ASSUMED	UNDETERMINED	IN ALL SCIENCE ROOMS	(7) REPLACED ON 6/14/04.	N/A
M	12" VFT TAN	171	NON ASBESTOS	8,000 S	ALL ROOMS EXCEPT SCIENCE LAB/STORAGE	(1) (4) MODERNIZATION 2004 MANUFACTURER LETTER ON FILE	N

CONDITION CODE

- General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: _____

District: Chico Unified School District

Inspector: _____

School: Chico Senior High School

Building: LH

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPEWRAP STRAIGHT	45	35-40%	3 L	CUSTODIAL ROOM	(1) (4)	Y
T	MUD JOINTS	52	5-10%	10 EACH	UNDER STAGE 939	(10)	Y
M	9" VFT GREY	55	1-5%	6,800 S	943-KITCHEN & 940-MPR	(2) CRACKED & MISSING TILES IN THE KITCHEN, STAFF ROOM.	N
S	PLASTER	57	1-5%	900 S	ROOMS 940-951	(1) (4) PAINTED TROWELED ON CEILING.	N
M	TRANSITE PANELS	95	ASSUMED	364 S	951-SNACK BAR, 939-STAGE, AND CAFE	(1) (4)	N
M	9" VFT	101	ASSUMED	250 S	ON STAGE-939	(1) (6)	N
T	MUD JOINTS	102	5-10%	4 JOINTS	942-TEACHER'S LOUNGE RESTROOMS	(1) (4)	Y
M	TRANSITE PIPE FLUE	103	ASSUMED	12 L	945-WATER HEATER ROOM (2 PIPES)	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: _____

District: Chico Unified School District

Inspector: _____

School: Chico Senior High School

N/A

Building: LH
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	172	NON ASBESTOS	36 S	KITCHEN OFFICE AND SUPPLY ROOM	(1) MANUFACTURER LETTER ON FILE MODERNIZATION 2003	N
M	LINOLEUM	173	ASSUMED	30 S	KITCHEN RESTROOM	(1)	N
M	DRYWALL & JOINT COMPOUND	174	ASSUMED	UNDETERMINED	THROUGHOUT	(1)	N
M	12" ACT	175	ASSUMED	UNDETERMINED	THROUGHOUT	(1)	N
M	WHITE LINOLEUM	176	NONE DETECTED	300 S	ON COLUMNS	(2) (13) SAMPLE ECG-07-465-02A COLLECTED ON 5-11-07.	N/A
M	12" VFT BEIGE	177	NONE DETECTED		UNDER KITCHEN DISHWASHER	(13) SAMPLE CUSD CHS01 COLLECTED ON 6-0-06. MODERNIZATION 2003	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: David Hunt

School: Chico Senior High School

Building: GYM

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALLS & CEILING PLASTER	46	NONE DETECTED	2,000 S	ALL ROOMS EXCEPT BOILER	(13) SAMPLE HMS-CHS-46A-C COLLECTED ON 3-28-88. ADDITIONAL SAMPLES HMS-93103-03A-C COLLECTED ON 7-8-93.	N/A
T	PIPEWRAP STRAIGHT	50	50-55%	2,700 S	GIRL'S & BOY'S LOCKER ROOM AND BOILER ROOM CRAWL SPACES	(10) ISOLATED & RESTRICTED	Y

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: IA (FKA IT-1000)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPEWRAP STRAIGHT	45	35-40%	700 L	AUTO SHOP, LOFT, AND WOOD SHOP	(7) REMOVED IN 2004.	N/A
T	BREECHING INSULATION	90	15-20% AMOSITE	100 S	WOOD FINISHING ROOM	(7) REMOVED IN 2004. REPRESENTED BY SAMPLES HMS-R1303-09A & B COLLECTED ON 4-13-04.	N/A
M	9" VFT TAN	152	ASSUMED	1,800 S	HALLWAYS AND CLASSROOMS IT2 & IT6	(7) REMOVED IN 2004.	N/A
M	DRYWALL & JOINT COMPOUND	158	<1% CHRYSOTILE (COMPOSITE)	400 S	NORTH & SOUTH WALL OF PROJECT AND HAM ROOMS OFF ELECTRONICS, SOUTH WEST CORNER WALL OF NORTH OFFICE BY RESTROOMS, OFFICE BY TOILET ROOM TO MECHANICAL DRAWING, AND FINISH ROOM	(7) REMOVED IN 2004. SAMPLES HMS-R1303-10A-E COLLECTED ON 4-13-04. DRYWALL - NONE DETECTED, JOINT COMPOUND - 1-2% CHRYSOTILE, AND COMPOSITE - <1% CHRYSOTILE .	N/A
M	WHITE DOOR INSULATION	159	10-15% CHRYSOTILE 10-15% AMOSITE	40 S	PROJECT AND HAM ROOM	(7) REMOVED IN 2004. SAMPLE HMS-R1303-11A COLLECTED ON 4-13-04.	N/A
S	UPPER WALL PLASTER	165	NONE DETECTED	UNDETERMINED	TOILET ROOM	(7) REMOVED IN 2004. SAMPLES HMS-R1303-08A-C COLLECTED ON 4-13-04.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

Inspector: Daniel Hart

Building: AG-1100

District: Chico Unified School District
School: Chico Senior High School

Material Class	Material	Homo Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALL PLASTER	46	1-5%	950 S	CLASSROOM 2	(1) (4)	N
M	TRANSITE PANELS	48	15-20%	200 S	CLASSROOM 1 WELD BOOTHS & TABLES	(7) REMOVED IN 2004 MODERNIZATION.	N/A
M	12" VFT MOTTLED & YELLOW MASTIC	89	NONE DETECTED	400 S	CLASSROOM 2	(13) REPRESENTED BY SAMPLE HMS-R1303-12A COLLECTED ON 4-13-04.	N
M	TRANSITE PIPES	96	ASSUMED	12 L	CLASSROOM 1 (2 PIPES)	(7) REMOVED IN 2004.	N/A
M	WALL PLASTER	160	NONE DETECTED	150 S	SOUTH WEST CORNER AREA BY DOOR OF TOILET ROOM OF CLASSROOM 1	(13) SAMPLE HMS-R1303-15A COLLECTED ON 4-13-04.	N/A
S	STUCCO	161	NONE DETECTED	UNDETERMINED	EXTERIOR SOUTH ENTRY DOOR AND EAST WALL BY COKE MACHINE	(13) SAMPLES HMS-R1303-16A & B COLLECTED ON 4-13-04.	N/A
M	LINOLEUM LIKE COUNTER TOP W/ASPHALT LIKE BACKING - GREEN	162	NONE DETECTED	UNDETERMINED	CLASSROOM 3	(13) SAMPLE HMS-R1303-17A COLLECTED ON 4-13-04.	N/A
M	BROWN COLORED GLOSS LIKE FLOOR FINISH	163	NONE DETECTED	UNDETERMINED	HALLWAY BY CLASSROOM 2	(13) SAMPLE HMS-R1303-13A COLLECTED ON 4-13-04.	N/A
M	GREEN COLORED GLOSS LIKE FLOOR FINISH	164	NONE DETECTED	UNDETERMINED	TOILET ROOM OFF CLASSROOM 1	(13) SAMPLE HMS-R1303-14A COLLECTED ON 4-13-04.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 10-9-14

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Senior High School

Building: 20 Portable Classrooms and 2 Portable Restrooms on West Campus

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
					PORTABLE CLASSROOMS PC1-PC17 AND 2 PORTABLE RESTROOMS	CERTIFICATION LETTER ON FILE.	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS