

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT C - Classrooms 3-6

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (GREEN) & ADHESIVE	4	1-5%	4,500 S	CLASSROOMS 3-6 AND STAFF ROOM	(1) (4)	N
S	ACOUSTIC CEILING PLASTER	5	1-5%	5,000 S	CLASSROOMS 3-6 AND STAFF ROOM	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	480 S	CLASSROOMS 3-6	(1) (4)	N
S	STUCCO	252	ASSUMED POSITIVE	1,000 S	COVERED WALKWAY AT ROOMS 3-6	(1) (4)	N
M	WINDOW GLAZING PUTTY	254	ASSUMED POSITIVE	50 S	COVERED WALKWAY AT ROOMS 3-6	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District

Inspector:

School:

Fair View High School

Building: UNIT D - Restrooms & Custodial Room

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	ACOUSTIC CEILING PLASTER	5	1-5%	1,000 S	RESTROOMS, CUSTODIAL ROOMS, AND BOILER ROOM	(1) (4)	N
T	LARGE MUD JOINT	6	ASSUMED POSITIVE	22 JOINTS	BOILER ROOM	(1) (4)	Y
T	SMALL MUD JOINT	7	ASSUMED POSITIVE	26 JOINTS	BOILER ROOM	(1) (4)	Y
S	WALL PLASTER	31	ASSUMED POSITIVE	400 S	RESTROOMS	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

S	STUCCO	252	ASSUMED POSITIVE	200 S	COVERED WALKWAY	(1) (4)	N
---	--------	-----	---------------------	-------	-----------------	---------	---

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District

Inspector:

School:

Fair View High School

Building: UNIT E - Classrooms 7-10

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (BEIGE) & ADHESIVE	4	1-5%	4,500 S	CLASSROOMS 7-10, WORK ROOM AND STAFF RESTROOMS	(1) (4)	N
S	ACOUSTIC CEILING PLASTER	5	1-5%	5,000 S	CLASSROOMS 7-10, WORK ROOM, AND STAFF RESTROOMS	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	480 S	CLASSROOMS 7-10	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	400 S	CLASSROOMS 7-10	(1) (4)	N
S	STUCCO	252	ASSUMED POSITIVE	1,000 S	COVERED WALKWAY	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

M	WINDOW GLAZING PUTTY	254	ASSUMED POSITIVE	50 S	COVERED WALKWAY	(1) (4)	N
---	----------------------	-----	------------------	------	-----------------	---------	---

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District

Inspector:

School:

Fair View High School

Building: UNIT G - Classrooms 11-14

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (GREEN) & ADHESIVE	4	1-5%	4,500 S	CLASSROOMS 11-14	(1) (4)	N
S	ACOUSTIC CEILING PLASTER	5	1-5%	5,000 S	ALL CLASSROOMS AND BOTH RESTROOMS	(1) (4)	N
S	WALL PLASTER	31	ASSUMED POSITIVE	1,200 S	CUSTODIAL ROOM AND RESTROOMS	(1) (4)	N
M	BASE COVE ADHESIVE	250	ASSUMED POSITIVE	480 S	CLASSROOMS 11-14	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

S	STUCCO	252	ASSUMED POSITIVE	1,000 S	COVERED WALKWAY	(1) (4)	N
M	WINDOW GLAZING PUTTY	254	ASSUMED POSITIVE	50 S	COVERED WALKWAY	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT F - MPR

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPE WRAP STRAIGHT	3	70-75%	20 L	KITCHEN, WATER HEATER ROOM	(1) (4) MATERIAL REMOVED FROM MPR STORAGE AND CUSTODIAL ROOM	Y
M	9" VINYL FLOOR TILE (GREEN) & ADHESIVE	4	1-5%	6,000 S	MPR, KITCHEN, AND ADMINISTRATION	(1) (4)	N
T	MUD JOINT	7	ASSUMED POSITIVE	20 JOINTS	KITCHEN, WATER HEATER ROOM, MPR STORAGE, AND CUSTODIAL ROOM	(1) (4)	N
M	12" ACOUSTIC CEILING TILE	30	ASSUMED POSITIVE	2,500 S	MPR	(1) (4)	N
S	WALL PLASTER	31	ASSUMED POSITIVE	5,000 S	THROUGHOUT BUILDING	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

M	CEMENTITIOUS TRANSITE PIPE	99	ASSUMED POSITIVE	6 L	KITCHEN WATER HEATER ROOM	(1) (4)	N
M	BASE COVE ADHESIVE	250	ASSUMED POSITIVE	250 S	KITCHEN, MPR STORAGE, AND WATER HEATER ROOM	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT F - MPR
(Continued)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	STUCCO	252	ASSUMED POSITIVE	1,400 S	COVERED WALKWAY	(1) (4) THIS MATERIAL WAS PREVIOUSLY MIS-IDENTIFIED AS ACOUSTIC PLASTER, MATERIAL #5.	N
M	COVE BASE ADHESIVE	256	ASSUMED POSITIVE	200 S	MPR	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT H - Classroom 17

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	SHEET VINYL FLOORING (BEIGE) & ADHESIVE	10	NONE DETECTED	100 S	GIRL'S & BOY'S RESTROOMS	(13) SAMPLE HMS-PAR-08 COLLECTED ON 3-30-88	N/A
M	DRYWALL & JOINT COMPOUND	32	ASSUMED POSITIVE	1,800 S	CLASSROOM 17 AND GIRL'S & BOY'S RESTROOMS	(1) (4)	N
M	2' X 4' CEILING PANELS	65	NONE DETECTED	900 S	CLASSROOM 17	(13) SAMPLE HMS-CUSD-PART-200A COLLECTED 4-11-95	N/A
M	12" VINYL FLOOR TILE (CREAM) & ADHESIVE	103	ASSUMED POSITIVE	720 S	CLASSROOM 17	(1) (4) (11) 600 SQUARE FEET COVERED WITH CARPET	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	130 L	CLASSROOM 17	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

M	CARPET ADHESIVE	251	ASSUMED POSITIVE	600 S	CLASSROOM 17	(1) (4)	N
---	-----------------	-----	---------------------	-------	--------------	---------	---

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT I

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND	32	ASSUMED POSITIVE	2,500 S	ROOMS 15 & 16	(11)	N
M	2' X 4' CEILING PANEL - GASH/PINHOLE PATTERN	65	NONE DETECTED	1,800 S	ROOMS 15 & 16	(13) SAMPLE HMS-CUSD-PART-200A COLLECTED 4-11-95	N/A
M	12" VINYL FLOOR TILE (CREAM) & ADHESIVE	103	ASSUMED POSITIVE	240 S	ROOMS 15 & 16	(11) COVERED WITH 12" VINYL FLOOR TILE PINK IN ROOM 16 (1) (4) ROOM 15	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	260 L	ROOMS 15 & 16	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

M	CARPET ADHESIVE	251	ASSUMED POSITIVE	1,200 S	ROOMS 15 & 16	(1) (4)	N
M	12" VINYL FLOOR TILE (PINK) & ADHESIVE	260	ASSUMED POSITIVE	240 S	ROOM 16	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT J

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 8' ACOUSTIC CEILING TILE WOOD	50	NON-SUSPECT	480 S	SFA TRAILER (916) AND SPEECH TRAILER	(13)	N/A
M	2' X 4' CEILING PANELS	65	NONE DETECTED	900 S	LIBRARY/COMPUTER ROOM (917)	(13) SAMPLE HMS-CUSD-PART-200A COLLECTED 4-11-95	N/A
M	DRYWALL	66	NONE DETECTED	400 S	COMPUTER ROOM (917)	(13) SAMPLE HMS-CUSD-PART-201A COLLECTED 4-11-95	N/A
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	160 S	THROUGHOUT BUILDING	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	900S	THROUGHOUT BUILDING	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT K - Portables 18 & 19

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND	32	ASSUMED POSITIVE	2,500 S	PORTABLES 18 & 19	(11) COVERED WITH TAGBOARD	N
M	12" VINYL FLOOR TILE (LIGHT GRAY) & ADHESIVE	51	ASSUMED POSITIVE	300 S	PORTABLES 18 & 19	(1) (4)	N
M	2' X 4' CEILING PANEL - FISSURE PATTERN	52	ASSUMED POSITIVE	1,800 S	PORTABLES 18 & 19	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	240 L	PORTABLES 18 & 19	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

M	CARPET ADHESIVE	251	ASSUMED POSITIVE	640 S	PORTABLES 18 & 19	(1) (4)	N
---	-----------------	-----	---------------------	-------	-------------------	---------	---

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT A - Portable 1

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' CEILING PANEL - FISSURE PATTERN	53	ASSUMED POSITIVE	900 S	PORTABLE 1	(1) (4)	N
M	12" VINYL FLOOR TILE (CREAM) & ADHESIVE	61	ASSUMED POSITIVE	300 S	PORTABLE 1 - EAST SIDE	(11) COVERED WITH SHEET VINYL FLOORING	N
M	12" VINYL FLOOR TILE (CREAM) & ADHESIVE	90	ASSUMED POSITIVE	600 S	PORTABLE 1 - WEST SIDE	(11) COVERED WITH CARPET	N
M	SHEET VINYL FLOORING (TAN) & ADHESIVE	100	ASSUMED POSITIVE	60 S	LAUNDRY AND GIRL'S & BOY'S RESTROOMS	(1) (4)	N
M	DRYWALL	101	ASSUMED POSITIVE	300 S	LAUNDRY AND GIRL'S & BOY'S RESTROOMS	(1) (4)	N
M	DRYWALL	101	ASSUMED POSITIVE	2,000 S	PORTABLE 1	(11) COVERED WITH TAGBOARD	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	150 S	THROUGHOUT BUILDING	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	600 S	PORTABLE 1 AT WEST SIDE	(1) (4)	N
M	SHEET VINYL FLOORING (BLUE SPECKLED) & ADHESIVE	253	ASSUMED POSITIVE	100 S	PORTABLE 1 AT SOUTH SIDE PORTION OF WEST & EAST SIDE	(1) (4) INSTALLED IN 2008	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT B - Portable 2

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location c	Condition: Code & Comments	Friable Yes/No
S	ACOUSTIC CEILING PLASTER	5	ASSUMED POSITIVE	1,000 S	ROOM 2 - UNIT B	(1) (4)	N
S	WALL PLASTER	31	ASSUMED POSITIVE	1,200 S	PORTABLE 2	(1) (4)	N
M	9" VINYL FLOOR TILE (GREEN) & ADHESIVE	63	ASSUMED POSITIVE	200 S	PORTABLE 2	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	100 L	THROUGHOUT BUILDING	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	100 S	SOUTH SIDE OF CLASSROOM	(1) (4)	N
S	STUCCO	252	ASSUMED POSITIVE	200 S	COVERED WALKWAY	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: UNIT L - Portable 20

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND	32	ASSUMED POSITIVE	1,250 S	PORTABLE 20	(11) COVERED WITH TAGBOARD	N
M	2' X 4' CEILING PANELS FIBERGLASS	54	NON-SUSPECT	600 S	PORTABLE 20	(13)	N/A
M	12" VINYL FLOOR TILE (WHITE) & ADHESIVE	62	ASSUMED POSITIVE	900 S	PORTABLE 20	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	150 S	PORTABLE 20	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School
Building: METAL/WOOD SHOP

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location c	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND	500	ASSUMED POSITIVE	700 S	WOOD/METAL SHOP	(1)	N
S	DW TEXTURE	501	ASSUMED POSITIVE	700 S	PORTABLE 2	(1)	N
M	12" X 12" ACOUSTICAL CEILING TILE (PINHOLE)	502	ASSUMED POSITIVE	500 S	COVERED WALKWAY	(1)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District:

Chico Unified School District
Inspector:

School:

Fair View High School - Academy of Learning
Building: PORTABLES 21-26 AND RR

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location c	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FIBERGLASS CEILING PANELS	503	ASSUMED POSITIVE	5, 800S	THROUGHOUT PORTABLES	(1)	N
M	GRAY MARBLED SHEET VINYL FLOORING	504	ASSUMED POSITIVE	5, 800 S	THROUGHOUT PORTABLES	(1)	N
M	VINYL BASE COVE	505	ASSUMED POSITIVE	800 S	THROUGHOUT PORTABLES	(1)	N
M	GRAY EPOXY FLOORING	506	ASSUMED POSITIVE	350 S	RESTROOMS	(1)	N
M	DRYWALL AND JOINT COMPOUND	507	ASSUMED POSITIVE	500 S	RESTROOMS	(1)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Fair View HS 4-18-17\Fair View HS - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS