

## SIX MONTH SURVEILLANCE HOMOGENEOUS ACBM RECORDS

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit A - Rooms 1 & 2

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (WHITE) & ADHESIVE	2	1-5%	2,800 S	CLASSROOMS 1 & 2	(1) (4) SAMPLE MAR-02 COLLECTED ON 3-30-88.	N
M	2' X 4' FCP FISSURE PATTERN	94	ASSUMED POSITIVE	1,800 S	CLASSROOMS 1 & 2	(1) (4)	N
M	CEMENTITIOUS TRANSITE PANELS	99	ASSUMED POSITIVE	300 S	ABOVE GLASS PANELS (EXTERIOR)	(1) (4)	N
M	DRYWALL & JOINT COMPOUND	105	ASSUMED POSITIVE	600 S	CLASSROOMS 1 & 2	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	170 L	CLASSROOMS 1 & 2	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

### CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit B - MPR

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (CREAM) & ADHESIVE	2	1-5%	3,160 S	KITCHEN (909), ADMIN OFFICE, MULTI PURPOSE ROOM (905), STORAGE, PIP ROOM (908), AND HEALTH OFFICE (903)	(1) (4) (11) PRINCIPAL OFFICE AND PIP ROOM (908) COVERED WITH CARPET. ADMIN OFFICE (NORTH HALF ONLY) COVERED WITH 12" VINYL FLOOR TILE BLUE.	N
M	COLD BOX CEILING	6	30-35%	20 S	COLD BOX	(1) (4) SAMPLE MAR-06 COLLECTED ON 3-30-88.	N
S	PLASTER	75	ASSUMED POSITIVE	1,000 S	KITCHEN (909) AND RESTROOMS (907 & 907A)	(1) (4)	N
M	12" ACOUSTIC CEILING TILE FISSURE PATTERN	90	ASSUMED POSITIVE	2,500 S	MULTI-PURPOSE ROOM (905) UPPER WALLS CEILING	(1) (4)	N
M	2' X 4' CEILING PANELS FISSURE PATTERN	91	ASSUMED POSITIVE	5,000 S	PRINCIPALS OFFICE, OFFICE, PIP ROOM (908), CLASSROOM A, AND HEALTH OFFICE (903)	(1) (4)	N
M	12" VINYL FLOOR TILE (BLUE) & ADHESIVE	106	ASSUMED POSITIVE	240 S	ADMIN OFFICE	(1) (4)	N
M	12"X12" VFT (OFF WHITE)	149	ASSUMED POSITIVE	200 S	PRINCIPALS OFFICE	(1)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	800 L	MPR AND KITCHEN/ADMIN OFFICE PRINCIPAL OFFICE	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	100 S	PRINCIPAL'S OFFICE	(7)	N

S	STUCCO	260	ASSUMED POSITIVE	1000 S	EXTERIOR WALL PANELS	(1) (4)	N
---	--------	-----	---------------------	--------	----------------------	---------	---

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit C - Rooms 3-5

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (BROWN) & ADHESIVE	8	1-5%	5,728 S	CLASSROOMS 3-5	(1) (4) SAMPLE MAR-08 COLLECTED ON 3-30-88.	N
M	12" ACOUSTIC CEILING TILE 1/8" HOLE PATTERN	98	ASSUMED POSITIVE	5,728 S	CLASSROOMS 3-5	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	300 L	CLASSROOMS 3-5	(1) (4)	N
S	STUCCO	260	ASSUMED POSITIVE	1,000 S	COVERED WALKWAY	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit D - Rooms 6A & 6B

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VINYL FLOOR TILE (OFF WHITE MOTTLED) & ADHESIVE	95	ASSUMED POSITIVE	240 S	CLASSROOMS 6A & 6B	(1) (4)	N
M	2' X 4' CEILING PANELS	96	ASSUMED POSITIVE	1,800 S	CLASSROOMS 6A & 6B	(1) (4)	N
M	DRYWALL & JOINT COMPOUND	107	ASSUMED POSITIVE	2,500 S	CLASSROOMS 6A & 6B	(11) COVERED WITH TAGBOARD.	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	100 L	CLASSROOMS 6A & 6B	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	240 S	CLASSROOMS 6A & 6B	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit E - Restrooms

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPE WRAP STRAIGHT	10	60-65%	150 L	BOILER ROOM	(1) (4) SAMPLE MAR-10 COLLECTED ON 3-30-88.	Y
M	12" ACOUSTIC CEILING TILE FISSURE PATTERN	97	ASSUMED POSITIVE	850 S	GIRL'S & BOY'S RESTROOMS	(2) (4) MINOR WATER DAMAGE ON ACT'S IN BOY'S & GIRL'S RESTROOMS.	N
M	CEMENTITIOUS TRANSITE PANELS	99	ASSUMED POSITIVE	50 S	MAIN BOILER ROOM AT BOILERS	(11)	N
S	PLASTER	101	ASSUMED POSITIVE	600 S	BOY'S & GIRL'S RESTROOMS AND CUSTODIAL ROOM	(1) (4)	N
T	BOILER INSULATION	108	ASSUMED POSITIVE	2 EACH	BOILER ROOM	(1) (4)	Y
S	STUCCO	260	ASSUMED POSITIVE	1,000 S	COVERED WALKWAY	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit F - Rooms 7-9

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (BROWN) & ADHESIVE	8	1-5%	5,728 S	CLASSROOMS 7-9	(1) (4)	N
M	12" ACOUSTIC CEILING TILE 1/8" HOLE PATTERN	98	ASSUMED POSITIVE	5,728 S	CLASSROOMS 7-9	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	300 L	CLASSROOMS 7-9	(1) (4)	N
S	STUCCO	260	ASSUMED POSITIVE	1,500 S	COVERED WALKWAY	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit G - Room 10

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' CEILING PANELS FIBERGLASS	96	ASSUMED POSITIVE	1,800 S	CLASSROOM 10	(1) (4)	N
M	DRYWALL & JOINT COMPOUND	109	ASSUMED POSITIVE	1,700 S	CLASSROOM 10	(11) (4) COVERED WITH TAGBOARD.	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	100 L	CLASSROOM 10	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	800 S	CLASSROOM 10	(1) (4)	N

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**



**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit H - Rooms 11-14

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VINYL FLOOR TILE (BEIGE) & ADHESIVE	2	1-5%	4,500 S	CLASSROOMS 11-14 AND MIDDLE RESTROOM RESTROOM IN STAFF LOUNGE	(1) (4) MIDDLE RESTROOM. (4) (11) ASSUMED POSITIVE TO EXIST UNDER CARPET IN CLASSROOMS 11, 13, & 14.	N
M	2' X 4' CEILING PANELS FISSURE PATTERN	92	ASSUMED POSITIVE	4,500 S	ALL ROOMS	(1) (4)	N
M	12" VINYL FLOOR TILE (WHITE/BLUE) & ADHESIVE	93	ASSUMED POSITIVE	900 S	ROOM 12 - LIBRARY	(11) (4) 9" VINYL FLOOR TILE WAS CONCEALED BY CARPET AND 12" VINYL FLOOR TILE WAS REPLACED WITH 12" VINYL FLOOR TILE WHITE WITH BLUE.	N
M	CEMENTITIOUS TRANSITE PANELS	99	ASSUMED POSITIVE	300 S	ABOVE WINDOWS	(1) (4) APPROXIMATELY 18 PANELS.	N
M	12" VINYL FLOOR TILE (GREEN) & ADHESIVE	151	ASSUMED POSITIVE	305 S	STAFF LOUNGE (920)	(1) (4)	N
S	PLASTER	152	ASSUMED POSITIVE	2,000 SF	RESTROOMS (918 & 919) AND STAFF LOUNGE (920)	(1) (4)	N
M	DRYWALL & JOINT COMPOUND	153	ASSUMED POSITIVE	2,500 SF	CLASSROOMS 11-14	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	1,000 L	STAFF LOUNGE (920), CLASSROOMS, LIBRARY & COMPUTER LAB	(1) (4)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	4,000 S	CLASSROOMS, LIBRARY & COMPUTER LAB	(1) (4)	N

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit J - Rooms 19-23

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VINYL FLOOR TILE (CREAM) & ADHESIVE	80	ASSUMED POSITIVE	2,400 S	PORTABLES 19-23	(1) (4)	N
M	DRYWALL	81	ASSUMED POSITIVE	10,000 S	PORTABLES 19 - 23 AND RESTROOMS (923 & 924)	(11) (4) COVERED WITH TAGBOARD IN CLASSROOMS	N
M	2' X 4' CEILING PANELS FISSURE PATTERN (FIBERGLASS)	89	ASSUMED POSITIVE	8,000 S	PORTABLES 19-23	(1) (4)	N
M	SHEET VINYL FLOORING (TAN) & ADHESIVE	100	ASSUMED POSITIVE	500 S	RESTROOMS (923 & 924)	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	500 L	CLASSROOMS 19-23	(1)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	3,600 S	CLASSROOMS 19-23	(1)	N
						NOTE: BUILT BY - KRUSEMARK - JULY 1988 ROOM 19 - SERIAL # 8751-9A, B & C ROOM 20 - SERIAL # 8888-4A, B & C ROOM 21 - SERIAL # 8888-5 A, B & C ROOM 22 - SERIAL # 8888-6A, B & C ROOM 23 - SERIAL # 8888-7A, B & C THE DISTRICT MUST OBTAIN CERTIFICATION LETTERS ON ANY PORTABLES MANUFACTURED AFTER OCTOBER 12, 1988.	

### CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit K - Room 18

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VINYL FLOOR TILE (WHITE MOTTLED) & ADHESIVE	80	ASSUMED POSITIVE	2,400 S	PORTABLE 18	(1) (4) MISSING TILE LOTS OF SMALL CRACKS.	N
M	DRYWALL	81	ASSUMED POSITIVE	10,000 S	PORTABLE 18	(1) (4)	N
M	2' X 4' CEILING PANELS	89	ASSUMED POSITIVE	8,000 S	PORTABLE 18	(1) (4)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	100 L	PORTABLE 18	(1) (4)	N
						NOTE: BUILT BY: DESIGNED MOBILE SYSTEMS IND. INC. 6-97 SERIAL # 20-310-1 & 2 THE DISTRICT MUST OBTAIN CERTIFICATION LETTERS ON ANY PORTABLES MANUFACTURED AFTER OCTOBER 12, 1988.	

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection:

District: Chico Unified School District

Inspector:

School: Marigold Elementary School

Building: Unit L - Portables 24 & 25

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VINYL FLOOR TILE (BLUE) & ADHESIVE	102	ASSUMED POSITIVE	360 S	PORTABLES 24 & 25	(1) (4)	N
M	DRYWALL & JOINT COMPOUND	103	ASSUMED POSITIVE	960 S	PORTABLES 24 & 25	(11) COVERED WITH TAGBOARD.	N
M	2' X 4' CEILING PANELS (FIBERGLASS)	104	NON-SUSPECT	900 S	PORTABLES 24 & 25	(13)	N
M	VINYL SHEET FLOORING (BLUE SPECKLED) & ADHESIVE	200	ASSUMED POSITIVE	84 S	RESTROOMS AT PORTABLES 24 & 25	(1)	N
M	COVE BASE ADHESIVE	250	ASSUMED POSITIVE	200 L	PORTABLES 24 & 25	(1)	N
M	CARPET ADHESIVE	251	ASSUMED POSITIVE	1,800 S	PORTABLES 24 & 25	(1)	N
						NOTE: THE DISTRICT MUST OBTAIN CERTIFICATION LETTERS ON ANY PORTABLES MANUFACTURED AFTER OCTOBER 12, 1988.	

Z:\Clients\Chico USD\16-4066 3 Year Reinspections\Sites\Marigold ES\Marigold - 6 Month.wpd

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous:            (11) Inaccessible, no inspection data            (12) Other (Explain under comments)            (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**