

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 4-01-11

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Country Day School (FKA Fairview High School)

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT BEIGE	10	1-5%	1,920 S	CLASSROOM 1 AND ADMINISTRATION OFFICES	(1) (4) NEEDS WAX COAT TO AVOID WEAR IN ROOM 1 (4)	N
M	DRYWALL	75	TRACE	1,400 S	OFFICE WALLS, RESTROOMS, AND CUSTODIAN ROOM	(4)	N
M	12" ACT	101	ASSUMED	1,920 S	CLASSROOM 1 AND ADMINISTRATION OFFICES	(1) (4) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 4-01-11

Inspector: Daniel Hunt

Building: B

District: Chico Unified School District

School: Chico Country Day School (FKA Fairview High School)

Material Class	Material	Homo. Mat. #	% Asb.	FT ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT BEIGE	10	1-5%	4,300 S	ALL CLASSROOMS & COUNSELING OFFICES	(1) (4) NEEDS WAX COAT, Room 4 needs 1 tile (1)	N
M	DRYWALL	98	NON ASBESTOS	UNDETERMINED	CLASSROOMS AND CUSTODIAN ROOM	(13) USD sample FD 1-6 6/3/05	N
M	DRYWALL	98	ASSUMED	600 S	BOY'S & GIRL'S RESTROOMS CEILING	(1) (4) Boys ceiling shows minor repair (4)	N
M	12" ACT	101	ASSUMED	4,220 S	ALL CLASSROOMS	(1) (4) (1) (4)	N
M	2 X 4 FCP	102	ASSUMED	50 S	CLASSROOM 2	(1) (4) (1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 4-01-11

Inspector: Daniel Hunt

District: Chico Unified School District

School: Chico Country Day School (FKA Fairview High School)

Building: D

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP (PLASTIC)	96	NOT SUSPECT	2,400 S	ALL CLASSROOMS 6, 7, 8 & 10	(13) CUSD sample CCDS 01 & 02 7/20/05	N
M	9" VFT	97	Not Detect	2,400 S	ALL CLASSROOMS	(13) CUSD sample CCDS 01 & 02 7/20/05	N
M	2 X 4 FCP	102	ASSUMED	600 S	CLASSROOM 9 ONLY	(1) (4) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 4-01-11

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Country Day School (FKA Fairview High School)

Building: G - MPR

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	PLASTER	5	1-5%	2,600 S	MPR	(1) (4) (1)	N
M	9" VFT GREEN	6	1-5%	2,800 S	MPR, KITCHEN, FOOD STORAGE, AND ENTRANCE	(2) (4) MINOR CRACKS AND CHIPPED TILES IN THE SOUTH WEST CORNER. NEEDS WAX.	N
T	BOILER INSULATION	7	75-80%	150 S	BOILER ROOM	(1) (4) APPEARS TO BE IN GOOD SHAPE. (4)	N
T	MUD JOINT	8	35-40%	32 EACH	BOILER ROOM	(1) (4) (4)	N
M	TRANSITE PIPE FLUE	99	ASSUMED	2 EACH 25 L	BOILER ROOM	(1) (4) (4)	N
M	12" VFT RED	100	ASSUMED	150 S	KITCHEN	(1) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 4-01-11

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Country Day School (FKA Fairview High School)

Building: H - Classrooms 23-27

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP'S		CERTIFIED NON- ASBESTOS	3,200 S	CLASSROOMS 23-25	(13) LETTER ON FILE 2007.	N
M	12" VFT WHITE/BLUE		CERTIFIED NON- ASBESTOS	3,200 S	CLASSROOMS 23-25	(13) LETTER ON FILE 2007.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 4-01-11

District: Chico Unified School District

Inspector: Daniel Hunt

School: Chico Country Day School (FKA Fairview High School)

Building: Portable

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL		Certified Non-Asbestos		RESTROOM	(13) Letter on file dated 10/6/06	N
M	2' X 4' FCP		Certified Non-Asbestos		RESTROOM	(13) Letter on file dated 10/6/06	N
M	12" VFT GREY		Certified Non-Asbestos		RESTROOM	(13) Letter on file dated 10/6/06	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS