

**SIX MONTH /EILLANCE
HOMOGENEOUS CBM RECORDS**

Date of Inspection: 3/25/11

Inspector: Daniel Hunt

Building: Unit A (FKA C) - Classrooms 1-5

District: Chico Unified School District

School: Hooker Oak Elementary School

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT GREEN	101	NON ASBESTOS	2,200 S	HALLWAY	(1) (4) MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE	N
M	2' X 4' FCP'S	110	ASSUMED	4,500 S	CLASSROOMS 1-5	(1) (4) (1) (4)	N
M	12" ACT	111	ASSUMED	2,500 S	HALLWAY	(1) (5) NEEDS REPAIR IN FRONT OF RESTROOM (1)	N
M	12" VFT SALMON	112	NON ASBESTOS	4,500 S	CLASSROOMS 1-5	(1) (4) MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE	N
M	4" COVE BASE MAUVE	113	ASSUMED	600 LF	CLASSROOMS 1-5	(1) (1)	N
M	4" COVE BASE GREEN	114	ASSUMED	420 LF	HALLWAY	(1) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH EILLANCE
HOMOGENEOUS ACM RECORDS

Date of Inspection: 3/25/11

Inspector: DANIEL THURST

Building: Unit B - Classrooms 6-10

District: Chico Unified School District

School: Hooker Oak Elementary School

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP'S	107	ASSUMED	4,500 S	CLASSROOMS 6-10	(1) (4) (1) (4)	N
M	12" ACT	108	ASSUMED	2,500 S	HALLWAY & STAFF ROOM (906)	(1) (2) STAINED & LOOSE (1)	N
M	12" VFT SALMON	109	NON ASBESTOS	4,500 S	CLASSROOMS 6-10	(1) (4) MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE	N
M	12" VFT GREEN	115	NON ASBESTOS	2,500 S	HALLWAY AND STAFF ROOM (906)	(1) (5) MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE STAFF ROOM COVERED BY CARPET NEEDS REPAIR BY RESTROOM & BACK DOOR (1)	N
M	4" COVE BASE MAUVE	116	ASSUMED	600 S	CLASSROOMS 6-10	(1) (1)	N
M	4" COVE BASE GREEN	117	ASSUMED	480 S	HALLWAY AND STAFF ROOM (906) <i>wood base</i>	(1) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 3/25/11

Inspector: DANIEL HUNT

District: Chico Unified School District

School: Hooker Oak Elementary School

Building: Unit C (FKA A) - Classrooms 13-17

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT GREEN	13	1-5%	2,880 S	CLASSROOMS 13-16	(5) ROOM 16 FRONT DOOR MISSING TILE (1)	N
M	12" ACT	14	NONE DETECTED	1,200 S	CLASSROOM 17	(13) SAMPLE HMS-HKR-14 COLLECTED ON 3-29-88.	N/A
M	9" VFT BRIGHT GREEN	97	ASSUMED	400 S	SINK ROOM (914)	(1) (4) (1)	N
M	12" ACT	98	ASSUMED	2,880 S	CLASSROOMS 13-16, SINK ROOM (914), AND RESTROOM (915 & 916)	(1) (4) (1)	N
M	12" VFT CREAM	99	NON ASBESTOS	1,200 S	CLASSROOM 17	(1) (4) MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE	N
M	4" COVE BASE BROWN	118	ASSUMED	125 LF	CLASSROOM 17	(1) (1)	N
M	4" COVE BASE YELLOW	119	ASSUMED	90 LF	COMPUTER ROOM (912 & 913)	(1) (1)	N
M	4" COVE BASE BLACK	120	ASSUMED	460 LF	CLASSROOMS 13-16	(1) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 3/25/11

District: Chico Unified School District

Inspector: Daniel Hunt

School: Hooker Oak Elementary

Building: Unit D - Portable Library & Portable 18

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP FIBERGLASS	104	NON-SUSPECT	900 S	LIBRARY PORTABLE	(13) MANUFACTURE DATE OF PORTABLE LIBRARY IS 6/95. I.D. #63260 DMSI CONSTRUCTION. Letter on file.	N/A
M	2' X 4' VFT	105	Certified Non-Asbestos	900 S	PORTABLE CLASSROOM 18	(13) SUN SERI CONSTRUCTION OSA #47175. MANUFACTURE DATE OF PORTABLE 18 IS 8/86. Letter on File.	N
M	12" VFT	106	Certified Non-Asbestos	240 S	PORTABLE CLASSROOM 18	(13) SUN SERI CONSTRUCTION OSA #47175. MANUFACTURE DATE OF PORTABLE 18 IS 8/86. Letter on File.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH EILLANCE
HOMOGENEOUS ASBESTOS RECORDS**

Date of Inspection: 3/25/11

Inspector: Daniel Hunt

District: Chico Unified School District

School: Hooker Oak Elementary School

Building: Unit E (FKA D) - MPR

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	2	NONE DETECTED	350 S	MPR (NORTH WALL) (921)	(1) (13) SAMPLE HMS-HKR-02 COLLECTED ON 3-29-88.	N/A
T	BOILER LINER	8	50-55%	210 S	BOILER ROOM (925)	(1) (4) 2 BOILERS. SAMPLE HMS-HKR-08 COLLECTED ON 3-29-88. CANNOT SEE (4)	Y
M	LINOLEUM	17	5-10%	250 S	ADMINISTRATION OFFICE (919)	(1) (4) (1)	N
M	12" VFT GREEN-WHITE	93	NON ASBESTOS	2,500 S	MPR (921) AND HALLWAY	(1) (12) REPLACED 9" VFT. MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE	N
M	12" VFT SALMON	96	NON ASBESTOS	1,800 S	CLASSROOMS 11 & 12	(1) (4) MODERNIZATION PROJECT 1997 MANUFACTURER LETTER ON FILE	N
M	9" VFT RED	100	ASSUMED	50 S	ADMINISTRATION STORAGE (918)	(1) (4) (1)	N
M	2' X 4' FCP	121	ASSUMED	8,400 S	CLASSROOMS 11 & 12, HALLWAY, AND MPR (921)	(1) (1) (1)	N
M	4" COVE BASE MAUVE	122	ASSUMED	180 LF	CLASSROOMS 11 & 12	(1) (1) (1)	N
M	4" COVE BASE GREEN	123	ASSUMED	700 LF	MPR (921) AND HALLWAY	(1) (1) (1)	N
M	DRYWALL	124	NONE DETECTED	UNDETERMINED	MPR (921) AND PRINCIPALS OFFICE	(13) SAMPLE CUSD HO-001-004 COLLECTED ON 8-16-06.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 3/25/11

Inspector: Daniel Hunt

District: Chico Unified School District

School: Hooker Oak Elementary

Building: Unit F - Portables 19-21 (FKA Portables 19-21)

Material Class	Material	Hom. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT WHITE	101	NON ASBESTOS	2,700 S	PORTABLES CLASSROOMS 19-21	(1) (4) MANUFACTURE DATE OF PORTABLES IS 6/97. DMSI CONSTRUCTION. MFG LETTER ON FILE	N
M	2' X 4' FCP FIBERGLASS	102	NON-SUSPECT	2,700 S	PORTABLES CLASSROOMS 19-21	(1) (13) MANUFACTURE DATE OF PORTABLES IS 6/97. DMSI CONSTRUCTION.	N/A

School: Hooker Oak Elementary

Building: Unit G - Portables 22-23

Material Class	Material	Hom. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT WHITE	101	Certified Non-Asbestos	2,700 S	PORTABLES CLASSROOMS 20-22	(1) (13) Letter on File.	N
M	2' X 4' FCP FIBERGLASS	102	Certified Non-Asbestos	2,700 S	PORTABLES CLASSROOMS 19-21	(1) (13) Letter on File.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH \$ VEILLANCE
HOMOGENEOU: BM RECORDS

Date of Inspection: 3-25-11

District: Chico Unified School District

Inspector: Dusty Lappe

School: Chapman Elementary School

Building: Unit A (FKA G)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	MUD JOINT	1	1-5%	UNDETERMINED	THROUGHOUT	(11) SAMPLE HMS-CPM-03 COLLECTED ON 4/9/88. <i>SHINE</i>	Y
M	TRANSITE PANELS	2	ASSUMED	UNDETERMINED	THROUGHOUT	(1) (2) By door room 21 <i>SHINE</i>	N
M	12" VFT CREAM	3	None Detected	400 S	CLASSROOMS 1, 2, 6, & 7	(13) CUSD sample taken 12/26/07 chp01-chp 04 <i>UNDER DOOR REPAIR SHINE</i>	N

School: Chapman Elementary School

Building: Unit D (FKA F)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT	4	1-5%	UNDETERMINED	THROUGHOUT EXCEPT IN LIBRARY	(1) (4) <i>SAME</i>	N/A
M	9" VFT	5	1-5%	UNDETERMINED	THROUGHOUT EXCEPT IN LIBRARY	(1) (4) <i>SAME</i>	N/A
M	TRANSITE PANELS	6	ASSUMED	400 S	EXTERIOR	(1) (4) <i>SAME</i>	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 3/25/11

District: Chico Unified School District

Inspector: Dusty Coppel

School: Chapman Elementary School

Building: Unit E (FKA C)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	TRANSITE PANELS	7	ASSUMED	400 S	EXTERIOR	(1) (4) <i>same</i>	N
M	12" VFT CREAM	8	None Detected	3,600 S	CLASSROOMS 15-18	(13) CUSD sample 12/26/07 chp 01-04 MODERNIZATION 1989 <i>same</i>	N

School: Chapman Elementary School

Building: Unit F (FKA A)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT BROWN	9	10-15%	UNDETERMINED	KITCHEN	(1) (2) 21 TILES MISSING <i>same</i>	N
M	12" VFT CREAM	10	None Detected	3,600 S	MPR, CORRIDOR, AND OFFICES	(13) CUSD sample on 12/26/07 chp 01-04 MODERNIZATION 1989 <i>same</i>	N
M	12" ACT	11	NON ASBESTOS	3,600 S	MPR, CORRIDOR, AND OFFICES	(13) CUSD SAMPLE COLLECTED ON 7/8/08 <i>same</i>	N
S	PLASTER	12	NONE DETECTED	UNDETERMINED	KITCHEN	(11) CUSD SAMPLE Chp01COLLECTED 2/22/06 <i>same</i>	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 3/25/11

Inspector: Dusty Cappel

District: Chico Unified School District

School: Chapman Elementary School

Building: Unit H (FKA B)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	TRANSITE PANELS	13	ASSUMED	400 S	EXTERIOR	(1) (4) <i>Same</i>	N
M	12" VFT cream	14	None Detected	3,600 S	CLASSROOMS 19-22	(13) CUSD sample on 12/26/07 chp 01- chp 04 MODERNIZATION 1989 <i>Same</i>	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected
CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS