

**SIX MONTHS / EILLANCE
HOMOGENEOUS ASBESTOS RECORDS**

Date of Inspection: 2/25/11

District: Chico Unified School District
School: McManus Elementary School

Inspector: David Hunt

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALL PLASTER	2	5-10%	4,400 S	ADMINISTRATION AREA, HALLWAYS, KITCHEN, AND ADMINISTRATION RESTROOMS	(1) (4) (6) (1) (4)	N
M	9" VFT BROWN	4	5-10%	1,063 S	HALLWAY AND KITCHEN	(1) (4) (4) MODERNIZATION PROJECT 1993	N
M	LINOLEUM	5	NONE DETECTED	120 S	BOTH ADMINISTRATION RESTROOMS	(13) SAMPLE HMS-MMS-05 COLLECTED ON 3/30/88.	N/A
S	TROWEL ON CEILING TEXTURED PLASTER	6	1-5%	16,000 S	ADMINISTRATION AREA, ATTIC AREA, HALLWAY, ADMINISTRATION RESTROOMS, AND KITCHEN STORAGE	(11) COVERED BY 12" ACT.	N
M	TRANSITE PIPE FLUE	98	ASSUMED	6 L	KITCHEN HEATER CLOSET	(1) (4) (1) (4)	Y
M	12" ACT	100	ASSUMED	400 S	ADMINISTRATION	(1) (4) (1) (4)	N
M	2' X 4' FCP'S	101	ASSUMED	800 S	PRINCIPAL'S OFFICE & ADMINISTRATIVE OFFICES	(1) (4) (1) (4)	N
M	12" VFT GREEN	102	NON ASBESTOS	2,570 S	MULTI-PURPOSE ROOM	(1) (4) MODERNIZATION PROJECT 1993 MANUFACTURER LETTER ON FILE	N
M	12" VFT WHITE	103	NON ASBESTOS	350 S	CORRIDOR (NORTH)	(1) (4) MODERNIZATION PROJECT 1993 MANUFACTURER LETTER ON FILE	N
M	12" ACT	104	ASSUMED	3,000 S	MULTI-PURPOSE ROOM	(1) (1) (4) (4)	N
M	DRYWALL	105	ASSUMED	3,000 S	ADMINISTRATION	(1) (2) COMING INTO HALL (1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 3/25/11

District: Chico Unified School District

Inspector: DANIEL HUNT

School: McManus Elementary School

Building: B (FKA C)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	PLASTER	2	5-10%	1,700 S	RESTROOMS AND RESOURCE ROOM	(1) (4) (1) EOS, INC. CLAIMS THIS MATERIAL WAS RETESTED AND FOUND TO BE NON-ASBESTOS CONTAINING. HOWEVER, NO SAMPLE NUMBER CAN BE LOCATED. (4)	N
M	12" VFT GREY	85	ASSUMED	3,000 S	CLASSROOMS 1 & 2	(1) (4) PARTIALLY CONCEALED BY CARPET. MODERNIZATION 1993 (4)	N
M	2' X 4' FCP'S	86	ASSUMED	3,000 S	CLASSROOMS 1 & 2	(1) (4) (4)	N
M	12" VFT BLUE	106	ASSUMED	140 S	ROOM 1 & 2 ENTRY	(1) (1) MODERNIZATION PROJECT 1993 MANUFACTURER LETTER ON FILE	N
M	LINOLEUM	107	ASSUMED	140 S	RESTROOM - MEN'S RESTROOM USED FOR STORAGE	(1) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH EILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 5/25/11

Inspector: Daniel Hunt

District: Chico Unified School District

School: McManus Elementary School

Building: C (FKA B)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALL PLASTER	2	5-10%	1,500 S	BOILER ROOM, HALLWAY, AND RESTROOMS	(1) (4)	N
M	LINOLEUM	10	1-5%	245 S	ALL CLASSROOMS COUNTERTOPS EXCEPT CLASSROOM 4	(1) (4)	N
M	2' X 4' FCP'S	87	ASSUMED	6,300 S	CEILING OF ALL CLASSROOMS	(1) (4)	N
T	PIPEWRAP	90	60-70%	UNDETERMINED	IN ATTICS AND WALLS	(11) THIS MATERIAL WAS DISCOVERED DURING THE JULY, 1993 REMODEL AND IS INACCESSIBLE, THEREFORE FOOTAGE HAS NOT BEEN DETERMINED.	Y
T	AIR CELL TANK WRAP	97	ASSUMED	20 S	MAIN BOILER ROOM	(1) (4)	Y
T	AIR CELL	99	ASSUMED	165 L	CUSTODIAN ROOM ATTIC AND MAIN BOILER ROOM	(1) (4)	Y
M	12" VFT CREAM/GREY	100	NON ASBESTOS	2,100 S	ENTRANCES OF ALL CLASSROOMS AND COPY ROOM	(1) (4) STRIPS ALONG ENTRANCES OF ALL CLASSROOMS. MODERNIZATIN 1993 MANUFACTURER LETTER ON FILE	N
M	12" ACT	108	ASSUMED	1,000 S	CLASSROOMS - WALLS AND COPY ROOM	(2) RM 16 SCRATCHED BY DOOR (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH EILLANCE
HOMOGENEOUS ACM RECORDS**

Date of Inspection: 3/25/11

District: Chico Unified School District

Inspector: DANIEL HUNT

School: McManus Elementary School

Building: D

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALL PLASTER	2	5-10%	2,000 S	CUSTODIAN ROOM, HALLWAY, AND RESTROOMS	(1) (4) (4)	N
M	9" VFT TAN	4	5-10%	7,000 S	HALLWAY AND ALL CLASSROOMS	(1) (4) SHOWS WEAR & NEEDS WAX COAT MODERNIZATION 1993 (1)	N
S	TROWELED ON CEILING TEXTURE	6	1-5%	600 S	HALLWAY	(1) (4) (4) REMOVED FROM CUSTODIAN ROOM.	N N/A
T	PIPEWRAP MUDDIED FITTING	12	20-25%	11 EACH	CUSTODIAN ROOM	(1) (4) SAMPLE HMS-MMS-12 COLLECTED ON 4-11-88. (4) (12) PIPEWRAP STRAIGHT-FIBER. PIPEWRAP CORNER - ACM.	Y
M	2' X 4' FCP'S	55	ASSUMED	5,400 S	ALL CLASSROOMS	(1) (4) (1) (4)	N
M	LINOLEUM TAN	72	45%	140 S	COUNTER TOPS IN ALL CLASSROOMS EXCEPT CLASSROOM 17	(1) (4) (7) REMOVED IN CLASSROOM 17.	N N/A
M	12" ACT	109	ASSUMED	840 S	ALL CLASSROOMS	(1) (1)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH EILLANCE
HOMOGENEOUS ACBM RECORDS

Date of Inspection: 3/25/11

District: Chico Unified School District

Inspector: Daniel Hust

School: McManus Elementary

Building: E

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCPS	13	NONE DETECTED	1,000 S	LIBRARY AND STAFF ROOM	(13) SAMPLE HMS-CUSD-MCM-13 COLLECTED ON 04-12-92. LIBRARY WAS ORIGINALLY PART OF BUILDING D.	N/A
M	DRYWALL	75	NONE DETECTED	350 S	LIBRARY ENTRANCE	(13) SAMPLE HMS-CUSD-MCM-75A COLLECTED ON 4-14-92.	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SCHEDULE
HOMOGENEOUS ACM RECORDS**

Date of Inspection: 3-25-11

District: Chico Unified School District

Inspector: DANIEL HUNT

School: McManus Elementary

Building: Portables 3, 3A and 18-28, 29-31

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL & JOINT COMPOUND		ASSUMED		30 } ALL WALLS VTB 31 } CLASSROOMS 29-31	THESE PORTABLES REQUIRE DISTRICT CERTIFICATION LETTERS. IF LETTERS ARE NOT AVAILABLE FOR ANY ONE OF THE PORTABLES, SAMPLES OF MATERIALS WITHIN THOSE PORTABLES WILL HAVE TO BE TAKEN TO DETERMINE ACM, IF ANY AT ALL. PORTABLES 29-31 WERE MOVED FROM THE FORMER FAIR VIEW (15 & 16) AND CHICO JR HIGH SCHOOL (P-1) (1)(4) (11) covered by VTB	
M	2" x 4" FCP'S		NONE DETECTED		CLASSROOMS 29-31	(13) CUSD SAMPLE Mc001 7/29/2005	
M	12" VFT GRAY		NONE DETECTED		CLASSROOMS 29-31	(13) CUSD SAMPLE Mc001 7/29/2005	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS