

DISTRICT Chico Unified School District DATE January 5, 1996  
 SCHOOL Fairview High School INSPECTOR Ron Jones

| BLDG. | HOMOG.     | ASBESTOS MATERIAL | LOCATION                 | CONDITION: CODE & COMMENTS |
|-------|------------|-------------------|--------------------------|----------------------------|
| A     | 9" VFT     | 1-5               | Rooms 1 & 2 (Beige)      | (1) (4)                    |
| B     | 9" VFT     | 1-5               | Rooms 4, 5, 3, 2         | (1) (4)                    |
| MPR   | Mud Jnt    | 65-70             | Kitchen                  | (7)                        |
| MPR   | 9" VFT     | 1-5               | MPR (Green)              | 1-4<br>1-4<br>1-4          |
| MPR   | 9" VFT     | 1-5               | Food Storage, ARS Office | (1) (4)                    |
| MPR   | 9" VFT     | 1-5               | S-storage & Food storage | (1) (4)                    |
| MPR   | Ceill plas | 1-5               | MPR                      | (2) (4)                    |
| MPR   | Boill Insl | 75-80             | Boiler Room              | (1) (4)                    |
| MPR   | Tran pipe  | Assumed           | Boiler Room              | (1) (4)                    |
| MPR   | Mud Jnt    | 35-40             | Boiler Room              | (1) (4)                    |
| C     | 9" VFTs    | 1-5               | All Classrooms           | (1) (4)                    |

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)