

Homogeneous Materials Record

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **A**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	1	KITCHEN OFFICE	01-05	40 S	N
9" VFTs	2	KITCHEN OFFICE	01-05	5 S	N
9" VFTs	2	MAIN HALLWAY CORIDOR	01-05	780 S	N
9" VFT L.GRN	3	KITCHEN COOKING AREA	00-01 TRACE	1100 S	N
WALL PLASTER	4	ALL ROOMS	00-00	10000 S	N
9" VFTs	5	FAN RMS	01-05	600 S	N
9" VFTs	5	MPR	01-05	4992 S	N
9" VFTs	5	TEACHERS LOUNGE	01-05	300 S	N
MUD JNTS	6	HT WTR TANK RM	01-05	3 J	N
CIELING PLAST	8	CAFETERIA (MPR)	01-05	4992 S	N
CIELING PLAST	8	ENTIRE WING	01-05	10000 S	N

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: A

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
CEILING PLAST	8	TEACHER'S LOUNGE	01-05	630 S	N
CEILING MATER	9	REFRIDGERATOR RM	01-05	60 S	N
PW STR	10	NORTH SIDE FAN RM	25-50	40 L	N
PW STR	10	SOUTH SIDE FAN RM	25-50	37 L	Y
MUD JNTs	11	NORTH SIDE FAN RM	50-55	10 J	N
MUD JNTs	11	SOUTH SIDE FAN ROOM	50-55	8 J	N
9" VFTs	14	TEACHER'S LOUNGE	01-05	300 S	N
LIGHTING CORD	90	STAGE LIGHTING	99-99 ASSUMED	50 L	N
PWSTR	96	STAGE AREA	40-45	115 L	Y

Inspected By: Mike Sharp
 These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: B

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
WALL PLASTER	4	HALL, LOWER WALLS	00-00	10000 S	N
CEILING PLAST	8	HALLWAY & UPPER WALL	01-05	6000 S	N
9" VFTs (NEW)	12	HALLWAY	01-05	250 S	N
12" VFTs	13	HALLWAY	01-05	250 S	N
9" VFTs	15	HALLWAY	01-05	4000 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: C

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
9" VFTs	2	JANITOR'S STORAGE	01-05	153 S	N
WALL PLASTER	4	RMS 11 AND 12	00-00	700 S	N
CEILING PLAST	8	RM 11	01-05	380 S	N
ACT	17	RM 200,202,204,206&8	00-00	3160 S	N
9" VFT	20	200,2,4,6, AND 208	05-10	4160 S	N
9" VFT	22	RM 22 (RUST)	05-10	1000 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: D

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9"VFTs	2	RM 10 JANITORS STR	01-05	153 S	N
WALL PLASTER	4	RMS 10 AND 11	00-00	700 S	N
CEILING PLAST	8	RM 11	01-05	380 S	N
ACT	17	RM 300,302,304,306&8	00-00	0	
9" VFTs	24	ALL ROOMS	01-05	4160 S	N

Inspected By: Mike Sharp
These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: **Chico USD**
Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **E**

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
9" VFTs	2	JANITOR'S STORAGE	01-05	153 S	N
WALL PLASTER	4	RMS 7 & 8	00-00	700 S	N
CEILING PLAST	8	RM 8	01-05	380 S	N
ACT	17	400,402,404,406,408	00-00	4160 S	N
9" VFTs	20	ALL ROOMS	05-10	4160 S	N

Inspected By: **Mike Sharp**

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: F

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	2	RM 1	01-05	153 S	N
WALL PLASTER	4	RMS 1 AND 2, RM 504	00-00	700 S	N
CEILING PLAST	8	RM 2	01-05	380 S	N
ACT	17	500,502,504,506	00-00	4500 S	N
9" VFTs	20	ALL RMS EXCEPT 504	05-10	3600 S	N
BEIGE LINO	25	ROOM 500	00-00	120 S	N
PW STR	26	RM 502	40-85	15 L	N
9" VFTs	27	504	05-10	900 S	N
PW STR	95	RM 506	99-99 ASSUMED	12 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **G**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
WALL PLASTER	4	RR	00-00	100 S	N
10" PW STR	29	BLR RM	55-60	300 L	N
8" PW STR	29	BLR RM	55-60	20 L	N
10" PW STR	29	TUNNEL CHASE	55-70	2500 L	N
BLR TANK WRAP	30	BLR RM	60-70	400 S	N
STRG TANKWRAP	30	BLR RM	60-70	40 S	N
PW STR	31	BLR RM	35-40	30 L	N
PW STR	31	SHOP OVERHEAD STRG	35-40	36 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: H

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
WALL PLASTER	4	WOOD SHOP & OFFICES	00-00	2000 S	N
CEILING PLAST	8	WOOD SHOP OFFICE	01-05	120 S	N
9" VFTs	14	WOOD SHOP CLS RM	01-05	630 S	N
9" VFTs	14	WOOD SHOP OFFICES	01-05	120 S	N
ACT	17	WOOD SHOP & CLSRM	00-00	4600 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **J**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	2	AADMIN OFFICE & HALL	01-05	4900 S	N
WALL PLASTER	4	ALL ROOMS	00-00	11000 S	N
CEILING PLAST	8	ALL ROOMS	01-05	7276 S	N
PW STR	10	WORK RM CLOSET	25-50	30 L	N
PW JNTs	11	WORK RM CLOSET	50-55	10 J	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: **Chico USD**
Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **K**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
ACT	17	203,205,207,209,211	00-00	4200 S	N
9" VFTs	18	ALL CLS RMS	01-05	4200 S	N
9" VFTs	19	RM 201 (TWO COLORS)	05-10	900 S	N
ACT	21	ROOM 201	00-00	900 S	N
PW Strs	75	Under Cabinets	99-99 ASSUMED	400 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: **Chico USD**
Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **L**

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
ACT	17	301,303,305,307,309	00-00	5018 S	N
9" VFTs	20	ALL CLS RMS	05-10	5018 S	N
PW Strs	75	Under Cabinets	99-99 ASSUMED	400 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: M

Material	Homog. Mat. #	Locations	% Asb	Footage	Y or N	Friable?
ACT	17	401,403,405,407,409	00-00	5018 S		N
9" VFTs	23	ALL CLS RMS	05-10	5018 S		N
PW STRs	75	UNDER CABINETS	99-99 ASSUMED	400 S		N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **N**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
BROWM LINO	0	RAISED FLOORING	00-00	900 S	N
WALL PLASTER	4	MUSIC RM OFFICE	00-00	1000 S	N
CEILING PLAST	8	OFFICE AREAS	01-05	632 S	N
PW STR	10	UNDER RAISED FLORING	25-50	35 L	N
9" VFTs	14	CHORAL RM	01-05	1752 S	N
9" VFTs	14	OFFICES	01-05	300 S	N
ACT	17	ALL ROOMS	00-00	4000 S	N
9" VFTs	20	RM 503 & PRACTCE RMS	05-10	2900 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: 0

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
CEILING PLSTR	0	ALL ROOMS	00-00	8182 S	N
WALL PLASTER	4	LOCKER RM & OFFICES	00-00	3000 S	N
9" VFTs	5	RRs	01-05	342 S	N
ACT	17	GYM	00-00	2000 S	N
PLASTER/DRY	32	WALL BETW'N GYM & RR	00-00	100 S	N
PWSTR	33	FAN UNITS ENCLOSED 4	60-70	17 L	Y
PWSTR	33	GYM STORAGE AREA	60-70	40 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD

School: CHICO JUNIOR HIGH

Date Inspected: 04/14/92

BUILDING: P

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	5	RM 18 STORAGE	01-05	630 S	N
PW STR	33	BLR RM	50-70	350 L	N
5" PW STR	34	BLR RM	45-50	350 L	N
5" PW STR	34	MEN'S LOCKER ROOM	45-50	12 L	N
5" PW STR	34	WOMEN'S LOCKER RM	45-50	12 L	N
MUD JNT	35	BLR RM	60-70	350 J	N
TANK WRAP	36	BLR RM	20-30	1000 S	Y
PW CNR	98	BETWEEN LOCKER RMS	99-99 ASSUMED	350 L	Y

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: **Chico USD**

School: **CHICO JUNIOR HIGH**

Date Inspected: **04/14/92**

BUILDING: 4 PORTABLES

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
DRYWALL	80	BEHING TAG BOARD	99-99 ASSUMED	6000 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: **Chico USD**
Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **N**

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
DRYWALL	76	GYM STORAGES	00-00	1000 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: O

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
DRYWALL	0	ALL RMS GYM EAST END	00-00	3000 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: A

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	1	KITCHEN OFFICE	01-05	40 S	N
9" VFTs	2	KITCHEN OFFICE	01-05	5 S	N
9" VFTs	2	MAIN HALLWAY CORIDOR	01-05	780 S	N
9" VFT L.GRN	3	KITCHEN COOKING AREA	00-01 TRACE	1100 S	N
WALL PLASTER	4	ALL ROOMS	00-00	10000 S	N
9" VFTs	5	FAN RMS	01-05	600 S	N
9" VFTs	5	MPR	01-05	4992 S	N
9" VFTs	5	TEACHERS LOUNGE	01-05	300 S	N
MUD JNTS	6	HT WTR TANK RM	01-05	3 J	N
CIELING PLAST	8	CAFETERIA (MPR)	01-05	4992 S	N
CIELING PLAST	8	ENTIRE WING	01-05	10000 S	N

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: A

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
CEILING PLAST	8	TEACHER'S LOUNGE	01-05	630 S	N
CEILING MATER	9	REFRIDGERATOR RM	01-05	60 S	N
PW STR	10	NORTH SIDE FAN RM	25-50	40 L	N
PW STR	10	SOUTH SIDE FAN RM	25-50	37 L	Y
MUD JNTs	11	NORTH SIDE FAN RM	50-55	10 J	N
MUD JNTs	11	SOUTH SIDE FAN ROOM	50-55	8 J	N
9" VFTs	14	TEACHER'S LOUNGE	01-05	300 S	N
LIGHTING CORD	90	STAGE LIGHTING	99-99 ASSUMED	50 L	N
PWSTR	96	STAGE AREA	40-45	115 L	Y

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: B

Material	Homog. Mat. #	Locations	% Asb	Footage	Y or N	Friable?
WALL PLASTER	4	HALL, LOWER WALLS	00-00	10000 S		N
CEILING PLAST	8	HALLWAY & UPPER WALL	01-05	6000 S		N
9" VFTs (NEW)	12	HALLWAY	01-05	250 S		N
12" VFTs	13	HALLWAY	01-05	250 S		N
9" VFTs	15	HALLWAY	01-05	4000 S		N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: C

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	2	JANITOR'S STORAGE	01-05	153 S	N
WALL PLASTER	4	RMS 11 AND 12	00-00	700 S	N
CEILING PLAST	8	RM 11	01-05	380 S	N
ACT	17	RM 200,202,204,206&8	00-00	3160 S	N
9" VFT	20	200,2,4,6, AND 208	05-10	4160 S	N
9" VFT	22	RM 22 (RUST)	05-10	1000 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **D**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9"VFTs	2	RM 10 JANITORS STR	01-05	153 S	N
WALL PLASTER	4	RMS 10 AND 11	00-00	700 S	N
CEILING PLAST	8	RM 11	01-05	380 S	N
ACT	17	RM 300,302,304,306&8	00-00	0	
9" VFTs	24	ALL ROOMS	01-05	4160 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: E

Material	Homog. Mat. #	Locations	% Asb	Footage	Y or N	Friable?
9" VFTs	2	JANITOR'S STORAGE	01-05	153 S		N
WALL PLASTER	4	RMS 7 & 8	00-00	700 S		N
CEILING PLAST	8	RM 8	01-05	380 S		N
ACT	17	400,402,404,406,408	00-00	4160 S		N
9" VFTs	20	ALL ROOMS	05-10	4160 S		N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **CHICO JUNIOR HIGH**

BUILDING: **F**

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	2	RM 1	01-05	153 S	N
WALL PLASTER	4	RMS 1 AND 2, RM 504	00-00	700 S	N
CEILING PLAST	8	RM 2	01-05	380 S	N
ACT	17	500, 502, 504, 506	00-00	4500 S	N
9" VFTs	20	ALL RMS EXCEPT 504	05-10	3600 S	N
BEIGE LINO	25	ROOM 500	00-00	120 S	N
PW STR	26	RM 502	40-85	15 L	N
9" VFTs	27	504	05-10	900 S	N
PW STR	95	RM 506	99-99 ASSUMED	12 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD

School: CHICO JUNIOR HIGH

Date Inspected: 04/14/92

BUILDING: G

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
WALL PLASTER	4	RR	00-00	100 S	N
10" PW STR	29	BLR RM	55-60	300 L	N
8" PW STR	29	BLR RM	55-60	20 L	N
10" PW STR	29	TUNNEL CHASE	55-70	2500 L	N
BLR TANK WRAP	30	BLR RM	60-70	400 S	N
STRG TANKWRAP	30	BLR RM	60-70	40 S	N
PW STR	31	BLR RM	35-40	30 L	N
PW STR	31	SHOP OVERHEAD STRG	35-40	36 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: H

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
WALL PLASTER	4	WOOD SHOP & OFFICES	00-00	2000 S	N
CEILING PLAST	8	WOOD SHOP OFFICE	01-05	120 S	N
9" VFTs	14	WOOD SHOP CLS RM	01-05	630 S	N
9" VFTs	14	WOOD SHOP OFFICES	01-05	120 S	N
ACT	17	WOOD SHOP & CLSRM	00-00	4600 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: J

Material	Homog. Mat. #	Locations	% Asb	Footage	Y or N	Friable?
9" VFTs	2	AADMIN OFFICE & HALL	01-05	4900 S		N
WALL PLASTER	4	ALL ROOMS	00-00	11000 S		N
CEILING PLAST	8	ALL ROOMS	01-05	7276 S		N
PW STR	10	WORK RM CLOSET	25-50	30 L		N
PW JNTs	11	WORK RM CLOSET	50-55	10 J		N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: K

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
ACT	17	203,205,207,209,211	00-00	4200 S	N
9" VFTs	18	ALL CLS RMS	01-05	4200 S	N
9" VFTs	19	RM 201 (TWO COLORS)	05-10	900 S	N
ACT	21	ROOM 201	00-00	900 S	N
PW Strs	75	Under Cabinets	99-99 ASSUMED	400 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: L

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
ACT	17	301,303,305,307,309	00-00	5018 S	N
9" VFTs	20	ALL CLS RMS	05-10	5018 S	N
PW Strs	75	Under Cabinets	99-99 ASSUMED	400 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD

School: CHICO JUNIOR HIGH

Date Inspected: 04/14/92

BUILDING: M

Material	Homog. Mat. #	Locations	% Asb	Footage	Y or N	Friable?
ACT	17	401,403,405,407,409	00-00	5018 S		N
9" VFTs	23	ALL CLS RMS	05-10	5018 S		N
PW STRs	75	UNDER CABINETS	99-99 ASSUMED	400 S		N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: N

Material	Homog. Mat. #	Locations	% Asb	Footage	Y or N	Friable?
BROWM LINO	0	RAISED FLOORING	00-00	900 S		N
WALL PLASTER	4	MUSIC RM OFFICE	00-00	1000 S		N
CEILING PLAST	8	OFFICE AREAS	01-05	632 S		N
PW STR	10	UNDER RAISED FLORING	25-50	35 L		N
9" VFTs	14	CHORAL RM	01-05	1752 S		N
9" VFTs	14	OFFICES	01-05	300 S		N
ACT	17	ALL ROOMS	00-00	4000 S		N
9" VFTs	20	RM 503 & PRACTCE RMS	05-10	2900 S		N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: 0

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
CEILING PLSTR	0	ALL ROOMS	00-00	8182 S	N
WALL PLASTER	4	LOCKER RM & OFFICES	00-00	3000 S	N
9" VFTs	5	RRs	01-05	342 S	N
ACT	17	GYM	00-00	2000 S	N
PLASTER/DRY	32	WALL BETW'N GYM & RR	00-00	100 S	N
PWSTR	33	FAN UNITS ENCLOSED 4	60-70	17 L	Y
PWSTR	33	GYM STORAGE AREA	60-70	40 L	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
 Date Inspected: 04/14/92

School: CHICO JUNIOR HIGH

BUILDING: P

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFTs	5	RM 18 STORAGE	01-05	630 S	N
PW STR	33	BLR RM	50-70	350 L	N
5" PW STR	34	BLR RM	45-50	350 L	N
5" PW STR	34	MEN'S LOCKER ROOM	45-50	12 L	N
5" PW STR	34	WOMEN'S LOCKER RM	45-50	12 L	N
MUD JNT	35	BLR RM	60-70	350 J	N
TANK WRAP	36	BLR RM	20-30	1000 S	Y
PW CNR	98	BETWEEN LOCKER RMS	99-99 ASSUMED	350 L	Y

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.