



Department of Toxic Substances Control

Edwin F. Lowry, Director
400 P Street, 4th Floor, P.O. Box 806
Sacramento, California 95812-0806



Winston H. Hickox
Secretary for
Environmental
Protection

Gray Davis
Governor

HAZARDOUS WASTE TRANSPORTER REGISTRATION

NAME AND ADDRESS OF REGISTERED TRANSPORTER:

BDC Special Waste Services
766 South Ayon Avenue
Azusa, California 91702


TRANSPORTER REGISTRATION NO: 3720

EXPIRATION DATE: July 31, 2000

THIS IS TO CERTIFY THAT THE FIRM NAMED ABOVE IS DULY REGISTERED TO
TRANSPORT HAZARDOUS WASTE IN THE STATE OF CALIFORNIA IN
ACCORDANCE WITH THE PROVISIONS OF CHAPTER 6.5, DIVISION 20 OF THE
HEALTH AND SAFETY CODE AND DIVISION 4.5, TITLE 22 OF THE CALIFORNIA
CODE OF REGULATIONS.

THIS REGISTRATION CERTIFICATE MUST BE CARRIED WITH EACH SHIPMENT OF
HAZARDOUS WASTE.

FOR REGISTRATION INFORMATION, PLEASE CONTACT MS. TARI PATTERSON AT
(916) 323-3219.


(AUTHORIZED SIGNATURE)

JUL 27 1999

(DATE)

**UNITED STATES OF AMERICA
DEPARTMENT OF TRANSPORTATION
RESEARCH AND SPECIAL PROGRAMS ADMINISTRATION**



**HAZARDOUS MATERIALS
CERTIFICATE OF REGISTRATION
FOR REGISTRATION YEAR**

1999-2000

Registrant:

BDC SPECIAL WASTE SERVICES
ATTN: FRANK GUTIERREZ
766 SOUTH AYON AVENUE
AZUSA, CA 91702-0000
USA

This certifies that the registrant is registered with the U. S. Department of Transportation as required by 49 CFR Part 107, Subpart G.

This certificate is issued under the authority of 49 U.S.C. §108. It is unlawful to alter or falsify this document.

Reg. No: 061599 012 049H Issued: 06/15/99 Expires: 06/30/00

Reissued: 06/30/99

Record keeping Requirements for the Registration Program

The following must be maintained at the principal place of business for a period of three years from the date of issuance of this Certificate of Registration:

- (1) A copy of the registration statement filed with RSPA; and
- (2) This Certificate of Registration

Each person subject to the registration requirement must furnish that person's Certificate of Registration (or a copy) and all other records and information pertaining to the information contained in the registration statement to an authorized representative or special agent of the U. S. Department of Transportation upon request.


Each motor carrier (private or for-hire) and each vessel operator subject to the registration requirement must keep a copy of the current Certificate of Registration or another document bearing the registration number identified as the "U.S. DOT Hazmat Reg. No." in each truck and truck tractor or vessel (trailers and semi-trailers not included) used to transport hazardous materials subject to the registration requirement. The Certificate of Registration or document bearing the registration number must be made available, upon request, to enforcement personnel.

For information, contact the Hazardous Materials Registration Manager, DPM-80 Research and Special Programs Administration, U.S. Department of Transportation, 400 Seventh Street, SW, Washington, DC 20590, telephone (202) 368-4109.

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.	Manifest Document No.	2. Page 1 of 1	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address		A. State Manifest Document Number		97337031	
4. Generator's Phone ()		B. State Generator's ID			
5. Transporter 1 Company Name		6. US EPA ID Number		C. State Transporter's ID	
BDC-FALCON SPECIAL WASTE SERVICES		CAR0000017657		D. Transporter's Phone (626) 969-1384	
7. Transporter 2 Company Name		8. US EPA ID Number		E. State Transporter's ID	
9. Designated Facility Name and Site Address		10. US EPA ID Number		G. State Facility's ID	
B & J LANDFILL 6426 HAY ROAD VACAVILLE, CA 95687		CAD982042475		H. Facility's Phone (707) 451-3276	
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers No.	Type	13. Total Quantity	14. Unit Wt/Vol
a. R.Q. ASBESTOS, 9, NA 2212, PGIII (NAERG#171)					
b.					
c.					
d.					
15. Special Handling Instructions and Additional Information		16. Handling Codes for Waste Listed Above			
24 HRS. EMERGENCY 1-800-535-5053 BDC-FALCON 766 SOUTH AYON AZUSA, CA 91702 EPA REGION IX-75 HAWTHORNE ST. BAAQMD-939 ELLIS, SAN FRAN. CA ASBESTOS REMOVAL REQUIREMENT 40CFR61 (BAGGED, SEALED & LABELED) WEST COAST		03			
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.					
If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.					
Printed/Typed Name		Signature		Month	Day Year
17. Transporter 1 Acknowledgement of Receipt of Materials		Signature		Month	Day Year
Printed/Typed Name		Signature		Month	Day Year
18. Transporter 2 Acknowledgement of Receipt of Materials		Signature		Month	Day Year
Printed/Typed Name		Signature		Month	Day Year
19. Discrepancy Indication Space					
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.					
Printed/Typed Name		Signature		Month	Day Year

DO NOT WRITE BELOW THIS LINE.

NEGATIVE EXPOSURE ASSESSMENT



PRECISION^I MICRO-ANALYSIS^N_C

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

Air Sample Analysis (PCM) Report

Report # 99357010

Kevin Bussard
West Coast Environmental
3181 Fitzgerald Road
Rancho Cordova, CA 95742-

Date Received: 12/22/99
Date Analyzed: 12/27/99

Job Information:
EDD

Phone: (916) 852-7200

Sample Number	Lab #	Sample Location/Personnel	Date	Air Vol.	Fibers	Fields	Fiber/CC	UCL	LOD	LOQ
1001	00-200904	Personal: Jesus Lepe Room 1002 - Tile / mastic	12/15/99	1097	1.0	100	<0.001*	0.001	0.002	.0351
2002	00-200905	Personal: Omar Lepe Room 1002 - Tile / mastic	12/15/99	1046	6.0	100	0.003	0.006	0.003	.0368
3003	00-200906	Personal: Orlando Garcas Room 1002 - Tile / mastic	12/15/99	1061	2.5	100	0.001*	0.003	0.003	.0363
4004	00-200907	Personal: Rene Lepe Room 1002 - Tile / mastic	12/15/99	1056	2.0	100	0.001*	0.002	0.003	.0365
5005	00-200908	Personal: Tomas Montes Room 1002 - Tile / mastic	12/15/99	1082	1.5	100	0.001*	0.002	0.002	.0356
6006	00-200909	Personal: Omar Lepe Room 1002 - Tile / mastic	12/15/99	1097	2.0	100	0.001*	0.002	0.002	.0351

OFFICIAL NOTICE: After 45 days, samples are disposed of through a licensed waste hauler, unless client requests their return.

Total Number of Samples: 6

Page 1 of 1


Supervisor

Analyst

* Samples marked with asterisks were below the limit of detection (7 fibers/mm²) for the NIOSH 7400 method.

Note: The test result findings are made to the methodologies and parameters described on the reverse of this page.

3463 Ramona Ave., Suite 17 • Sacramento, CA 95826 • (916) 456-4892 • Fax (916) 456-1082



PRECISION MICRO-ANALYSIS

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

Air Sample Analysis (PCM) Report

Report # 99312006

Kevin Bussard
West Coast Environmental
3181 Fitzgerald Road
Rancho Cordova, CA 95742-

Date Received: 11/05/99
Date Analyzed: 11/08/99

Phone: (916) 852-7200

Job Information:
UC Davis
Steam Pits

Sample Number	Lab #	Sample Location/Personnel	Date	Air Vol.	Fibers	Fields	Fiber/CC	UCL	LOD	LOQ
1001	00-200365	Personal: Jose Medrano Remove pipe lagging	10/30/99	1008	12.0	100	0.006	0.011	0.003	0.0382
2002	00-200366	Personal: Rick Roybal Remove pipe lagging	10/30/99	1032	2.5	100	0.001*	0.003	0.003	0.0373

OFFICIAL NOTICE: After 45 days, samples are disposed of through a licensed waste hauler, unless client requests their return.

Total Number of Samples: 2


Page 1 of 1

Supervisor

Analyst

* Samples marked with asterisks were below the limit of detection (7 fibers/mm²) for the NIOSH 7400 method.

Note: The test result findings are made to the methodologies and parameters described on the reverse of this page.



PRECISION MICRO-ANALYSIS

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

8-HOUR TIME-WEIGHTED AVERAGE REPORT

Personnel: JOSE MEDRANO

SSN: 612-05-7319

Date Collected: 10/30/99

West Coast Environmental
3181 Fitzgerald Road
Rancho Cordova, CA 95742-

Job Information:
UC Davis
Steam Pits

Sampling History for this 8-Hour Time Period:

PMA Lab Number	Client's Sample #	Pump On	Pump Off	Total Time	Avg. Flow	Worker Activity	Respirator Protection Factor	Analytical Result (Fibers/CC)	Respirator Corrected Result
00-200365	11001	07:30	15:30	480	12.10	Pipe lagging	10	0.006	0.000600

NOTE: In the 8-hour Time Weighted Average calculation, 8 hours (480 minutes) is used as the sampling period, unless the total time sampled is greater than 8 hours. It is assumed that the unsampled portion of the 8-hours is free of asbestos exposure. The "Respirator Protection Factor" is an estimate of the relative degree of protection offered by the various types of respirators: Half-Face = 10, Full-Face = 50, P.A.F.R. = 100, S.A.R. = 1000.

Total Time Sampled: 480 minutes (8.00 hours)

8-Hour Time-Weighted Average: 0.006 F/CC

(Respirator-Corrected 8-Hour Time-Weighted Average: 0.000600 F/CC)


$$TWA = \frac{C(1)T(1) + C(2)T(2) + \dots + C(n)T(n)}{T}$$

480 (or total time if greater than 480)

Where C is the fiber concentration (F/CC)

and T is the time sampled (minutes)

In order to calculate the results of this Time Weighted Average (TWA) report, Precision Micro-Analysis, Inc. utilized client-supplied data. The responsibility for the accuracy of that data, along with the data concerning the type and fit testing of the respirators, rests solely with the client. The formula to the left is used to calculate the TWA. The method used by PMA for sample analysis is stated on the reverse side.



PRECISION MICRO-ANALYSIS

I
N
C

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

8-HOUR TIME-WEIGHTED AVERAGE REPORT

Personnel: RICK ROYBAL

SSN: 585-11-6060

Date Collected: 10/30/99

West Coast Environmental
3181 Fitzgerald Road
Rancho Cordova, CA 95742-

Job Information:
UC Davis
Steam Pits

Sampling History for this 8-Hour Time Period:

PMA Lab Number	Client's Sample #	Pump On	Pump Off	Total Time	Avg. Flow	Worker Activity	Respirator Protection Factor	Analytical Result (Fibers/CC)	Respirator Corrected Result
00-200366	2002	07:30	15:30	480	2.15	Pipe lagging	10	0.001	0.000100

NOTE: In the 8-hour Time Weighted Average calculation, 8 hours (480 minutes) is used as the sampling period, unless the total time sampled is greater than 8 hours. It is assumed that the unsampled portion of the 8-hours is free of asbestos exposure. The "Respirator Protection Factor" is an estimate of the relative degree of protection offered by the various types of respirators: Half-Face = 10, Full-Face = 50, P.A.P.R. = 100, S.A.R. = 1000.

Total Time Sampled: 480 minutes (8.00 hours)

8-Hour Time-Weighted Average: 0.001 F/CC

(Respirator-Corrected 8-Hour Time-Weighted Average: 0.000100 F/CC)

$$TWA = \frac{C(1)T(1) + C(2)T(2) + \dots + C(n)T(n)}{480 \text{ (or total time if greater than 480)}}$$

Where C is the fiber concentration (F/CC) and T is the time sampled (minutes)

In order to calculate the results of this Time Weighted Average (TWA) report, Precision Micro-Analysis, Inc. utilized client-supplied data. The responsibility for the accuracy of that data, along with the data concerning the type and fit testing of the respirators, rests solely with the client. The formula to the left is used to calculate the TWA. The method used by PMA for sample analysis is stated on the reverse side.

CONTRACTOR / ACTIVITY	M	T	W	T	F	M	T	W	T	F	M	T	W	T	F	M	T	W	T	F	M	T	W	T	F	M	T
UNITS K&M	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	3	4	5	6	7	10	11	12	13	14	17	18
SET UP CONTAINMENTS																											
REMOVE CABINETS																											
REMOVE TILE																											
REMOVE MASTIC																											
REMOVE PIPE LAGGING																											
ENCAPSULATE																											
FINAL AIR CLEARANCE																											
TEAR DOWN / LOAD OUT																											
UNIT B																											
SET UP CONTAINMENTS																											
DEMO PLASTER																											
ENCAPSULATE																											
FINAL AIR CLEARANCE																											
TEAR DOWN / LOAD OUT																											
UNIT S																											
SET UP CONTAINMENTS																											
DEMO PLASTER																											
REMOVE FLOOR TILE / MASTIC																											
REMOVE PIPE LAGGING																											
ENCAPSULATE																											
FINAL AIR CLEARANCE																											
TEAR DOWN / LOAD OUT																											

CRITICAL ITEMS & NOTES:

NOTIFICATION OF DEMOLITION AND RENOVATION

OPERATOR PROJECT #	POSTMARK	DATE RECEIVED	NOTIFICATION #		
I. TYPE OF NOTIFICATION (O-ORIGINAL R-REVISED C-CANCELLED) : O			WFR Notice?		
II. FACILITY INFORMATION (IDENTIFY OWNER, REMOVAL CONTRACTOR, AND OTHER OPERATOR)					
OWNER NAME: Chico Unified School District					
ADDRESS: 2455 Carmichael Drive					
CITY: Chico	STATE: CA	ZIP: 95928			
CONTACT: Mary Leary		TEL: (530) 898-3000			
REMOVAL CONTRACTOR: West Coast Environmental					
ADDRESS: 3181 Fitzgerald Road					
CITY: Rancho Cordova	STATE: CA	ZIP: 95742			
CONTACT: Kevin T. Bussard		TEL: (916) 852-7200			
OTHER OPERATOR:					
ADDRESS:					
CITY: Rancho Cordova	STATE: CA	ZIP: 95742			
CONTACT:		TEL:			
III. TYPE OF OPERATION (D-DEMO O-ORDERED DEMO R-RENOVATION E-EMER. RENOVATION) : R					
IV. IS ASBESTOS PRESENT? (YES/NO) Yes					
V. FACILITY DESCRIPTION (INCLUDE BUILDING NAME, NUMBER AND FLOOR OR ROOM NUMBER)					
Bldg NAME: Chico Junior High School					
ADDRESS: 280 Memorial Way					
CITY: Chico	STATE: CA	COUNTY: Butte			
SITE LOCATION: Bldgs, A,B, J,K,L,M		AGE IN YEARS: 20-30 yrs			
BUILDING SIZE: 50,000sf	NUM OF FLOORS: 1				
PRESENT USE: Education		PRIOR USE: Education			
VI. PROCEDURE, INCLUDING ANALYTICAL METHOD, IF APPROPRIATE, USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL:					
Bulk sample analyzed using PLM method.					
VII. APPROXIMATE AMOUNT OF ASBESTOS, INCLUDING:					
1. REGULATED ACM TO BE REMOVED	RACH TO BE REMOVED	NONFIBRILLABLE ASBESTOS MATERIAL NOT TO BE REMOVED		INDICATE UNIT OF MEASUREMENT BELOW	
2. CATEGORY I ACM TO REMOVED		CAT I	CAT II	UNIT	
3. CATEGORY II ACM TO REMOVED					
PIPES	1,197			LF: X	LI =:
SURFACE AREA	4,494	21,620		SQ: X	SQ =:
VOL RACH OFF FACILITY COMPONENT				CU: X	CU =:
VIII. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) START: 5/30/00 COMPLETE: 7/17/00					
IX. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) START: COMPLETE:					

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:
Remove pipe lagging material using wet methods and hand tools.

XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION AND RENOVATION SITE:
Remove pipe lagging material using negative pressure enclosure and wet methods. Double bag waste

XIII. WASTE TRANSPORTER #1

NAME: BDC Special Waste Services

ADDRESS: 6233 San Leandro Street

CITY: Oakland

STATE: CA

ZIP: 94621

CONTACT PERSON: Sherri Mooney

TELEPHONE: (510) 568-6732

WASTE TRANSPORTER #2

NAME:

ADDRESS:

CITY:

STATE:

ZIP:

CONTACT PERSON:

TELEPHONE:

XIII. WASTE DISPOSAL SITE

NAME: B&J Landfill

LOCATION: 6426 Hay Road

CITY: Vacaville

STATE: CA

ZIP: 95687

TELEPHONE: (707) 451-3276

XIV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

NAME:

TITLE:

AUTHORITY:

DATE OF ORDER (MM/DD/YY):

DATE ORDERED TO BEGIN (MM/DD/YY):

XV. FOR EMERGENCY RENOVATIONS

DATE AND HOUR OF EMERGENCY (MM/DD/YY):

DESCRIPTION OF THE SUDDEN, UNEXPECTED EVENT:

EXPLANATION OF HOW THE EVENT CAUSED UNSAFE CONDITIONS OR WOULD CAUSE EQUIPMENT DAMAGE OR AN UNREASONABLE FINANCIAL BURDEN:

XVI. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBED, PULVERIZED, OR REDUCED TO POWDER.

Remove using wet methods and negative pressure enclosure.

XVII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ON-SITE DURING THE DEMOLITION OR RENOVATION AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS (REQUIRED 1 YEAR AFTER PROMULGATION).

SIGNATURE OF OWNER/OPERATOR

5/2/00
(DATE)

XVIII. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT.

SIGNATURE OF OWNER/OPERATOR

5/2/00
(DATE)

**TEMPORARY WORKSITE NOTIFICATION FOR ASBESTOS
and METHYLENEDIANILINE-RELATED WORK**

COMPANY/EMPLOYER NAME: WCE, INC. DBA West Coast Environmental

HEADQUARTERS ADDRESS: 3181 Fitzgerald Road Rancho Cordova, CA 95742

*CONTRACTORS STATE LICENSE BOARD LICENSE NUMBER: 718733

DOSH-ACRU (CAL/OSHA) *ASBESTOS REGISTRATION NUMBER: 633
and/or *REPORT OF USE *REGISTRY NUMBER: _____

ADDRESS OF TEMPORARY WORKSITE and PRECISE LOCATION: Chico Junior High School
280 Memorial Way Chico, CA 95928 Bldgs. A,B,J,K,L, and M

NEAREST INTERSECTION: _____

TYPE OF BUSINESS: school

*NAME OF CERTIFIED SUPERVISOR: Anthony Roybal

*NAME OF QUALIFIED PERSON IN CHARGE OF AIR MONITORING,
LABORATORY WORK, AND RESPIRATORS: Anthony Roybal

*NAME OF CERTIFIED CONSULTANT: Cal Inc.

PROJECTED START DATE: 5/30/00 PROJECTED COMPLETION DATES: 7/17/00

DESCRIBE TYPE, SCOPE AND WORK PRACTICES OF JOB: Remove and dispose of approximately
1,197 lf of pipe lagging using wet methods and glove bagging techniques and 4,494 sf of ceiling plaster and
21,620 sf of floor tile/mastic using wet methods and negative pressure enclosure.

EVALUATION OF POTENTIAL FOR EXPOSURE: Minimal. Employees will wear respirators
and protective clothing

ESTIMATED NUMBER OF EMPLOYEES ON THIS JOB: 6-8

ACCORDING TO TITLE 8 CCR SECTIONS 341.9 AND 1529(r) for ASBESTOS and 5200(p) for MDA,
PLEASE SEND THIS COMPLETED NOTICE TO THE NEAREST DISTRICT COMPLIANCE OFFICE
(SEE ATTACHED LISTING), NOT TO DOSH HEADQUARTERS OR TO DOSH CONSULTATION,
PRIOR TO COMMENCEMENT OF ANY SUCH WORK ACTIVITY.

NOTE: ANY CHANGE IN THE INFORMATION PROVIDED TO THE DISTRICT OFFICE BY THE
WRITTEN NOTICE SHALL BE REPORTED TO THE DISTRICT OFFICE WITHIN 24 HOURS
OF SUCH CHANGE.

*THE STAR DENOTES ASBESTOS INQUIRY ONLY

CAL/OSHA 183B
May, 1993

STATE OF CALIFORNIA
REGISTRATION FOR AHERA ACCREDITED PERSONS
 PURSUANT TO CHAPTER 1601, STATUTES OF 1933
 SAB 238 (REV. 08/98)

STATE ALLOCATION BOARD
 OFFICE OF PUBLIC SCHOOL CONSTRUCTION

(See reverse side for instructions)

The following information is necessary for the Office of Public School Construction (OPSC) to register or renew your registration as an Asbestos Hazard Emergency Response Act (AHERA) accredited inspector, management planner, project designer, abatement contractor, supervisor or worker.

PART I

FIRM NAME West Coast Environmental		APPLICANT NAME CARLOS LOPEZ	
ADDRESS 3181 Fitzgerald Road		ADDRESS 3181 Fitzgerald Road	
CITY/ZIP CODE Rancho Cordova 95742	CITY/ZIP CODE Rancho Cordova, CA 95742		
COUNTY Sacramento	STATE CA	COUNTY Sacramento	STATE CA
PHONE NUMBER (916) 852-7200	E-MAIL ADDRESS	PHONE NUMBER (916) 852-7200	E-MAIL ADDRESS

PART II

1	2	3	4	5
DISCIPLINE	REGISTRATION REQUEST	TRAINING PROVIDER CERTIFICATE NUMBER	TRAINING PROVIDER CERTIFICATE EXPIRATION DATE	(OPSC USE ONLY)
	New	Renewal		OPSC REGISTRATION NUMBER
a. ☐ Inspector				
b. ☐ Management Planner				
c. ☐ Project Designer				
d. ☐ Abatement Contractor				
e. ☐ Abatement Supervisor				
f. ☒ Abatement Work	X	HEES 17000	11/11/00	2000.155 3.29.00

*PART III Must be completed by abatement contractor for registration to be valid.

DOCSH/DIR REGISTRATION NUMBER 633	CONTRACTOR'S STATE LICENSE BOARD LICENSE NUMBER 718733
--------------------------------------	---

I certify that I have met all the requirements for accreditation and registration, and the statements I have made are true and correct. The attached Training Provider's Certificate is a copy of the original certificate.

SIGNATURE (Original signature of applicant is required) CARLOS LOPEZ	DATE 3/22/00
---	-----------------

Certificate of Training

This is to certify that

Amado Tellez

671-98-9865

has successfully completed 8 hours of formal training entitled

AHERA Worker Refresher

*as certified by the Environmental Protection Agency and approved by AHERA under TSCA Title II
presented by*

**Design For Health
Training Center**

3574 Kettner Blvd.
San Diego, CA 92101
Phone: (619) 291-1777 Fax: (619) 291-4318

Certificate #500WR7235
Course Date: 05/22/00
Exam Date: N/A

This is an annual certification. It must be renewed by: 05/22/01

By Virginia L. Shyfa

MED CENTER MEDICAL CLINIC

6651 MADISON AVENUE
CARMICHAEL, CA 95608

TELEPHONE (916) 965-1111
FAX (916) 965-5143

MEDICAL EXAMINATION CERTIFICATE

Final Report

I certify that I have examined the below named employee in accordance with the provisions of Title 29 Code of Federal Regulations 1926.58 (m) (ii). I have provided their employer with the results of the medical examination and included as part of a written opinion that I have not detected any medical health conditions that 1) would place any of these employees at an increased risk of material health impairment from exposure to airborne asbestos fibers, and 2) would not limit their use of negative pressure respirators. I have informed the employee of the results of the medical examination. I also certify that the employer provided me with all of the information required in 29 CFR 1926.58 (m) (3).

Company

West Coast Environmental

Employee Name

Tellez, Amado

Social Security Number

671-98-9865

Expiration Date

6-12-00

Don W. Burt MD

Physician Signature

Name/Stamp

6-12-99

Date

WEST COAST ENVIRONMENTAL

RESPIRATOR FIT TEST

EMPLOYEE NAME Amado Teller DATE 2.25.00
SOCIAL SECURITY NUMBER 671-98-9865

RESPIRATORS TESTED

QUANTITATIVE RESULTS

Make/Model North 7700 Size M NIOSH/MSHA # TC-21C-132

Make/Model _____ Size _____ NIOSH/MSHA # _____

TYPE OF TEST

Quantitative _____

Qualitative X

Isoamyl Acetate _____

Irritant Smoke X

TEST EXERCISES

- ☒ Positive/Negative Pressure Test
- ☒ Normal Breathing
- ☒ Deep Breathing
- ☒ Turn Head Side to Side
- ☒ Nod Head Up and Down
- ☒ Reading (Rainbow Passage)
- ☒ Grimace
- ☒ Bend Over and Touch Toes
- ☒ Jogging in Place
- ☒ Breathe Normally

THIS CERTIFIES THAT THE ABOVE NAMED TEST SUBJECT HAS BEEN INFORMED OF THE HAZARDS INVOLVED IN WORKING WITH ASBESTOS, AND HAS BEEN GIVEN INSTRUCTION IN THE USE AND CARE OF THE RESPIRATOR SELECTED.

Employee Signature Amado Teller

Witnessed By Anthony B. Rafael

RJ Lee Group, Inc.

530 McCormick Street • San Leandro, CA 94577
(510) 567-0480 • FAX (510) 567-0488

March 3, 2000

Mr. Peter Connell
CAL Environmental Services, Inc.
P. O. Box 6327
Vacaville, CA 95696-6327

RE: PLM Standard Asbestos Analysis Results for Samples as Shown on Test Report
RJLeeGroup, Inc. Job No.: AOC003030
Client P.O./Job Number: Chico Jr. High School
Client Job Name/Location: Chico

Dear Mr. Connell:

Enclosed are the results from the polarized light microscopy (PLM) asbestos analysis of the above referenced sample(s). Sample(s) were analyzed in accordance with guidelines set forth in the Interim Method for the Determination of Asbestos in Bulk Insulation Samples (40 CFR Part 763, Appendix E to Subpart E).


Test Report lists each sample identification number, gross sample description, sample location, type(s) and concentration of asbestos, type(s) and concentration of nonasbestos fibers, major components and concentration of nonfibrous material (NFM), sample run date, analyst, sample homogeneity, and a layer breakdown if applicable. All concentrations are given in area percents (visual estimation).

RJ Lee Group, Inc. is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) (NVLAP Participant Number 1208-2) for bulk asbestos fiber analysis (PLM), and by the California Department of Health Services, Environmental Laboratory Accreditation Program (CALELAP) for bulk asbestos analysis. Neither the NVLAP Accreditation of this laboratory nor this report may be used to claim product endorsement by NVLAP or any agency of the United States government. The results reported relate only to the items tested. The report shall not be reproduced except in full.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the sample(s) covered by this report, RJ Lee Group will store the sample(s) for a period of ninety (90) days before discarding. A shipping and handling fee will be assessed for the return of any sample(s).

If you have any questions on this report or if RJ Lee Group, Inc. can be of further assistance, please do not hesitate to call.

Sincerely,



Stephen S. Yata
Geologist

SSY/sjb
Enclosure