

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 26, 1991

SCHOOL District Office INSPECTOR Robert Peters V.P.

BLDG.	HOMOG. MAT. #	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
1	9" VFT	1-5%	Computer Room Office	1-4
1	PW Str	80-85%	Basement Crawl Space	2 - 4 - 10 (no sign)
1	PW Jnt	10-15%	Basement Crawl Space	2 - 4 - 10
1	PW Debris	25-35%	Basement Crawl Space	2 - 4 - 10

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 2, 1991

SCHOOL Corporation Yard INSPECTOR Robert Peters R.P.

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Mechanics Office	1-4
A	9" VFT	1-5	Maintenance Office	1-4
A	Asbestos curtain	Assumed	Welding Booth	(5) (7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)