

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11-24-2003

District: Chico Unified School District

Inspector: Robert Baughman

School: Corporate Yard

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Frivable Yes/No
M	9" VFT	2	1-5%	980 S	MECHANICS OFFICE & MAINTENANCE OFFICE	(1) (4) SAME 11/24/03	N
M	12" VFT	4	TRACE	40 S	UPSTAIRS RESTROOM	(1) (4) SAMPLE HMS-COP-04 COLLECTED IN 1988.	N
M	12" VFT	6	TRACE	180 S	TRANSPORTATION OFFICE	(1) (4) SAMPLE HMS-COP-06 COLLECTED IN 1988.	N
M	12" ACT	7	NONE DETECTED	680 S	DRIVERS LOUNGE & TRANSPORTATION OFFICE	(13) SAMPLE HMS-COP-07 COLLECTED IN 1988.	N/A
M	DRYWALL	77	NONE DETECTED	5,000 S	ALL ROOMS	(13) SAMPLE HMS-CUSD-CORP-77A COLLECTED ON 5-20-92.	N/A
M	12" VFT	78	ASSUMED	150 S	DRIVERS LOUNGE	(1) SAME 11/24/03	N
M	GLAZING COMPOUND	79	ASSUMED	50 L	GROUND SHED WINDOWS	(1) (4) SAME 11/24/03	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11-24-2003

School: Corporate Yard

Building: Key Smith Shop

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT BEIGE	62	ASSUMED	500 S	KEY SMITH SHOP	(1) (4) Same, Just More Dirt SAME 11/24/03	N

School: Corporate Yard

Building: Paint Shop

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL	75	1-5% IN SKIM COAT	2,000 S	PAINT SHOP - ALL AREAS	(1) (4) SAME 11/24/03	N

CONDITION CODE

- General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

School: Corporate Yard

Building: Poison Storage

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL	76	NONE DETECTED	500 S	ALL ROOMS, Grounds Shop	(13) SAME 11/24/03	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/12/2003

District: Chico Unified School District

Inspector: Robert Peters

School: Corporate Yard

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT	2	1-5%	980 S	MECHANICS OFFICE & MAINTENANCE OFFICE	(1) (4) Same 5/12/03	N
M	12" VFT	4	TRACE	40 S	UP-STAIRS RESTROOM	(1) (4) SAMPLE HMS-COP-04 COLLECTED IN 1988.	N
M	12" VFT	6	TRACE	180 S	TRANSPORTATION OFFICE	(1) (4) SAMPLE HMS-COP-06 COLLECTED IN 1988.	N
M	12" ACT	7	NONE DETECTED	680 S	DRIVERS LOUNGE & TRANSPORTATION OFFICE	(13) SAMPLE HMS-COP-07 COLLECTED IN 1988.	N/A
M	DRYWALL	77	NONE DETECTED	5,000 S	ALL ROOMS	(13) SAMPLE HMS-CUSD-CORP-77A COLLECTED ON 5-20-92.	N/A
M	12" VFT	78	ASSUMED	150 S	DRIVERS LOUNGE	(1) Same 5/12/03	N
M	GLAZING COMPOUND	79	ASSUMED	50 L	GROUND SHED WINDOWS	(1) (4) Same 5/12/03	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/12/2003

District: Chico Unified School District

Inspector: Robert Peters

School: Corporate Yard

Building: Key Smith Shop

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT BEIGE	62	ASSUMED	500 S	KEY SMITH SHOP	(1) (4) Same, Just More Dirt 5/12/03	N

School: Corporate Yard

Building: Paint Shop

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL	75	1-5% IN SKIM COAT	2,000 S	PAINT SHOP - ALL AREAS	(1) (4) Same 5/12/03	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/12/2003

District: Chico Unified School District

Inspector: Robert Peters

School: Corporate Yard

Building: Poison Storage

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL	76	NONE DETECTED	500 S	ALL ROOMS, Grounds Shop	(13) SAME 5/13/03	N/A

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

22709819

IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802. WITHIN CALIFORNIA, CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. C A C 0 0 2 3 1 5 6 1 7 5		Manifest Document No. 0 9 8 1 9		2. Page 1 of 1		Information in the shaded areas is not required by Federal law.									
3. Generator's Name and Mailing Address Chico Unified School District 2455 Carmichael Dr. Chico, CA 95928 4. Generator's Phone (530) 895-3195						A. State Manifest Document Number 22709819											
5. Transporter 1 Company Name A/C Industrial Services Corp.						6. US EPA ID Number C A D 9 8 3 6 6 1 4 6 3											
7. Transporter 2 Company Name						8. US EPA ID Number											
9. Designated Facility Name and Site Address Bay Road Landfill 6426 Bay Road Yacaville, CA 95607						10. US EPA ID Number C A D 9 8 2 0 4 2 4 7 5											
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number) FR Asbestos, 9, NA2212, PGIII						12. Containers		13. Total Quantity		14. Unit Wt/Vol		I. Waste Number					
						No.		Type						State		151	
								B A		4000 GZ		Y		EPA/Other			
														State			
														EPA/Other			
J. Additional Descriptions for Materials Listed Above 11a) 52 x bags						K. Handling Codes for Wastes Listed Above a. b. c. d.											
15. Special Handling Instructions and Additional Information 24 Hour Emergency Service -- (800)-341-5468 JCE #03-0434																	
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.																	
Printed/Typed Name ALEX NEE				Signature <i>[Signature]</i>				Month		Day		Year					
17. Transporter 1 Acknowledgement of Receipt of Materials Printed/Typed Name KUBER RESEYS				Signature <i>[Signature]</i>				Month		Day		Year					
18. Transporter 2 Acknowledgement of Receipt of Materials Printed/Typed Name				Signature				Month		Day		Year					
19. Discrepancy Indication Space																	
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19. Printed/Typed Name										Signature		Month		Day		Year	

DO NOT WRITE BELOW THIS LINE.

22531250
 IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-852-7550
 GENERATOR
 TRANSPORTER
 FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. CAD981415284	Manifest Document No. 086161	2. Page 1 of 1	Information in the shaded areas is not required by Federal law.	
3. Generator's Name and Mailing Address CHICO UNIFIED SCHOOL DISTRICT (TRANS. DEPT.) 2455 CARMICHAEL DRIVE CHICO, CA 95928 530 891-3097				A. State Manifest Document Number 22531250		
4. Generator's CA ID No. 530 891-3097				B. State Generator's ID		
5. Transporter 1 Company Name CHICO DRAIN OIL SERVICE		6. US EPA ID Number CAD980694103		C. State Transporter's ID (Reserved)		
7. Transporter 2 Company Name		8. US EPA ID Number		D. Transporter's Phone		
9. Designated Facility Name and Site Address D/K ENVIRONMENTAL 3650 EAST 26TH STREET VERNON CA 90023		10. US EPA ID Number CAT080033681		E. State Transporter's ID (Reserved)		
				F. Transporter's Phone		
				G. State Facility ID CAT080033681		
				H. Facility's Phone (923) 268-5056		
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers	13. Total Quantity	14. Unit	1. Waste Number	
a. NON RCRA HAZARDOUS WASTE LIQUID		No. 001	Type DM	Quantity 00050	Wt/Vol G	State 222
b. DK ENVIRONMENTAL FACILITY IN LOS ANGELES, CALIFORNIA HAS THE APPROPRIATE PERMITS TO RECEIVE YOUR WASTE STREAM AS QUALIFIED OUR EPA NUMBER IS CAT080033681						EPA/Other
c.						State
d.						EPA/Other
J. Additional Descriptions for Materials Listed Above OILY SLUDGE WITH DEBRIS				K. Handling Codes for Waste Listed Above		
				a. 0301	b.	
				c.	d.	
15. Special Handling Instructions and Additional Information WEAR GLOVES AND EYE PROTECTION. 24 HR. EMERGENCY CONTACT CHEMTREC 800-424-9300 AND CHICO DRAIN OIL 800-733-9043						
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.						
Printed/Typed Name LARRY SHEPARD		Signature <i>Larry Shepard</i>		Month 07	Day 23	Year 03
17. Transporter 1 Acknowledgement of Receipt of Materials Printed/Typed Name ROD DeLeon		Signature <i>Rod DeLeon</i>		Month 07	Day 23	Year 03
18. Transporter 2 Acknowledgement of Receipt of Materials Printed/Typed Name		Signature		Month	Day	Year
19. Discrepancy Indication Space						
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19. Printed/Typed Name Clayton Perez		Signature <i>Clayton Perez</i>		Month 07	Day 23	Year 03

DO NOT WRITE BELOW THIS LINE.

Yellow: 780-655-6125
 FACILITY
 SENDS THIS COPY TO GENERATOR WITHIN 30 DAYS.
 (Generators who submit hazardous waste for transport out-of-state, produce completed copy of this copy and send to DTSC within 30 days.)

CERTIFICATE OF TREATMENT/RECYCLING

PRESENTED TO

CHICO UNIFIED SCHOOL DIST.

Manifest No: 22531250

Date: 07/31/03

The waste stream(s) received on the above manifest has been treated/handled to standards mandated by the applicable federal and/or state regulations. Waste treatment is performed under permits granted to D/K ENVIRONMENTAL, a California corporation, by the California EPA in coordination with the U.S. Environmental Protection Agency, in the accordance with the provisions of the Resource Conservation and Recovery Act (RCRA) of 1976, together with applicable federal and state regulations.

When the above described material is accepted by D/K ENVIRONMENTAL, the responsibility for the material becomes that of D/K ENVIRONMENTAL for the treatment/recycling.

Issued By

D/K ENVIRONMENTAL

Signed:



Date: 07/31/03



Forensic Analytical
Analytical Report

Preliminary FAX

Bulk Asbestos Analysis

(EPA Method 600/R-93-116)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B049198
Date Received: 04/04/03
Date Analyzed: 04/07/03
Date Printed: 04/07/03

Job ID / Site: Corporate Yard

FASI Job ID: 2921-63

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
D-3	10225536						
		Layer: Yellow Semi-Fibrous Material				ND	
		Layer: Off-White Fibrous Material				ND	
		Layer: Tan Semi-Fibrous Material				ND	
		Layer: Grey Fibrous Material				ND	
		Layer: Beige Woven Material				ND	
		Layer: Tan Adhesive				ND	

Total Composite Values of Fibrous Components:	Asbestos:(ND)
Cellulose (7%)	Synthetic (7%)

D-4	10225537						
		Layer: Grey Non-Fibrous Material				ND	
		Layer: Beige Woven Material				ND	
		Layer: Off-White Non-Fibrous Material				ND	
		Layer: Tan Fibrous Material				ND	

Total Composite Values of Fibrous Components:	Asbestos:(ND)
Cellulose (70%)	Synthetic (5%)

*C: Mary Beary
Kip Hansen
Bob Michael
Rob Peters
Brenda Co
Jill*

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written consent from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.




Forensic Analytical

BULK SAMPLE REQUEST FORM

CLIENT NAME & ADDRESS: 2921 Chico Unified School District 63 2455 Carmichael Drive Chico, CA 95928		PHONE: (916) 891- FAX: (916) 891-3190	DATE: 4/3/03
		Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM Standard Point Count	Gravimetry Prep
CONTACT: ROB PETERS.		TEM: QUAL / QUANT. / WATER	
P.O.#	JOB #	AA/Flame AA/Furnace ICP	
SITE: CORP YARD.		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
D-3	4/3	FOLDING DOOR IN STORAGE (WHITE)
D-4	4/3	FOLDING DOOR IN STORAGE (YELLOW)

Sampled by: ROB PETERS	Date: 4/3/03 Time: 12:50
Relinquished by:	Received By: Melissa [Signature]
Date/Time:	Date/Time: 4/4/03 [Signature]
Relinquished by:	Sealed Condition (circle one) YES / NO
Date/Time:	Received By:
Date/Time:	Date/Time:
	Sealed Condition (circle one) YES / NO



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B049198
Date Received: 04/04/03
Date Analyzed: 04/07/03
Date Printed: 04/07/03
First Reported: 04/07/03

Job ID / Site: Corporate Yard

FASI Job ID: 2921-63

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
D-3	10225536						
		Layer: Yellow Semi-Fibrous Material		ND			
		Layer: Off-White Fibrous Material		ND			
		Layer: Tan Semi-Fibrous Material		ND			
		Layer: Grey Fibrous Material		ND			
		Layer: Beige Woven Material		ND			
		Layer: Tan Adhesive		ND			

Total Composite Values of Fibrous Components: **Asbestos:(ND)**

Cellulose (7%) Synthetic (70%)

Comment: Collected on 04/03/2003

D-4 10225537

Layer: Grey Non-Fibrous Material	ND
Layer: Beige Woven Material	ND
Layer: Off-White Non-Fibrous Material	ND
Layer: Tan Fibrous Material	ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)**

Cellulose (70%) Synthetic (5%)

Comment: Collected on 04/03/2003

*C: many
Kip
Rob m.
Beriles (3)
Jeli*

Jim Flores

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.



BULK SAMPLE REQUEST FORM

NAME & ADDRESS: 2921 Chico Unified School District 63 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE: 4/3/03
	Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	
	PLM: <u>Standard</u> Point Count	
CONTACT: ROBERT PETERS		
P.O.#	JOB #	TEM: QUAL. / QUANT. / WATER AA/Flame AA/Furnace ICP
SITE: CORP YARD		
METALS:		

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
D-3	4/3	FOLDING DOOR IN STORAGE (WHITE)
D-4	4/3	FOLDING DOOR IN STORAGE (YELLOW)

Sampled by: ROBERT PETERS	Date: 4/3/03 Time: 12:50
Relinquished by:	Received By: Melissa [Signature]
Date/Time:	Date/Time: 4/4/03
Relinquished by:	Sealed Condition (circle one) YES / NO
Date/Time:	Received By:
Relinquished by:	Date/Time:
Date/Time:	Sealed Condition (circle one) YES / NO

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

April 3, 2003

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Corporation Yard Folding Doors


To Whom It May Concern:

Please test the enclosed samples from the folding doors stored at the Corporation Yard for asbestos. We would like a 24-hour turn around on the samples. Please fax the results to us as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Corporation Yard
Location: Folding Doors in Storage
Date Sampled: April 3, 2003
Number of Samples: Two (2), Sample #D-3 & #D-4
Sample Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosure



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B055172
Date Received: 10/16/03
Date Analyzed: 10/16/03
Date Printed: 10/17/03
First Reported: 10/17/03

Job ID / Site: USD Corp Yard - Transp. Office

FASI Job ID: 2921-71

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
T0-1	10272429						
		Layer: Beige Skimcoat/Joint Compound			ND		
		Layer: Drywall Tape			ND		
		Layer: Paint			ND		

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (80%)
 Comment: Collected on 10/15/2003

T0-2	10272430						
		Layer: Beige Skimcoat/Joint Compound			ND		
		Layer: Drywall Tape			ND		
		Layer: Paint			ND		

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (80%)
 Comment: Collected on 10/15/2003

T0-3	10272431						
		Layer: Beige Skimcoat/Joint Compound			ND		
		Layer: Drywall Tape			ND		
		Layer: Paint			ND		

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (80%)
 Comment: Collected on 10/15/2003

*C: Mary Leary
 Rep Hansen
 Rob Peters
 Sanders (3)
 Jiri*

OCT 22 2003
 FACILITIES

Jim Flores

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

All results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.



BULK SAMPLE REQUEST FORM

CLIENT NAME & ADDRESS: 2921 - 71 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE: 10/15/03
	Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	Results Needed
	PLM: Standard / Point Count	Gravimetry Prep
	TEM: QUAL. / QUANT. / WATER AA/Flame AA/Furnace ICP	
CONTACT: ROB PETERS		METALS:
P.O.#	JOB #	
SITE: CORP YARD - Transp. Office		

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
T0-1	10/15	YELLOW DRYWALL SAMPLE
T0-2	10/15	OFF WHITE DRYWALL
T0-3	10/15	GLUE MASTIC ON DRYWALL

Sampled by: ROB PETERS.	Date: 10/15 Time: 7:12
Relinquished by:	Received By: E. [Signature] 12:40 PM 10/16/03
Date/Time:	Date/Time:
Sealed Condition (circle one) YES / NO	Sealed Condition (circle one) YES / NO
Relinquished by:	Received By:
Date/Time:	Date/Time:
Sealed Condition (circle one) YES / NO	Sealed Condition (circle one) YES / NO

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

Fed Ex Priority Overnight
Tracking #8358 1795 1319

October 15, 2003

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Corporation Yard - Transportation Office

To Whom It May Concern:

Please test the enclosed drywall samples from the Corporation Yard Transportation Office for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Corporation Yard
Location: Transportation Office
Date Sampled: October 15, 2003
Number of Samples: Three
#TO-1 Yellow Dry Wall Sample
#TO-2 Off White Drywall
#TO-3 Glue Mastic on Drywall

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures

Semi Copy 10/16/03