

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8808998

Sample Number: CHS-56

Site: Chico High School

Analyst: MF

Location: Lincoln Hall, Staff Dining Room - wall and ceiling tile.

P.O.: Chico USD

Gross Description: Off-white, fibrous, ceiling tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	90-95	%	90-95	%
Mineral Wool	Trace	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	%	5-10	%
--------------------------	------	---	------	---

Analyst:

Michelle D. Fox

Supervisor:

ae

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8808999
Sample Number: CMS-57A
Site: Chico High School

Analyst: MF

Location: Lincoln Hall, Women's RR - ceiling, troweled on
plaster.

P.O.: Chico USD

Gross Description: White plaster powder (Sample size too small
for accurate quantitation)

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
--------------------------	-------	---	-------	---

Analyst:

Michelle Fox

Supervisor:

ae

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809000

Analyst: MF

Sample Number: CHS-57B

Site: Chico High School

Location: Lincoln Hall, Men's RR - T-O-P ceiling (troweled on plaster).

P.O.: Chico USD

Gross Description: White plaster powder (Sample size too small for accurate quantitation)

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	3
Amosite	<1	3
Crocidolite	<1	3

1-5 1

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	3
Mineral Wool	<1	3
Polyethylene	<1	3

<1 1

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	3
--------------------------	-------	---

95-99 1

Analyst:

Michelle J. Fox

Supervisor:

MF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809001

Sample Number: CHS-57C

Site: Chico High School

Analyst: MF

Location: Entrance to Staff Dining Room - T-O-P ceiling.

P.O.: Chico USD

Gross Description: White plaster powder (Sample size too small for accurate quantitation)

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	Trace	3	Trace	3
Amosite	<1	3		
Crocidolite	<1	3		
		3		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	3	<1	3
Mineral Wool	<1	3		
Polyethylene	<1	3		
		3		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	98-99	3	98-99	3
		3		
		3		
		3		

Analyst:

Michelle Fox

Supervisor:

[Signature]

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809002

Sample Number: CHS-57D

Site: Chico High School

Analyst: HF

Location: Middle of Cafeteria - T-O-P ceiling.

P.O.: Chico USD

Gross Description: White plaster powder (Sample size too small for accurate quantitation)

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	3	1-3	3
Amosite	<1	3		
Crocidolite	<1	3		
		3		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	3	<1	3
Mineral Wool	<1	3		
Polyethylene	<1	3		
		3		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	93-99	3	95-99	3
		3		
		3		
		3		

Analyst:

Michelle Fox

Supervisor:

[Signature]

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 148

Report Number: 7021

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809003

Sample Number: CHS-57E

Site: Chico High School

Analyst: MF

Location: Ceiling near Stage of Cafeteria - T-O-P ceiling.

P.O.: Chico USD

Gross Description: White plaster powder.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	3	1-5	3
Amosite	<1	3		
Crocidolite	<1	3		
		3		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	3	<1	3
Mineral Wool	<1	3		
Polyethylene	<1	3		
		3		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	3	95-99	3
		3		
		3		
		3		

Analyst:

Michelle Fox

Supervisor:

MF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7011

Date Received: 04/04/88

Date Examined: 04/12/88

Lab Number: 8809004

Sample Number: CHS-58

Site: Chico High School

Analyst: MF

Location: Stage of Lincoln Hall - 9" VET - white (900 sq ft).

P.O.: Chico USD

Gross Description: Off-white floor tile assoc. with black tar adhesive. (Asbestos in both)

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	3	1-5	3
Amosite	<1	3		
Crocidolite	<1	3		
		3		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	3	1-5	3
Mineral Wool	<1	3		
Polyethylene	<1	3		
		3		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	90-95	3	90-95	3
		3		
		3		
		3		

Analyst:

Michelle J. Fox

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809005

Analyst: MF

Sample Number: CHS-59

Site: Chico High School

Location: Rm F1 Fine Arts Building (Act Room) - 2 x 4 ceiling panels.

P.O.: Chico USD

Gross Description: Off-white fibrous ceiling tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	10-15	%	90-95	%
Mineral Wool	75-80	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	%	5-10	%
		%		
		%		
		%		

Analyst:

Michelle J. Fox

Supervisor:

SC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809006

Sample Number: CHS-60

Site: Chico High School

Analyst: MF

Location: Fine Arts Building, Rm F1, Act Room - pw corners.

P.O.: Chico USD

Gross Description: Grey semifibrous powder.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	5-10	%	5-10	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%	55-60	%
Mineral Wool	55-60	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	30-35	%	30-35	%
--------------------------	-------	---	-------	---

Analyst:

Michelle J. Fox

Supervisor:

ee

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%), are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7031

Date Received: 04/04/88

Date Examined: 04/10/88

Lab Number: 8809007

Sample Number: CHS-61

Site: Chico High School

Analyst: HF

Location: Fine Arts Building, Rm Fl. Act Room - 9" VET - beige.

P.O.: Chico USD

Gross Description: Beige floor tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile

Trace

Trace

Amosite

<1

Crocidolite

<1

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose

Trace

Trace

Mineral Wool

<1

Polyethylene

<1

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

88-99

88-99

Analyst:

Michelle J. Fox

Supervisor:

HF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

Client:

FOR

Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 7031
Date Received: 04/04/88
Date Examined: 04/10/88

Lab Number: 8809008
Sample Number: CHS-62
Site: Chico High School

Analyst: HF

Location: Fine Arts Building, Outside of Room 22 - kiln brick
lining.
P.O.: Chico USD

Gross Description: White fibrous insulation.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile			<1	0
Amosite	<1	0		
Crocidolite	<1	0		
	<1	0		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose			20-25	0
Mineral Wool	Trace	0		
Polyethylene	80-85	0		
	<1	0		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	15-20	0	15-20	
		0		
		0		
		0		

Analyst:

Michelle Fox

Supervisor:

HF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Client Number Report Number
 Received By Date Rec'd
 Billing Address: HAZARD MANAGEMENT SERVICES, INC.
Bill To:
P.O. Box 7012, Modesto, Ca 95355
School CHICO H.S.
OR
Bldg

Reported Results Date/Time/By
 Collected by: JES Date 3/28/88
 Sent to Lab by: JES date 4/1/88
 LAB Request: % Asbestos By PLM

Sample #HMS-	Sample I - 1 page No	MATERIALS/LOCATION	% Asbestos
CHS-01	1	M: 2x4 ceil panel L: Admin Reception Area Bldg A-1 (Main)	<1
CHS-02	2	M: Ceiling 12" VFT L: Admin Reception Area Bldg A-1 (Main)	TRACE
CHS-03	3	M: Ceil tile 12" - acoustic L: Admin Reception A-106	<1
CHS-04	4	M: Baseboard & glue L: Admin. office Area	<1
CHS-05A	5	M: Drywall L: Admin office A-102	<1
CHS-06	6	M: 2x4 Ceiling Panel L: Classroom A-130 - Main Bldg	<1
CHS-05B	5	M: Drywall L: Main Bldg A-134 Office - Reception area	<1
CHS-05C	5	M: Drywall L: Rm 114 - Main Bldg	<1
CHS-05D	5	M: Drywall L: A-113 Secretary's Office	<1
CHS-07	7	M: Perforated concrete - mounded L: Reception area, Main Bldg 1st Floor	5-10

Client Number		Report Number		HAZARD MANAGEMENT SERVICES, INC.		<u>CHICO UNIFIED SCHOOL DIST.</u>	
Received By		Date Rec'd		Bill To:		District or Business	
				P.O. Box 7012, Modesto, Ca 95355		School <u>CHICO H.S.</u>	
				Billing Address:		OR	
				Bldg		date <u>4/1/88</u>	
Reported Results		Date/Time/By		Collected by: <u>JES</u>		Sent to Lab by:	
				LAB Request: % Asbestos By PLM			

FAS Lab#	Sample #HMS-	I - 1 page No	MATERIALS/LOCATION	% Asbestos
	CHS-08	8	M: <u>Asbestos</u> L: <u>Asbestos - 1st Floor</u>	15-20
	CHS-10	10	M: <u>Ventilation - duct work</u> L: <u>2nd floor - main entry - A208</u>	<1
	CHS-09	9	M: <u>Plaster - wall</u> L: <u>Exterior wall - 2nd floor - Hallways - Main Bldg</u>	TRACE
	CHS-11	11	M: <u>2x4 panel ceiling</u> L: <u>Room A-102 2nd floor - Main Bldg</u>	<1
	CHS-12A		M: <u>Plaster</u> L: <u>Wing C - 12A 2nd floor</u>	<1
	12B		M: <u>As above</u> L:	<1
	12C		M: <u>As above</u> L:	<1
	CHS-13		M: <u>2x4 panel ceiling</u> L: <u>Wing C - Room C-1</u>	<1
	CHS-14		M: <u>12" VFT tile</u> L: <u>Classroom C-10</u>	1-5
	CHS-15		M: <u>Acid tile - 12"</u> L: <u>Wing C Hallways</u>	<1

BULK SAMPLES

3777 Depot Rd: Suite 408 Hayward, Ca. 94545 (415) 887-8828 Page 3 of 3

Client Number		Report Number		HAZARD MANAGEMENT SERVICES, INC.		CHICO UNIFIED SCHOOL DIST.	
Received By		Date Rec'd		Bill To:		District or Business	
				P.O. Box 7012, Modesto, Ca 95355		School CHICO HIGH	
				Billing Address:		OR Bldg	
Reported Results		Date/Time/By		Collected by:		Sent to Lab by:	
				JES		JES	
				3/28/88		4/1/88	
				LAB Request: % Asbestos By PLM			

FASI Lab#	Sample #HMS-	I - 1 page No	MATERIALS/LOCATION	% Asbestos
	CHS-16		M: Blue (used behind chalkboards) L: Room B-8 Wall	<1
	CHS-17		M: 2x4 Mil Panel L: Theater - 2, 12, 13, 14 Library Bldg	<1
	CHS-18		M: Linoleum L: Staircase for Bldg L	<1
	CHS-19		M: Mural paint L: Library office, Rm L3	5-10
	CHS-20A		M: Drywall L: Library walls	<1
	CHS-20B		M: Drywall L: Bldg Library walls	<1
	CHS-20C		M: Drywall L: Bldg Library walls	<1
	CHS-21		M: Sheet shield paper L: Heat exchanger unit, wing 5-3, Sewer Bldg	75-80
	CHS-22		M: 2x4 Cell Panel L: 5-3 2x4 panel cell	<1
	CHS-23		M: Mural paint L: 5-3 attic wall	5-10

Client Number Report Number
 Received By Date Rec'd
 Billing Address: HAZARD MANAGEMENT SERVICES, INC
Bill To:
P.O. Box 7012, Modesto, Ca 95355
School CHICO H.S.
 OR
 Bldg

Reported Results Date/Time/By
 Collected by: JES Date 3/28/88
 Sent to Lab by: JES date 4/1/88

LAB Request: % Asbestos By PLM

FAI Lab#	Sample #HMS-	I page No	MATERIALS/LOCATION	% Asbestos
	CHS-24		M: 9" VFT L: <u>Sawdust Bldg - S-4</u>	1-5
	CHS-25		M: <u>Blank Sawdust</u> L: <u>S-4 Bldg - Sawdust</u>	<1
	CHS-26		M: <u>Paint</u> L: <u>S-5 Storage Room</u>	65-70
	CHS-27		M: <u>12" oil lib - Acoustic</u> L: <u>Horn Economics H-1</u>	<1
	CHS-28		M: <u>9" VFT - green</u> L: <u>Horn Economics - H-1</u>	<1
	CHS-29		M: <u>Sawdust + fuel</u> L: <u>H-1 - Horn Ec</u>	<1
	CHS-30		M: <u>9" VFT - red</u> L: <u>H-2 - Horn Ec</u>	<1
	CHS-31		M: <u>RW straight</u> L: <u>Horn Ec H-1 Storage closet</u>	75-80
	CHS-32		M: <u>Mud</u> L: <u>Horn Ec H-1 Storage closet</u>	75-80
	CHS-33		M: <u>Water & Ceiling plaster</u> L: <u>H-2 Horn Ec</u>	<1

Client Number		Report Number		Received By		Date Rec'd		Reported Results		Date/Time/By	
HAZARD MANAGEMENT SERVICES, INC.						Bill To:					
P.O. Box 7012, Modesto, Ca 95355						Billing Address:					
JES						Date: 3/28/88					
JES						Collected by:					
LAB Request: % Asbestos By PLM						Sent to Lab by:					
Bldg						date					
CHICO UNIFIED SCHOOL DIST.						District or Business					
CHICO HIGH						School OR					
Sample #HMS-		I-1 page No		MATERIALS/LOCATION				% Asbestos			
CHS-31		N: Dave Linton L: Heated Room - Home Co Wing				25-35					
CHS-35		N: Pul string L: Home Co wing Heater Room				5-10					
CHS-36		N: Painted pipe L: Home Co wing Heater Room				<1					
CHS-37		N: Boiler insulation / pipe L: Home Co. Heater Room				25-30					
CHS-38A		N: Canceled on schedule L: Music wing ball netting				1-5					
CHS-38B		N: L:				1-5					
CHS-38C		N: L:				1-5					
CHS-39		N: yellow VFT - 9" L: music wing rail				5-10					
CHS-40		N: Linoleum L: Music wing hall window sill				<1					
CHS-41		N: Turquoise tile - segment L: Musical Supply Room - Music wing				15-20					
								Band Practice room (5)			

BULK SAMPLES

3777 Depot Rd: Suite 408 Hayward, Ca. 94545 (415) 887-8828 Page 6 of

Client Number		Report Number		HAZARD MANAGEMENT SERVICES, INC.		CHICO UNIFIED SCHOOL DIST.	
Received By		Date Rec'd		Bill To:		District or Business	
Reported Results		Date/Time/By		P.O. Box 7012, Modesto, Ca 95355		School CHICO HIGH	
Sample #HMS-		I - 1 page No		Billing Address:		OR	
FAS Lab#				JES		Bldg	
				Collected by:		JES	
				Date		4/1/88	
				LAB Request: % Asbestos By PLM		Sent to Lab by:	
						date	


FAS Lab#	Sample #HMS-	I - 1 page No	MATERIALS/LOCATION	% Asbestos
	CHS-38D		N: Trunked on Plaster L: Instrument Storage Room - Musicking	1-5
	CHS-42		N: Wall Plaster L: Instrument Storage Room - Musicking	<1
	CHS-43		N: Yellow Linoleum L: Instrument Room - Musicking	<1
	CHS-44		N: Acoustic wall tile L: Instrument Room - Musicking wall	<1
	CHS-45		N: Pul straight L: Auto shop of school - Auto shop	35-40
	CHS-46A		N: Wall & floor - east wall L: Classroom #2	1-5
	CHS-46B		N: West wall L: West wall	1-5
	CHS-46C		N: West wall L: West wall	1-5
	CHS-47		N: Pul straight L: 402 Classroom, Women's RR	<1
	CHS-48		N: Transit Panels L: 401 High Booths - Bus Wash in Shop	15-20

HAZARD MANAGEMENT SERVICES, INC.		CHICO UNIFIED SCHOOL DIST.	
Client Number	Report Number	District or Business	
Received By	Date Rec'd	School	date
Reported Results		Bldg	
Date/Time/By		Sent to Lab by:	
Sample #HMS-		LAB Request: % Asbestos By PLM	% Asbestos
FAI Lab #	I - 1 page No	MATERIALS/LOCATION	
		M: 2x4 nail panel L: Gym - broken broken beam	<1
		M: PU Stracraft L: broken broken beam - Gym Attic - No asbestos	50-55
		M: broken wrap L: Gym boiler room	1-5
		M: broken corner - mudd L: Gym boiler room	5-10
		M: broken insulation - inside metal panels L: Gym boiler room	<1
		M: broken ambient L: Gym boiler room	85-90
		M: VFT - Gray 9" L: Kitchen / MBR Floor	1-5
		M: Wall & Ceiling tile L: Staff dining room - Senior hall	<1
		M: Ceiling suspended on plaster L: Women's RR - Senior hall	1-5
		M: F-O-P wiring (Traveled One Plaster) L: Men's RR - Senior hall	1-5


Client Number	Report Number	Date Rec'd	Received By
HAZARD MANAGEMENT SERVICES, INC.	Bill To:	P.O. Box 7012, Modesto, Ca 95355	Billing Address:
District or Business	School	CHICO HIGH	OR Bldg
Sent to Lab by:	JES	4/1/89	date
Collected by:	Date	3/28/88	J.E. SHARP
LAB Request: % Asbestos By PLM	MATERIALS/LOCATION	% Asbestos	
N: T-O-P Ceiling	L: Extruded Styrofoam lining rm.	TRACE	
N: T-O-P Ceiling	L: Middle of Cafeteria	1-5	
N: FOP Ceiling	L: Ceil near stairs of Cafeteria	1-5	
N: 9" VFT white - 900 sq ft	L: STAIRS OF LINCOLN Hall	1-5	
N: 2x4 ceiling panels	L: RM F1 - Jan Peters (Pet room)	<1	
N: Pipe wrap on pipes (etc)	L: RM F1 - Air Con air exchanger Fan Room Bldg	5-10	
N: 9" VFT - Base	L: RM F1 - Pet room - Jan Peters Bldg	TRACE	
N: Kils Brick lining	L: Autowash Room E2 - Jan Peters	<1	
N:	L:		
N:	L:		
N:	L:		




Crawl space next to boiler room
in gym




Chico High School
Inspected 3/28/88




Red transtite panels. Transite
panels also above doors and stair
wells



All shop pipewrap



Crawl space/light well next to
boiler room in gym




Looking into crawl space from
storeroom in boys gym

3/6-
DOM



Crawl space next to boiler
room in gym




CHS-21
Bldg. S
Rm 3



Crawl space next to boiler room
in gym



CHS-35
Bldg H
Boiler room




CHS-38 A,B,C
Trowled on plaster



CHS-38 D
Music entrance
Wire showing/metal lath



CHS-52
Gym boiler room



CHS-62
Kiln brick lining

NO
ASBESTOS