

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

Alan Otto

Alan Otto

SCHOOL Chico Senior High School

INSPECTOR Dennis Deveaux

Dennis Deveaux

BLDG. HOMOG. ASBESTOS MATERIAL

LOCATION CONDITION: CODE & COMMENTS

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	Mud Joint	5-10%	Darkroom - Attic	1
A	Mesh Wrap	15-20%	Darkroom - Attic	1
A	Transite Panels	Assumed	Red painted panels along walkways, janitor closets, r/r, stairwells	1
B	Beige 12" VFT	1-5%	All rooms	1
C	Beige 12" VFT	1-5%	Room 10	1
C	Beige 12" VFT	1-5%	All Rooms	1

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 & OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

Alan Otto
ALAN OTTO

SCHOOL Chico Senior High School

INSPECTOR Dennis DeVeaux

Dennis DeVeaux

BLDG. **HOMOG.** **ASBESTOS**
MAT. **MATERIAL**

LOCATION

CONDITION: CODE & COMMENTS

Bldg.	Homog. Mat.	Asbestos Material	Location	Condition: Code & Comments
400	Mud Joint	5-10%	Library Attic	1
500	Mud Joint	5-10%	Room F-1	1
500	Transite Panel	Assumed	2 - Kilns	1
500	Mud Joints	5-10%	Fine Arts	1

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 & OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

Alan Otto
Alan Otto

SCHOOL Chico Senior High School

INSPECTOR Dennis DeVeaux

Dennis DeVeaux

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
S	Heat Shield Paper	75-80%	Rm S-3	2
S	Black Counters	Assumed	Science Rooms	1
S	Mud Joints	5-10%	All Rooms	1
S	Belge 9" VFT	1-5%	All Rooms	1
S	PW Str	65-70%	Rm S-5 Storeroom	2

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 * OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

Alan Otto
Alan Otto

SCHOOL Chico Senior High School

INSPECTOR Dennis DeVeaux

Dennis DeVeaux
Dennis DeVeaux

BLDG. HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
H 700	Bir. Ins.	25-35%	Home Ec Boiler Room	2
700	T-O-C	1-5%	Music Wing Hall Ceiling	7
700	T-O-C	1-5%	Instrument Storage Room	1
700	Yellow 9" VFT	5-10%	Music Wing Hall	7
700	Transite Peg Board	15-20%	Custodial & Band Room	1
700	Holding Tank	Assumed	Home Ec Heater Room	2
700	PW Str	75-80%	Home Ec Storage Closet	1
700	PW Str	75-80%	2nd Home Ec storage Closet	1
700	PW CNR	75-80%	Home Ec Storage Closet	1
700	Door Filler	25-35%	Home Ec Heater Room	1
700	PW str	5-10%	Home Ec Heater Room	2

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 + OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

Alan Otto

SCHOOL Chico Senior High School

INSPECTOR Alan Otto

Alan Otto

BLDG. HOMOG. ASBESTOS
MAT. MATERIAL

LOCATION CONDITION: CODE & COMMENTS

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
700	Transite Pipe	Assumed	Home Ec Heater Room	1
700	PW Aircell	Assumed	Under Choral Room Risers	2
700	PW Debris	Assumed	Under Choral Room Risers	1

CONDITION CODES

- (1) GOOD
- (2) DAMAGED
- (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 + OR MORE)
- (4) NO [IF YES, EXPLAIN UNDER COMMENTS]
- (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
- (6) REPAIRED
- (7) REMOVED
- (8) ENCAPSULATED
- (9) ENCLOSED
- (10) ISOLATED & RESTRICTED

ABATED:

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90 *Alan Otto*

SCHOOL Chico Senior High School

INSPECTOR Dennis DeVeaux
Dennis DeVeaux

BLDG. HOMOG. ASBESTOS LOCATION CONDITION: CODE & COMMENTS
 MAT. MATERIAL

1000	PW Str	35-40%	Auto Shop, Loft, Woodshop	1	
1100	Wall Plaster	1-5%	Ag Classroom 2 (space 3)	1	
1100	Transite Panel	15-20%	Ag Shop Welding Booth	2	
1100	Transite Pipe	Assumed	Ag Shop (two pipes)	1	

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 * OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

Dennis Deveau
 Dennis Deveau/Alan Otto

SCHOOL Chico Senior High School

INSPECTOR

BLDG. HOMOG. ASBESTOS MAT. MATERIAL LOCATION CONDITION: CODE & COMMENTS

900	PW Str	50-55%	Girls/Boys Locker Room	1	
900	PW Str	50-55%	Girls/Boys Boiler Rm Crawl Sp	3	
900	Tank Wrap	1-5%	Gym Boiler Room	2	
900	Mud Joint	5-10%	Gym Boiler Room	2	
900	Boiler Room Gasket	85-90%	Gym Boiler Room	1	
900	Wall & Ceiling Plaster	1-5%	ALL Rooms except Boiler Room	1	

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 % OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT DATE 1/5/90 Alan Otto

SCHOOL Chico Senior High School INSPECTOR Dennis DeVeaux

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
800	Grey 9" VFT	1-5%	Kitchen	1
800	T-O-C	1-5%	ALL Rooms	2
800	Transite Panel	Assumed	Snack Bar	1
800	Transite Panel	Assumed	Stage & Cafe	1
800	Mud Joints	5-10%	Under Stage	1

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 % OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED