



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B027538
Date Received: 03/07/01
Date Analyzed: 03/09/01
Date Printed: 03/09/01
First Reported: 03/09/01

Job ID / Site: Chico High School

FASI Job ID: 2921-30

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

1 10079042

Layer: Off-White Plaster

ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 03/06/2001

2 10079043

Layer: Off-White Plaster

ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 03/06/2001

3 10079044

Layer: Off-White Plaster

ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 03/06/2001

4 10079045

Layer: Off-White Plaster

ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 03/06/2001

5 10079046

Layer: Off-White Plaster

ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 03/06/2001

6 10079047

Layer: Off-White Plaster

ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 03/06/2001

MAR 29 2001



BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 2921 / Chlco Unified School District 2455 Carmichael Drive Chlco, CA 95928		PHONE: (916) 891- FAX: (916) 891-3190	DATE: 3/6/01
		Circle the Method and Turn Around Time 48 hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM: Standard / Point Count	
		Gravimetry Prep	
CONTACT: ROB PETERS		TEM: QUAL. / QUANT. / WATER	
P.O.#	JOB #	AA/Flame AA/Furnace ICP	
SITE: CHICO HIGH.		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1	3/6/01	100 WING RGSTROOM PLASTER
2	↓	100 WING RGSTROOM PLASTER
3	↓	100 WING RGSTROOM PLASTER
4	↓	300 WING RGSTROOM PLASTER
5	↓	300 WING RGSTROOM PLASTER
6	↓	300 WING RGSTROOM PLASTER
		* ALL SAMPLES ARE FROM
		PIPE CHASE.

Sampled by: ROB PETERS.		Date: 3/6/01	Time: 8:55.
Relinquished by: ROB PETERS.		Received By: [Signature]	
Date/Time: 3/6/01 8:55 AM.		Date/Time: 3/7/01 10:30	
		Sealed Condition (circle one) YES / NO	
Relinquished by:		Received By:	
Date/Time:		Date/Time:	
		Sealed Condition (circle one) YES / NO	

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3095
Fax: (530) 891-3190

Chico Unified School District

March 6, 2001

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Plaster Samples – 100 & 300 Wing Restrooms
Chico Senior High School

To Whom It May Concern:

Please test the enclosed plaster samples from Chico Senior High for asbestos. We would like a 48-hour turnaround on the samples. Please fax the results to me as soon as they are available. My fax number is (530) 891-3190.

Site Sampled: Chico Senior High
Location: 100 Wing Restroom Plaster
Date Sampled: March 6, 2001
Number of Samples: Three (#1, #2, #3)

Location: 300 Wing Restroom Plaster
Date Sampled: March 6, 2001
Number of Samples: Three (#4, #5, #6)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures

Where **STUDENTS** are the **FIRST** priority



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B034036
Date Received: 10/26/01
Date Analyzed: 10/30/01
Date Printed: 10/30/01
First Reported: 10/30/01

Job ID / Site: Chico High School - Gym

FASI Job ID: 2921-30

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

1-3A 10123496

Layer: Off-White Plaster
Layer: Paint

ND
ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

2-3A 10123497

Layer: Off-White Plaster
Layer: Paint

ND
ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

3-3A 10123498

Layer: Off-White Plaster
Layer: Paint

ND
ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

1-WR 10123499

Layer: Beige Plaster
Layer: Paint

ND
ND


Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

2-WR 10123500

Layer: Off-White Plaster
Layer: Beige Plaster
Layer: Paint

ND
ND
ND

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001





Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B034036
Date Received: 10/26/01
Date Analyzed: 10/30/01
Date Printed: 10/30/01
First Reported: 10/30/01

Job ID / Site: Chico High School - Gym

FASI Job ID: 2921-30

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
3-WR	10123501						
Layer: Off-White Plaster			ND				
Layer: Beige Plaster			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components:		Asbestos:(ND)	Cellulose (Trace%)	Fibrous Glass (ND)			
Comment:Collected on 10/24/2001							
4-WR	10123502						
Layer: Off-White Plaster			ND				
Layer: Beige Plaster			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components:		Asbestos:(ND)	Cellulose (Trace%)	Fibrous Glass (ND)			
Comment:Collected on 10/24/2001							
1-2A	10123503						
Layer: Off-White Plaster			ND				
Layer: Beige Plaster			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components:		Asbestos:(ND)	Cellulose (Trace%)	Fibrous Glass (ND)			
Comment:Collected on 10/24/2001							
2-2A	10123504						
Layer: Off-White Plaster			ND				
Layer: Beige Plaster			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components:		Asbestos:(ND)	Cellulose (Trace%)	Fibrous Glass (ND)			
Comment:Collected on 10/24/2001							
3-2A	10123505						
Layer: Off-White Plaster			ND				
Layer: Beige Plaster			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components:		Asbestos:(ND)	Cellulose (Trace%)	Fibrous Glass (ND)			
Comment:Collected on 10/24/2001							



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B034036
Date Received: 10/26/01
Date Analyzed: 10/30/01
Date Printed: 10/30/01
First Reported: 10/30/01

Job ID / Site: Chico High School - Gym

FASI Job ID: 2921-30

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

1-TO 10123506

Layer: Grey Cementitious Material

ND

Layer: Paint

ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

2-TO 10123507

Layer: Grey Cementitious Material

ND

Layer: Paint

ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

3-TO 10123508

Layer: Grey Cementitious Material

ND

Layer: Paint

ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

1-2A 10123509

Layer: Off-White Plaster

ND

Layer: Beige Plaster

ND

Layer: Paint

ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001

2-2A 10123510

Layer: Off-White Plaster

ND

Layer: Beige Plaster

ND

Layer: Paint

ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment:Collected on 10/24/2001



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B034036
Date Received: 10/26/01
Date Analyzed: 10/30/01
Date Printed: 10/30/01
First Reported: 10/30/01

Job ID / Site: Chico High School - Gym

FASI Job ID: 2921-30

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

3-2A 10123511

Layer: Off-White Plaster
Layer: Beige Plaster
Layer: Paint

ND
ND
ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 10/24/2001

1-MR 10123512

Layer: White Plaster
Layer: Paint

ND
ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 10/24/2001

2-MR 10123513

Layer: White Plaster
Layer: Paint

ND
ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 10/24/2001

3-MR 10123514

Layer: White Plaster
Layer: Paint

ND
ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 10/24/2001

TER-1 10123906

Layer: Off-White Plaster
Layer: Beige Plaster
Layer: Paint

ND
ND
ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)** Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 10/24/2001



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones2455 Carmichael Drive
Chico, CA 95928Client ID: 2921
Report Number: B034036
Date Received: 10/26/01
Date Analyzed: 10/30/01
Date Printed: 10/30/01
First Reported: 10/30/01

Job ID / Site: Chico High School - Gym

FASI Job ID: 2921-30

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
TER-2	10123907						
Layer: Off-White Plaster			ND				
Layer: Beige Plaster			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (Trace%) Fibrous Glass (ND) Comment:Collected on 10/24/2001							
TER-3	10123908						
Layer: Off-White Drywall			ND				
Layer: Paint			ND				
Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (20%) Fibrous Glass (10%) Comment:Collected on 10/24/2001							

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, without the approval of Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

IT NAME & ADDRESS:

2921 Chlco Unified School District
2455 Carmichael Drive
Chlco, CA 95928

PHONE: (916) 891-
FAX: (916) 891-3190

DATE: 10/25/01

Circle the Method and
Turn Around Time

Results Needed:

hr/12hr/24hr/48hr/Ext

PLM: Standard / Point Count

Gravimetry Prep

CONTACT: ROB PETERS.

TEM: QUAL. / QUANT. / WATER

P.O.#

JOB #

AA/Flame AA/Furnace ICP

SITE: CHICO HIGH GYM.

METALS:

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1-3A	10/24	STORAGE RM 3A WALL PLASTER
2-3A	10/24	STORAGE RM 3A WALL PLASTER
3-3A	10/24	STORAGE RM 3A WALL PLASTER
1-WR	10/24	WEIGHT RM WALL PLASTER
2-WR	10/24	" " WALL PLASTER
3-WR	10/24	" " WALL PLASTER
4-WR	10/24	" " WALL PLASTER
1-2A	10/24	OFFICE 2A WALL PLASTER
2-2A	10/24	OFFICE 2A WALL PLASTER
3-2A	10/24	OFFICE 2A WALL PLASTER

Sampled by: ROB PETERS.

Date: 10/25/01 Time: 11:25 AM

Relinquished by:

Received By:

Date/Time:

Date/Time: 10/26/01
Sealed Condition (circle one) YES / NO

Inquished by:

Received By:

Date/Time:


Date/Time:
Sealed Condition (circle one) YES / NO



BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928		PHONE: (916) 891- FAX: (916) 891-3190	DATE: 10/25/01
		Circle the Method and Turn Around Time	Results Needed:
		____ hr/12hr/24hr/48hr/Ext	
		PLM. Standard / Point Count	Gravimetry Prep
CONTACT: ROB PETERS		TEM: QUAL. / QUANT. / WATER	
P.O.#	JOB #	AA/Flame AA/Furnace ICP	
SITE: CHICO HIGH GYM		METALS:	


SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1-TO	10/25	TICKET OFFICE STUCCO
2-TO	10/25	TICKET OFFICE STUCCO
3-TO	10/25	TICKET OFFICE STUCCO
1-2A	10-24	STORAGE RM 2A Wall Plaster
2-2A	10-24	" " " "
3-2A	10-24	" " " "
1-MR	10-24	MENS REST RM. Wall Plaster
2-MR	10-24	" " " "
3-MR	10-24	" " " "

Sampled by: ROB PETERS	Date: 10/25/01 Time: 11:25 AM
Relinquished by:	Received By: 
Date/Time:	Date/Time: Sealed Condition (circle one) YES NO
Inquished by:	Received By:
Date/Time:	Date/Time: Sealed Condition (circle one) YES / NO

BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS:  2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928		PHONE: (916) 891- 1 FAX: (916) 891-3190	DATE: 10/25/01
		Circle the Method and Turn Around Time _____ hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM: <u>Standard</u> / Point Count	
		CONTACT: ROB PETERS	
P.O.#	JOB #	AA/Flame AA/Furnace ICP	
SITE: <u>Chico Senior HS</u>		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1-TER	10/24	TEAM EQUIPMENT RM. WALL PLASTER
2-TER	10/24	TEAM EQUIPMENT RM. WALL PLASTER
3-TER	10/24	TEAM EQUIPMENT RM. DRY WALL
		PLEASE PICK ONE SAMPLE
		FROM EACH LOT TO TEST FOR
		(LEAD)

Sampled by: ROB PETERS		Date: 10/25/01 Time: 11:30	
Relinquished by:		Received By: 	
Date/Time:		Date/Time:	
Inquished by:		Received By:	
Date/Time:		Date/Time:	
		Sealed Condition (circle one) YES / NO	
		Sealed Condition (circle one) YES / NO	

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

March 6, 2001

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Plaster, Stucco & Dry Wall Samples – Gymnasium
Chico Senior High School

To Whom It May Concern:

Please test the enclosed plaster samples from the Chico Senior High School Gymnasium for asbestos.. In addition, please pick one sample from each lot to test for lead. We would like a 24-hour turnaround on the samples. Please fax the results to me as soon as soon as they are available. My fax number is (530) 891-3190.

Site Sampled: Chico Senior High Gymnasium
Location: Storage Room 3A Wall Plaster
Date Sampled: October 24, 2001
Number of Samples: Three (#1-3A, #2-3A, #3-3A)

Location: Weight Room Wall Plaster
Date Sampled: October 24, 2001
Number of Samples: Four (#1-WR, #2-WR, #3-WR, #4-WR)

Location: Office 2A Wall Plaster
Date Sampled: October 24, 2001
Number of Samples: Three (#1-2A, #2-2A, #3-2A)

Location: Ticket Office Stucco
Date Sampled: October 25, 2001
Number of Samples: Three (#1-TO, #2-TO, #3-TO)

Location: Storage Room 2A Wall Plaster
Date Sampled: October 24, 2001
Number of Samples: Three (#1-2A, #2-2A, #3-2A)

Forensic Analytical
Chico High Samples
October 25, 2001
Page 2

Location: Men's Restroom Wall Plaster
Date Sampled: October 24, 2001
Number of Samples: Three (#1-MR, #2-MR, #3-MR)

Location: Team Equipment Room Wall Plaster
Date Sampled: October 24, 2001
Number of Samples: Three (#1-TER, #2-TER, #3-TER)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures

AZEVEDO CONSTRUCTION
P O Box 688
Forest Ranch, CA 95942
1-530-894-2360
Fax 1-530-894-0699
Lic. # 614121

Date: 9/10/01

RE: Site Work for the New Relocatable Classrooms at the Chico Senior & Pleasant Valley High School

To Chico Unified School District

There was no materials with asbestos used for the project listed above.

Sincerely,

A handwritten signature in black ink, appearing to read "Kim Azevedo". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

Azevedo Construction

2921-41

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

March 6, 2001

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Gymnasium Upper Roof Samples
Chico Senior High School

To Whom It May Concern:

Please test the enclosed upper roof samples from the Chico Senior High School Gymnasium for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Chico Senior High Gymnasium
Location: Upper Roof
Date Sampled: May 29, 2002
Number of Samples: Five (5)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures

SIX MONTH SURVEILLANCE HOMOGENEOUS ASBM RECORDS

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	FT ² /L.F.	Location	Condition: Code & Comments	Frable Yes/No
M	2' X 4' FCP	1	NONE DETECTED	5,735 S	ADMINISTRATION AREA	(13) SAMPLE HMS-CHS-01 COLLECTED ON 3-28-88.	N/A
M	12" VFT BEIGE	2	TRACE	5,700 S	RECEPTION AREA	(1) (4)	N
M	12" ACT	3	NONE DETECTED	3,550 S	PRINCIPLES OFFICE, COMPTROLLER, DW, & ROOMS 102-107	(13) SAMPLE HMS-CHS-03 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	7	5-10%	20 JOINTS	DARK ROOM ATTIC (ROOM 111)	(1) (4)	N
T	MESH WRAP	8	12-20%	1/2 L	DARK ROOM ATTIC (ROOM 111)	(11) INACCESSIBLE.	N
M	TRANSITE PANELS	95	ASSUMED	1,300 S	ALONG WALKWAYS, JANITORS CLOSETS, RESTROOMS, & STAIRWELLS	(1) (5) PANELS PAINTED WHITE.	N

CONDITION CODE

General Condition:

Change in Condition:

Abated:

Miscellaneous:

- (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 (4) No (5) Yes (If Yes, explain under comments)
 (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 (11) Inaccessible; no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH SURVEILLANCE HOMOGENEOUS ACBM RECORDS

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: A (Unit 200) Upstairs

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT BEIGE	2	TRACE	5,800 S	UPSTAIRS CLASSROOMS	(1) (4)	N
M	2' X 4' FCP	6	NONE DETECTED	10,000 S	UPSTAIRS CLASSROOMS	(13) SAMPLE HMS-CHS-06 COLLECTED ON 3-28-88.	N/A

School: Chico Senior High School

Building: B (Unit 100)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	13	NONE DETECTED	10,000 S	ALL CLASSROOMS	(13) SAMPLE HMS-CHS-13 COLLECTED ON 3-28-88.	N/A
M	12" VFT	14	1-5%	9,430 S	ALL CLASSROOMS	(1) (4)	N
M	TRANSITE PANELS	95	ASSUMED	1,300 S	ALONG WALKWAYS, JANITORS CLOSETS, RESTROOMS, & STAIRWAYS	(1) (5) PANELS PAINTED WHITE.	N

CONDITION CODE

General Condition:
Change in Condition:
Abated:
Miscellaneous:

(1) Good (2) Damaged (3) Significantly Damaged (25% or more)
(4) No (5) Yes (If Yes, explain under comments)
(6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
(11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH SURVEILLANCE HOMOGENEOUS ACM RECORDS

District: Chico Unified School District

Inspector: Robert Peters

Date of Inspection: 12/27/2001

School: Chico Senior High School

Building: C (Unit 300)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Frangible Yes/No
M	12" VFT	14	1-5%	9,513 S	ALL CLASSROOMS	(1) (4)	N
M	TRANSITE PANELS	95	ASSUMED	1,300 S	EXTERIOR OF BUILDING	(1) (5) PANELS PAINTED WHITE.	N

CONDITION CODE

General Condition:

Change in Condition:

Abated:

Miscellaneous:

- (1) Good
- (2) Damaged
- (3) Significantly Damaged (25% or more)
- (4) No
- (5) Yes (If Yes, explain under comments)
- (6) Repaired
- (7) Removed
- (8) Encapsulated
- (9) Enclosed
- (10) Isolated & Restricted
- (11) Inaccessible, no inspection data
- (12) Other (Explain under comments)
- (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: D & H (Unit 700 Music & Home EC)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Frable Yes/No
T	BOILER INSULATION	37	25-35%	48 S	HOME EC & BOILER ROOM	(1) (6) REPAIRED.	N
S	TROWELED ON CEILING	38	1-5%	300 S	INSTRUMENT STORAGE ROOM & BAND ROOM OFFICE	(1) (4)	N
M	9" VFT YELLOW	39	5-10%	1,410 S	MUSIC WING HALL, CHORAL ROOM UNDER RISERS, BAND ROOM OFFICE, & CHORAL ROOM STORAGE	(7) (1) (4) REPLACED WITH 12" VFT GREY. 9" VFT UNDER CARPET IN BAND ROOM OFFICE.	N/A N
M	TRANSITE PEG BOARD	41	15-20%	1,000 S	BAND PRACTICE ROOM & CUSTODIAL ROOM	(2) 12/27/01 (2) (4) PIECES BROKEN & MISSING.	N
T	PIPEWRAP STRAIGHT	80	75-80%	58 L	HOME EC STORAGE CLOSET	(1) (4)	N
T	PIPEWRAP STRAIGHT	81	75-80%	120 L	2 ND HOME EC STORAGE CLOSET	(1) (4)	N
T	PIPEWRAP CORNER	82	75-80%	>1 EACH	HOME EC STORAGE CLOSET	(1) (4)	N
M	FIRE DOOR	83	25-35%	1 EACH	HOME EC HEATER ROOM	(1) (4)	N
M	HOLDING TANK	94	ASSUMED	72 S	HOME EC HEATER ROOM	(1) (4)	N
M	12" VFT GREY	100	ASSUMED	810 S	MUSIC WING HALL	(1)	N

CONDITION CODE

General Condition:

Change in Condition:

Abated:

Miscellaneous:

- (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 (4) No (5) Yes (If Yes, explain under comments)
 (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: 700 (Music)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPEWRAP STRAIGHT	84	5-10%	58 L	HOME EC HEATER ROOM	(1) (4)	N
T	PIPEWRAP AIRCELL	97	ASSUMED	70 L	UNDER CHORAL RISERS	(10)	N
M	TRANSITE PIPE	98	ASSUMED	8 L	HOME EC HEATER ROOM	(1) (4)	N

School: Chico Senior High School

Building: L (Unit 400 Library)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	14	1-5%	1,000 S	LIBRARY ENTRY & OFFICE AREA	(1) (4)	N
M	2' X 4' FCP	17	NONE DETECTED	11,155 S	ALL ROOMS	(13) SAMPLE HMS-CHS-17 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	19	5-10%	20 JOINTS	LIBRARY ATTIC	(1) (6) REPAIRED 1/27/01 (1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH SURVEILLANCE HOMOGENEOUS ACM RECORDS

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: F (Unit 500)

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	MUD JOINTS	52	5-10%	125 JOINTS	FINE ARTS	(1) (4)	N
M	2' X 4' FCP	59	NONE DETECTED	4,500 S	ALL CLASSROOMS	(13) SAMPLE HMS-CHS-59 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	60	5-10%	12 L	ROOM F-1	(1) (4)	N
M	9" VFT	61	TRACE	4,500 S	ALL CLASSROOMS	(1) (4)	N
M	TRANSITE PANELS	95	ASSUMED	150 S	2 KILNS	(1) (4)	N

CONDITION CODE

General Condition:

Change in Condition:

Abated:

Miscellaneous:

- (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 (4) No (5) Yes (If Yes, explain under comments)
 (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: S (Unit 600 Science)

Material Class	Material	Homo. Mat. #	% Asb.	FT ² /L.F.	Location	Condition: Code & Comments	Frable Yes/No
M	2' X 4' FCP	22	NONE DETECTED	8,000 S	ALL ROOMS	(13) SAMPLE HMS-CHS-22 COLLECTED ON 3-28-88.	N/A
T	MUD JOINTS	23	5-10%	40 JOINTS	ALL ROOMS	(1) (4)	N
M	9" VFT	24	1-5%	8,100 S	ALL ROOMS	(1) (4)	N
T	PIPE WRAP STRAIGHT	26	65-70%	12 L	ROOM 5 (STORE ROOM)	(1) (6)	N
M	BLACK COUNTER TOPS	99	ASSUMED	UNDETERMINED	IN ALL SCIENCE ROOMS	(1) (4)	N

CONDITION CODE

General Condition:
Change in Condition:
Abated:
Miscellaneous:

(1) Good (2) Damaged (3) Significantly Damaged (25% or more)
(4) No (5) Yes (If Yes, explain under comments)
(6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
(11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH SURVEILLANCE HOMOGENEOUS ACBM RECORDS

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: LH-800

Material Class	Material	Homo. Mat. #	% Asb.	FF ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPEWRAP STRAIGHT	45	35-40%	3 L	CUSTODIAL ROOM	(1) (4)	N
T	MUD JOINTS	52	5-10%	10 EACH	UNDER STAGE	(1) (4)	N
M	9" VFT GREY	55	1-5%	6,800 S	KITCHEN & MPR	(1) (6) REPAIRED.	N
S	TROWELED ON CEILING	57	1-5%	900 S	ALL ROOMS	(1) (6) PAINTED.	N
M	TRANSITE PANELS	95	ASSUMED	364 S	SNACK BAR, STAGE, & CAFE	(1) (4)	N
M	9" VFT	101	ASSUMED	250 S	UNDER STAGE	(1) (4)	N
T	MUD JOINTS	102	5-10%	10 EACH	TEACHER'S LOUNGE RESTROOMS	(1) (4)	N
M	TRANSITE PIPE	103	ASSUMED	12 L	WATER HEATER ROOM (2 PIPES)	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

SIX MONTH SURVEILLANCE HOMOGENEOUS ACBM RECORDS

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: 900 GYM

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALLS & CEILING PLASTER	46	NONE DETECTED	2,000 S	ALL ROOMS EXCEPT BOILER	(13) SAMPLE HMS-CHS-46A-C COLLECTED ON 3-28-88. ADDITIONAL SAMPLES HMS-93103-03A-C COLLECTED ON 7-8-93.	N/A
T	PIPEWRAP STRAIGHT	50	50-55%	2,700 S	GIRL'S & BOY'S LOCKER ROOM & BOILER ROOM CRAWL SPACE	(10) ISOLATED & RESTRICTED	N

CONDITION CODE

General Condition:

Change in Condition:

Abated:

Miscellaneous:

- (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 (4) No (5) Yes (If Yes, explain under comments)
 (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: IT-1000

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
T	PIPEWRAP STRAIGHT	45	35-40%	700 L	AUTO SHOP, LOFT, & WOOD SHOP	(1) (4)	N
T	BREECHING	90	ASSUMED	100 S	WOOD FINISHING ROOM	(1) (4)	N

School: Chico Senior High School

Building: AG-1100

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
S	WALL PLASTER	46	1-5%	950 S	AG CLASSROOM 2 (SPACE 3)	(1) (4)	N
M	TRANSITE PANELS	48	15-20%	200 S	AG SHOP WELD BOOTHS & TABLES	(1) (4)	N
M	12" VFT	89	ASSUMED	400 S	CLASSROOM	(1) (4)	N
M	TRANSITE PIPES	96	ASSUMED	12 L	AG SHOP (2 PIPES)	(1) (4)	N

CONDITION CODE

General Condition:

Change in Condition:

Abated:

Miscellaneous:

- (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 (4) No (5) Yes (If Yes, explain under comments)
 (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2001

District: Chico Unified School District

Inspector: Robert Peters

School: Chico Senior High School

Building: 17 Portable Classrooms and 2 Portable Restrooms on West Campus

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
					17 PORTABLE CLASSROOM AND 2 PORTABLE RESTROOMS	DISTRICT CERTIFICATION REQUIRED.	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

HMS, Inc.
HAZARD MANAGEMENT SERVICES, INC.

September 28, 2001

Mr. Rob Peters
Chico Unified School District
1163 E. Seventh Street
Chico, CA 95928

RE: Fourth Triennial AHERA Three-Year Reinspection

Dear Mr. Peters:

Enclosed is the data obtained from the fourth AHERA three-year reinspections Hazard Management Services, Inc. (HMS, Inc.) conducted between May 1, 2001 and May 2, 2001. The documents included with this letter are the "Three-Year Reinspection Homogeneous ACBM Material Records" covering all buildings known from the original inspection to contain ACBM. The sites inspected were Chapman Elementary, Chico Senior High, and Citrus Elementary Schools. After Chapman and Citrus Elementary Schools were inspected, HMS, Inc. had the files for these sites stolen. The information for these two sites were recreated using the prior six month surveillance reports conducted by the District. With these reports, this completes the Three-Year Reinspections as contracted with Chico Unified School District.

You should review the updated Homogeneous Materials Reports to familiarize yourself with the current status of asbestos containing materials and identified suspect asbestos materials. It is the District's responsibility to assure that the school's site copy of the Management Plan is up to date and consistent with the District's Management Plan for that site. This is very important, and if not done, can cause the District to be penalized during an EPA site visit or investigation.

HMS, Inc. wants to remind you that materials containing "trace" amounts of asbestos must be considered in the event of renovations or demolitions. Although building materials containing trace amounts of asbestos (<1%) are not regulated under EPA, Cal/OSHA does regulate work practices with materials containing 0.1% asbestos. The original AHERA inspection contains information regarding materials with trace amounts of asbestos.

When you provide your annual notification to parents and staff, include information regarding this three-year reinspection. Enclosed is a suggested format for your notification letter. Please note that you must include in your Management Plans a description of the steps you take to notify. It is also important that your Management Plans be updated after any and all actions conducted which impact asbestos containing materials.

Please remember that HMS, Inc. did not inspect new buildings or portable classrooms which were placed on the District sites since the original EPA AHERA inspection. It is the District's responsibility to obtain letters of certification from the Architect, Construction Superintendent, or manufacturer of new building materials, indicating there is no asbestos in the new buildings (constructed after October 12, 1988) or new building materials. A copy of these certification letters must be included in your Management Plans, both at the school site and at the LEA Designees office site. It is still required of School Districts to send a copy of these certification letters to the US EPA AHERA unit; Region IX in San Francisco.

Mr. Rob Peters
Chico Unified School District
September 28, 2001
Page Two

It is not necessary to send a copy of the three-year reinspection to the OPSC or EPA. However, the report should be included in your Management Plan. I want to thank you for your cooperation. If you have any questions, please feel free to contact me at (916) 632-6800.

Sincerely,

Douglas R. Colley (Hkb)

Douglas R. Colley
Certified Asbestos Consultant
DOSH #92-0222

Enclosures

A:\FINAL.letter.wpd

Following is a suggested letter to district personnel, building occupants, and parents in order to meet the AHERA requirement of annual notification. Whatever notification you use, you put a dated, signed copy in the Management Plan. You must also include in the Management Plan a brief statement describing the steps you take to notify. Include the date(s) you did the six-month surveillances, and include any other actions you have taken with regards to asbestos or AHERA.

Date:

To: Parents, PTA, Teachers, Maintenance, Staff

From: AHERA Designee

RE: Asbestos Hazard Emergency Response Act (AHERA) Asbestos Inspections and Management Plans.

Chico Unified School District has hired Hazard Management Services, Inc. (HMS, Inc.), a consulting company, to complete the required three-year reinspection of all asbestos-containing building materials in the District. The reinspection for Chapman Elementary, Chico Senior High, and Citrus Elementary School were completed between May 1, 2001 and May 2, 2001 by an accredited inspector, and the reinspection data has been incorporated into the Management Plan.

Also, during the past year the District has performed the required six-month surveillances on _____. This information is also incorporated into the Management Plan.

A copy of the District's Management Plan is available for review during normal office hours in the office of the _____. If copies of the plan are desired, a nominal duplicating fee may be charged.

Authorized Signature

Date

**RECORD OF FRIABLE AND NONFRIABLE ACM
(FORM B)**

Inspection Date(s)
May 2, 2001

THREE-YEAR REINSPECTION

SCHOOL Chico Senior High School					CDS CODE 04-61424-0431676
ADDRESS (NUMBER) (STREET) (CITY) (ZIP) 901 The Esplanade Chico, CA 95926					SCHOOL PHONE NUMBER (530) 891-3026

-IMPORTANT-

Each building and functional space with friable ACM or friable assumed ACM listed on this form requires completion of **FORM C** (PHYSICAL AND HAZARD ASSESSMENT OF FRIABLE ACM OR FRIABLE ASSUMED ACM). Indicate location of material on blueprint, diagram or narrative in square or linear feet, and attach a copy (Sec. 763.93).

LINE	BUILDING NAME & FUNCTIONAL SPACE (Indicate Address if Different From Above)	CHECK ONE			CHECK ONE			
		SUR- FACING	TSI	MISC	ACBM		ASSUMED ACM	
					FRIABLE	NON- FRIABLE	FRIABLE	NON- FRIABLE
1.	A		X	X		X		X
2.	A (UNIT 200) UPSTAIRS			X		X		
3.	B (UNIT 100)			X		X		X
4.	C (UNIT 300)			X		X		X
5.	D & H (UNIT 700 MUSIC & HOME EC)	X	X	X		X		X
6.	700 (MUSIC)		X	X		X		X
7.	L (UNIT 400 LIBRARY)		X	X		X		
8.	F (UNIT 500)		X	X		X		X
9.	S (UNIT 600 SCIENCE)		X	X		X		X
10.	LH-800	X	X	X		X		X
11.	900 GYM		X			X		
12.	IT-1000		X			X		X
13.	AG-1100	X		X		X		X
14.	17 PORTABLE CLASSROOMS AND 2 PORTABLE RESTROOMS ON WEST CAMPUS DISTRICT MUST CERTIFY							
15.								
16.								
17.								

See attached "Homogeneous Materials Records" for all materials and their locations by building. On Form B all buildings are listed, and a summary of all non-friable and friable material is provided. Friable materials and their locations are listed separately under each building on Form B.