

Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:
Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 20918
Date Received: 01/30/89
Date Examined: 02/16/89

Lab Number: 8904120
Sample Number: DO - 200A
Site:

Analyst: JM

Location:

P.O./Job ID: Chico Unified School District/Dist. Ofc

Gross Description: Off-white tile-like material.

Comments:

Microscopic Description

| | | |
|--|------------|------------|
| TOTAL ASBESTOS PRESENT: | | Non-Det. % |
| Chrysotile | Non-Det. % | |
| Amosite | Non-Det. % | |
| Crocidolite | Non-Det. % | |
| | % | |
| TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT: | | Trace % |
| Cellulose | Trace % | |
| Fibrous Glass | Non-Det. % | |
| Polyethylene | Non-Det. % | |
| | % | |
| TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT: | | 98-99 % |
| Unspecified Particulates | 98-99 % | |
| | % | |
| | % | |
| | % | |

Supervisor: _____

David Kahane
David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)

NVLAP

Accredited by the National Bureau of Standards, National Voluntary Laboratory Accreditation Program for selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218



Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:

Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 20918
Date Received: 01/30/89
Date Examined: 02/16/89

Lab Number: 8904121
Sample Number: DO - 200B
Site:

Analyst: JM

Location:

P.O./Job ID: Chico Unified School District/Dist. Ofc

Gross Description: Off-white tile-like material.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

| | | |
|-------------|------------|------------|
| Chrysotile | Non-Det. % | Non-Det. % |
| Amosite | Non-Det. % | |
| Crocidolite | Non-Det. % | |
| | % | |

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

| | | |
|---------------|------------|---------|
| Cellulose | Trace % | Trace % |
| Fibrous Glass | Non-Det. % | |
| Polyethylene | Non-Det. % | |
| | % | |

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

| | | |
|--------------------------|---------|---------|
| Unspecified Particulates | 98-99 % | 98-99 % |
| | % | |
| | % | |
| | % | |

Supervisor: _____

David Kahane
David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)

NVLAQ

Accredited by the National Bureau of Standards, National Voluntary Laboratory Accreditation Program for selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218

Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:
Hazard Management Services, Inc.
P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 20918
Date Received: 01/30/89
Date Examined: 02/16/89

Lab Number: 8904122
Sample Number: DO - 200C
Site:

Analyst: JM

Location:

P.O./Job ID: Chico Unified School District/Dist. Ofc

Gross Description: Off-white tile-like material.

Comments:

Microscopic Description

| | | |
|---|------------|------------|
| TOTAL ASBESTOS PRESENT: | | Non-Det. % |
| Chrysotile | Non-Det. % | |
| Amosite | Non-Det. % | |
| Crocidolite | Non-Det. % | |
| | % | |
| TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT: | | Trace % |
| Cellulose | Trace % | |
| Fibrous Glass | Non-Det. % | |
| Polyethylene | Non-Det. % | |
| | % | |
| TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT: | | 98-99 % |
| Unspecified Particulates | 98-99 % | |
| | % | |
| | % | |
| | % | |

Supervisor: _____

David Kahane
David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)

NVLAQ

Accredited by the National Bureau of Standards, National Voluntary Laboratory Accreditation Program for selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218

Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:

Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 20918
Date Received: 01/30/89
Date Examined: 02/16/89

Lab Number: 8904123
Sample Number: DO - 201A
Site:

Analyst: JM

Location:

P.O./Job ID: Chico Unified School District/Dist. Ofc

Gross Description: Grey fibrous ceiling tile-like material.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

Non-Det. %
Non-Det. %
Non-Det. %
%

Non-Det. %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Fibrous Glass
Polyethylene

35-40 %
35-40 %
Non-Det. %
%

75-80 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates
Perlite

1-5 %
15-20 %
%
%

20-25 %

Supervisor: _____

David Kahane
David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)



Accredited by the National Bureau of Standards, National Voluntary Laboratories Accreditation Program for selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218



Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:

Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 20918
Date Received: 01/30/89
Date Examined: 02/16/89

Lab Number: 8904124
Sample Number: DO - 201B
Site:

Analyst: JM

Location:

P.O./Job ID: Chico Unified School District/Dist. Ofc

Gross Description: Grey fibrous ceiling tile-like material.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

| | | |
|-------------|------------|------------|
| Chrysotile | Non-Det. % | Non-Det. % |
| Amosite | Non-Det. % | |
| Crocidolite | Non-Det. % | |
| | % | |

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

| | | |
|---------------|------------|---------|
| Cellulose | 35-40 % | 75-80 % |
| Fibrous Glass | 35-40 % | |
| Polyethylene | Non-Det. % | |
| | % | |

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

| | | |
|--------------------------|---------|---------|
| Unspecified Particulates | 1-5 % | 20-25 % |
| Perlite | 15-20 % | |
| | % | |
| | % | |

Supervisor: _____

David Kahane
David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (ASHERA)

NVLAQ

Accredited by the National Bureau
of Standards, National Voluntary
Laboratory Accreditation Program for
selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218

Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:

Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 20918
Date Received: 01/30/89
Date Examined: 02/16/89

Lab Number: 8904125
Sample Number: DO - 201C
Site:

Analyst: JM

Location:

P.O./Job ID: Chico Unified School District/Dist. Ofc

Gross Description: Grey fibrous ceiling tile-like material.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

Non-Det. %
Non-Det. %
Non-Det. %
%

Non-Det. %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Fibrous Glass
Polyethylene

35-40 %
35-40 %
Non-Det. %
%

75-80 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates
Perlite

1-5 %
15-20 %
%
%

20-25 %

Supervisor: _____


David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)



Accredited by the National Bureau of Standards, National Voluntary Laboratory Accreditation Program for selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT DATE 12/18/89
 SCHOOL CHICO DISTRICT OFFICE INSPECTOR Paul B. Davis
 GRAVES

BLDG. HOMOG. ASBESTOS MAT. MATERIAL LOCATION CONDITION: CODE & COMMENTS

| | | | | |
|---|-----------|----------|----------------------|------------|
| 1 | 9" VFT | 1 - 5% | Computer Room Office | 1 - 4 |
| 1 | PW Str. | 80 - 85% | Basement Crawl Space | 2 - 4 - 10 |
| 1 | PW Jnt. | 10 - 15% | " " | 2 - 4 - 10 |
| 1 | PW Debris | 25 - 35% | " " | 2 - 4 - 10 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 & OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED