



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B038474
Date Received: 04/11/02
Date Analyzed: 04/12/02
Date Printed: 04/12/02
First Reported: 04/12/02

Job ID / Site: JOB: District Office

FASI Job ID: 2921-40


Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
LR-1	10151622	Chrysotile	65 %				

Layer: Black Felt

Total Composite Values of Fibrous Components: **Asbestos:(65%)**

Cellulose (5%)

Comment: Collected on 04/10/2002



James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

All results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on this report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Forensic Analytical

San Francisco • Los Angeles • Minneapolis / St. Paul

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3095
Fax: (530) 891-3190

Chico Unified School District

April 10, 2002

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: District Office – Large Conference Room
Chapman Elementary School – Room 6 Storage

To Whom It May Concern:

Please test the enclosed roof sample from the District Office Large Conference Room and the ceiling plaster sample from Chapman Elementary School Room 6 Storage for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.


Site Sampled: District Office
Location: Large Conference Room Roof, under the shakes
Date Sampled: April 10, 2002
Number of Samples: One (1)

Site Sampled: Chapman Elementary School
Location: Plaster Ceiling in Unit A, Room 6 Storage
Date Sampled: April 10, 2002
Number of Samples: One (1)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures

SIX MONTH SURVEILLANCE HOMOGENEOUS ACBM RECORDS

Date of Inspection: 11/06/2002

District: Chico Unified School District

Inspector: Robert Peters

School: District Office

Building: District Office

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT	6	1-5%	100 S	COMPUTER ROOM OFFICE	(7) REPLACED WITH CARPET. (5) REMOVED CARPET	N/A
T	PIPE WRAP STRAIGHT	7	80-85%	350 L	BASEMENT CRAWL SPACE	(10) COULD NOT ACCESS.	N
T	PIPE WRAP JOINT	7	10-15%	350 L	BASEMENT CRAWL SPACE	(10) COULD NOT ACCESS	N
T	PIPE WRAP DEBRIS	7	25-35%	25 S	BASEMENT CRAWL SPACE	(10) COULD NOT ACCESS.	Y

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: District Office

Building: District Office

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	9" VFT	6	1-5%	100 S	COMPUTER ROOM OFFICE	(7) REPLACED WITH CARPET.	N/A
T	PIPE WRAP STRAIGHT	7	80-85%	350 L	BASEMENT CRAWL SPACE	(10) COULD NOT ACCESS.	N
T	PIPE WRAP JOINT	7	10-15%	350 L	BASEMENT CRAWL SPACE	(10) COULD NOT ACCESS	N
T	PIPE WRAP DEBRIS	7	25-35%	25 S	BASEMENT CRAWL SPACE	(10) COULD NOT ACCESS.	Y

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS