

**ENTEK CONSULTING GROUP, INC.
ASSESSMENT OF TSI and/or FRIABLE MATERIAL**

District: Chico Unified School District

Date: July 8, 2010

School: District Office

Inspector: Jack DeLay

Building & Location(s): Basement Crawl Space (Functional Area)

Sample#: HMS-DO-07C

% Asbestos- 25-35%

Homogeneous Mat. #7

Material description: Pipe Wrap Debris

Total amount of material this location: 25 S

Amount of friable material this location: 25 S

Damage	Local		Distributed	X	Damaged	98 -99%
Type of Damage	Air Erosion	X	Water	X	Flaking	X
	Deterioration	X	Physical	X	Delamination	

Probable cause(s) of damage: Unknown

POTENTIAL FOR DISTURBANCE			RESPONSE ACTIONS		PREVENTIVE MEASURES		
	H	M	L				
				Isolate/Restrict		Fix leaks	X
Accessibility	X			Repair/Cleanup	X	Prevent water contact	X
Vibration			X	Enclose		Do not drill, cut, sand, or grind	X
Air Erosion		X		Remove	X	Do not affix signs	X
Water		X		Encapsulate		Avoid contact	X
Occupancy			X	O & M			

Assessment of Material Condition

Significantly Damaged
(Poor)

Damaged
(Fair)

Not damaged
(Good)

Potential
Damage:

High

High

Mod

Low

High

Mod

Low

Hazard
Ranking:

1

2

3

4

5

6

7

--	--	--	--	--	--	--	--	--

Comments & Observations:

Was instructed by Leroy Christopher not go into the basement crawl space. Possibly removed and could not locate.