

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE Dec. 4, 1990

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters R.P.

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	All Rooms	1-4
A	AC Plas	1-5	Classrooms	1-4 (rm 7&9 slight wall damage - old)
A	AC Plas	1-5	Staff Room	1-4
A	L mud jnt	Assumed	Boiler room	1-4 Over
A	S mud jnt	Assumed	Boiler room	1-4
B	9" VFT	1-5	All Rooms	1-4
B	AC Plas	1-5	All Rooms	1-4 Rms 12,13,14 slight wall damage - old
C	PW Str	70-75	Kitchen Water Heater	2-4
C	9" VFT Gn	1-5	Kitchen & MPR	1-4
C	9" VFT Gn	1-5	All Rooms	1-4
C	AC Plas	1-5	RR, Hall, MPR, Classrm 12	1-4

CONDITION CODES

GENERAL CONDITION:

CHANGE IN CONDITION:

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

(1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE Dec. 4, 1990

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS
 MAT.#

C	Mud Jnts	Assumed	By Dishwasher	1-4
*			New Portable	No Letter

CONDITION CODES

- GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 10, 1990

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters R.P.

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	All Rooms	1-4
A	AC Plas	1-5	Classrooms	1-4 (rm 7&9 slight wall damage - old)
A	AC Plas	1-5	Staff Room	1-4
A	L mud jnt	Assumed	Boiler room	1-4 Over
A	S mud jnt	Assumed	Boiler room	1-4
B	9" VFT	1-5	All Rooms	1-4
B	AC Plas	1-5	All Rooms	1-4 Rms 12,13,14 slight wall damage - old
C	PW Str	70-75	Kitchen Water Heater	2-4
C	9" VFT Gn	1-5	Kitchen & MPR	1-4
C	9" VFT Gn	1-5	All Rooms	1-4
C	AC Plas	1-5	RR, Hall, MPR, Classrm 12	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE July 10, 1990

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters *R.P.*

BLDG. HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

C	Mud Jnts	Assumed	By Dishwasher	1-4
*			New Portable	No Letter

CONDITION CODES

- GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT DATE 1/5/90
 SCHOOL J. Partridge Elementary INSPECTOR Paul D. Davis
 INSPECTOR Paul Graves

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5%	All Rooms	1-4
A	A C Plaster	1-5%	Classrooms	1-4 (Rm 7 ²⁴⁴ & 8 ²⁴⁴ slight wall damage - old)
A	A C Plaster	1-5%	Staff Room 6-905	1-4
A	Large mud joint	Assumed	Boiler Room 903	1-4
A	Small mud joint	Assumed	Boiler Room	1-4
B	9" VFT	1-5%	All Rooms	1-4
B	A C Plaster	1-5%	All Rooms	1-4 (Rms 12, 13, & 14 slight wall damage - old) <i>CFR</i>
C	PW Str Green	70-75%	Kitchen Water Heater 912	2-4
C	.9" VFT Green	1-5%	Kitchen & MPR 911	1-4
C	9" VFT	1-5%	All Rooms	1-4
C	A C Plaster	1-5%	RR, Hallway, MPR, Classrm 12	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 * OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT

DATE 1/5/90

SCHOOL J. Partridge Elementary

INSPECTOR Paul Graves

BLDG. HOMOG. ASBESTOS MATERIAL

CONDITION: CODE & COMMENTS

LOCATION

C	Mud Joints	Assumed	By Dishwasher	1-4
*			New Portable	No Letter

CONDITION CODES

- GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 * OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED