

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 27, 1993

SCHOOL J. Partridge Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	All Rooms	1-4
A	AC Plas	1-5	Classrooms	1-4 (rm 7&9 slight wall damage - old)
A	AC Plas	1-5	Staff Room	1-4
A	L mud jnt	Assumed	Boiler room	1-4 Over
A	S mud jnt	Assumed	Boiler room	1-4
B	9" VFT	1-5	All Rooms	1-4
B	AC Plas	1-5	All Rooms	1-4 Rms 12,13,14 slight wall damage - old
C	PW Str	70-75	Kitchen Water Heater	6-4
C	9" VFT Gn	1-5	Kitchen & MPR	1-4
C	9" VFT Gn	1-5	All Rooms	1-4
C	AC Plas	1-5	RR, Hall, MPR, Classrm 12	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 27, 1993  
 SCHOOL J. Partridge Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
C		Assumed	By Dishwasher	1-4
*			New Portable	No Letter

CONDITION CODES

- GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 15, 1993

SCHOOL J. Partridge Elementary INSPECTOR Ron Jones *RJ*

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	All Rooms	1-4
A	AC Plas	1-5	Classrooms	1-4 (rm 7&9 slight wall damage - old)
A	AC Plas	1-5	Staff Room	1-4
A	L mud jnt	Assumed	Boiler room	1-4 Over
A	S mud jnt	Assumed	Boiler room	1-4
B	9" VFT	1-5	All Rooms	1-4
B	AC Plas	1-5	All Rooms	1-4 Rms 12,13,14 slight wall damage - old
C	PW Str	70-75	Kitchen Water Heater	6-4
C	9" VFT Gn	1-5	Kitchen & MPR	1-4
C	9" VFT Gn	1-5	All Rooms	1-4
C	AC Plas	1-5	RR, Hall, MPR, Classrm 12	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 15, 1993

SCHOOL J. Partridge Elementary INSPECTOR Ron Jones *AS*

BLDG. HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

C.	Mud Jnts	Assumed	By Dishwasher	1-4
*			New Portable	No Letter

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)