



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B024534
Date Received: 11/10/00
Date Analyzed: 11/13/00
Date Printed: 11/13/00
First Reported: 11/13/00

Job ID / Site: Jay Partridge Elementary

FASI Job ID: 2921-33

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

1	10057663						
		Layer: Black Tar		ND			
		Layer: Black Felt		ND			


Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (40%) Fibrous Glass (ND)
Comment: Collected on 11/09/2000

2	10057664						
		Layer: Black Tar		ND			
		Layer: Black Felt		ND			

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (40%) Fibrous Glass (ND)
Comment: Collected on 11/09/2000

3	10057665						
		Layer: Black Tar		ND			
		Layer: Black Felt		ND			

Total Composite Values of Fibrous Components: Asbestos:(ND) Cellulose (40%) Fibrous Glass (ND)
Comment: Collected on 11/09/2000



Jim Flores

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from the client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

C. Asbestos binder

2921-33

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3095
Fax: (530) 891-3190

Chico Unified School District

November 9, 2000

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Roof Samples, Jay Partridge Elementary (Jay P.)

To Whom It May Concern:


Please test the enclosed roof samples for asbestos. Please fax the results to me. My fax number is (530) 891-3190.

Site Sampled:	Jay Partridge Elementary School
Date Sampled:	November 9, 2000
Number of Samples:	Three
Sample #1:	Unit D Roof - Walkway
Sample #2:	Unit D Roof - Walkway
Sample #3:	Unit D Roof - Walkway

Samples Taken by: Rob Peters

Please provide results within the 24 hour turn around time. Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures



BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 2921 Chlico Unified School District 2455 Carmichael Drive Chlico, CA 95928		PHONE: (916) 891- FAX: (916) 891-3190	DATE:
		Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM: Standard / Point Count	Gravimetry Prep
		TEM: QUAL. / QUANT. / WATER	
CONTACT:	P.O.#	JOB #	AA/Flame AA/Furnace ICP
SITE:		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
PU 1	11/9/00	ROOF UNIT 5 PVHS
PU 2	↓	ROOF UNIT 5 PVHS
PU 3	↓	ROOF UNIT 5 PVHS
1	11/9/00	UNIT 10 WALKWAY ROOF JAY P
2	↓	UNIT 10 WALKWAY ROOF JAY P
3	↓	UNIT 10 WALKWAY ROOF JAY P
1	11/9/00	PARKVIEW UNIT 4
2	↓	PARKVIEW UNIT 4
3	↓	PARKVIEW UNIT 4

Sampled by: ROB P.	Date: 11-09-00 Time:
Relinquished by:	Received By: <i>[Signature]</i>
Date/Time:	Date/Time: 11/10/00 Sealed Condition (circle one) YES / NO
Relinquished by:	Received By:
Date/Time:	Date/Time: Sealed Condition (circle one) YES / NO

USE / CRIS,

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE 8/10/00

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters

BLDG.	HOMOG.	ASBESTOS	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
MAT.#					
A	9" VFT	1-5	All Rooms	1-4	
A	AC Plas	1-5	Classrooms	1-4	(rm 7&9 slight wall damage - old) (8/99) 5-1 Repaired
A	AC Plas	1-5	Staff Room	1-4	
A	L mud jnt	Assumed	Boiler Room	5-2	PW STR - WO issued (4-1)
A	S mud jnt	Assumed	Boiler Room	1-4	
A	Tran panl	Assumed	Under Entry Windows	1-4	
B	9" VFT	1-5	All Rooms	2-5	(2/00) Replace 5 Rm 13 w/o E23746
B	AC Plas	1-5	All Rooms	5-8	Rms 12,13,14 slight wall damage old (4-1) (8/99) 5-1 Painted
C	PW Str	70-75	MPR Storage Rooms	1-4	
C	PW Str	70-75	Kitchen Water Heater Room	1-4	
C	9" VFT Gn	1-5	Kitchen & MPR	1-4	

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

WHO DRILLED HOLES LEFT DUST IN CHALK TRAYS
 YIP + GILCC

DISTRICT Chico Unified School District DATE _____

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters

BLDG.	HOMOG.	ASBESTOS MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
C	Mud Jnts		Assumed	By Dishwasher	2-5 Damaged L - w/o #E9761 issued 2/23/99 (8/99) 5-1 Repaired
C	9" VFT Gn	1-5		All Rooms	1-4
C	AD Plas	1-5		RR, Hall, MPR, Classrm 12, Kindergarten	1-4
C	Tran Pipe		Assumed	Kitchen Water Heater Room	1-4
D	Drywall		None Detected	All Rooms	
D	2x4 FCPS		None Detected	All Rooms	
*				New Portable	No Letter

CONDITION CODES

- GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE February 3, 2000

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	All Rooms	1-4
A	AC Plas	1-5	Classrooms	1-4 (rm 7&9 slight wall damage - old) (8/99) 5-1 Repaired
A	AC Plas	1-5	Staff Room	1-4
A	L mud jnt	Assumed	Boiler Room	5-2 PW STR - WO issued (4-1)
A	S mud jnt	Assumed	Boiler Room	1-4
A	Tran panl	Assumed	Under Entry Windows	1-4
B	9" VFT	1-5	All Rooms	2-5 (2/00) Replace 5 Rm 13 w/o E23746
B	AC Plas	1-5	All Rooms	5-8 Rms 12,13,14 slight wall damage old (4-1) (8/99) 5-1 Painted
C	PW Str	70-75	MPR Storage Rooms	1-4
C	PW Str	70-75	Kitchen Water Heater Room	1-4
C	9" VFT Gn	1-5	Kitchen & MPR	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE February 3, 2000

SCHOOL J. Partridge Elementary INSPECTOR Robert Peters

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
C	Mud Jnts	Assumed	By Dishwasher	2-5 Damaged L - w/o #E9761 issued 2/23/99 (8/99) 5-1 Repaired
C	9" VFT Gn	1-5	All Rooms	1-4
C	AD Plas	1-5	RR, Hall, MPR, Classrm 12, Kindergarten	1-4
C	Tran Pipe	Assumed	Kitchen Water Heater Room	1-4
D	Drywall	None Detected	All Rooms	
D	2x4 FCPS	None Detected	All Rooms	
*			New Portable	No Letter

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)