

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 27, 1993

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones

HOMOG. ASBESTOS  
 MAT.# MATERIAL LOCATION

BLDG.	HOMOG. MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Classrooms	(1) Good (4)
B	9" VFT	1-5	Classrooms	(7) Removed
C	9" VFT	1-5	Classrooms	(7) Removed
C	PW Str	20-25	Basement	(7) Removed
B	9" VFT	1-5	Room 3	(1) Good (4)
B	PW Str	20-25	Basement	(7) Removed
D	PW Str	15-20	Boiler Room	(7) Removed
D	Boiler liner	50-55	Boiler Room	(7) Removed
D	PW Str	15-20	MPR Stage Attic	(7) Removed
D	Duct Wrap	10-15	MPR Stage Attic West	(7) Removed
D	PW Str	20-25	Stage Basement	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 27, 1993

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	9" VFT	1-5	Room 3 Teacher Lounge	(1) Good (4) carpeted
D	Mud Jnt	20-25	Boiler Room	(7) Removed
D	T-O-C	1-5	Front of Stage MPR	(7) Removed
D	T-O-C	1-5	Boiler Room	(7) Removed
D	T-O-C	1-5	MP	(7) Removed
D	Lino	5-10	Admin. Office	(1) Good (4) 3/4 carpeted
D	9" VFT	1-5	MPR	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 13, 1993

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Classrooms	(1) Good (4)
B	9" VFT	1-5	Classrooms	(7) Removed
C	9" VFT	1-5	Classrooms	(7) Removed
C	PW Str	20-25	Basement	(7) Removed
B	9" VFT	1-5	Room 3	(1) Good (4)
B	PW Str	20-25	Basement	(7) Removed
D	PW Str	15-20	Boiler Room	(7) Removed
D	Boiler liner	50-55	Boiler Room	(7) Removed
D	PW Str	15-20	MPR Stage Attic	(7) Removed
D	Duct Wrap	10-15	MPR Stage Attic West	(7) Removed
D	PW Str	20-25	Stage Basement	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 13, 1993

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	9" VFT	1-5	Room 3 Teacher Lounge	(1) Good (4) carpeted
D	Mud Jnt	20-25	Boiler Room	(7) Removed
D	T-O-C	1-5	Front of Stage MPR	(7) Removed
D	T-O-C	1-5	Boiler Room	(7) Removed
D	T-O-C	1-5	MP	(7) Removed
D	Lino	5-10	Admin. Office	(1) Good (4) 3/4 carpeted
D	9" VFT	1-5	MPR	(7) Removed

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)