



Forensic Analytical  
Analytical Report

San Francisco • 3777 Depot Road, Suite 409, Hayward, CA 94545 • Phone 510/887-8828 • Fax 510/887-4218  
Los Angeles • 2959 Pacific Commerce Drive, Rancho Dominguez, CA 90221 • Phone 310/763-2374 • Fax 310/763-8834

**Bulk Material Analysis**  
Method: 40 CFR 763, Subpart F, Appendix A (AHERA)

Client:  
Chico Unified School District  
Mr. Ron Jones  
2455 Carmichael Drive  
Chico, CA 95928

Client ID: 2921  
Report Number: 257031  
Date Received: 07/31/96

P.O. Num: 97-404  
Job ID:  
Site: Hooker Oak - B Wing

Sample Number	Lab Number	Total Asbestos	Total Fibrous Non-Asbestos	(Breakdown by type)
H.Oak-B-005C Off-white sheetrock with brown fibrous material.	19652738	Non-Det. %	35-40%	Cellulose (35-40%)

*David Kahane*

David Kahane, C.I.H., Laboratory Director, Hayward Laboratory

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full with approval from Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Samples submitted to Forensic Analytical are retained for a period of six months and then disposed of according to all state and federal guidelines.



Forensic Analytical

BULK SAMPLE REQUEST FORM

<b>CLIENT NAME &amp; ADDRESS:</b>		<b>PHONE:</b> 916-891-3194 FAX 916-891-3190	<b>DATE:</b> 7-30-96
2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	<b>Circle the Method and Turn Around Time</b>		<b>Results Needed:</b>
	<u>2</u> hr/12hr/24hr/48hr/Ext		7-31-96 3:00pm Fax
	PLM: <u>Standard</u> / Point Count		Gravimetry Prep
<b>CONTACT:</b> Ron Jones		<b>TEM:</b> QUAL / QUANT. / WATER	
<b>P.O.#</b> 97-404	<b>JOB #</b>	AA/Flame AA/Furnace ICP	
<b>SITE:</b> Hooker Oak B Wing		<b>METALS:</b>	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
H.Oak-B-005C	7-30-96	Ceiling Sheet Rock in Custodial Room (B Wing)
		Please analyse this sample by layer, and report accordingly.

<b>Sampled by:</b> Ron Jones <i>RJ</i>	<b>Date:</b> 7-30-96	<b>Time:</b> NOON
<b>Relinquished by:</b> Ron Jones	<b>Received By:</b> <i>[Signature]</i>	<b>Date/Time:</b> <i>7/31/96</i>
<b>Date/Time:</b> 7-30-96 4:00pm	<b>Sealed Condition (circle one) YES / NO</b>	
<b>Relinquished by:</b>	<b>Received By:</b>	
<b>Date/Time:</b>	<b>Date/Time:</b>	
	<b>Sealed Condition (circle one) YES / NO</b>	

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 19, 1996

SCHOOL Hooker Oak Elementary INSPECTOR Rob Peters *R.P.*

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Classrooms	(1) (4)
B	9" VFT	1-5	Classrooms	(7)
C	9" VFT	1-5	Classrooms	(7)
C	PW Str	20-25	Basement	(7)
B	9" VFT	1-5	Room 3	(1) (4)
B	PW Str	20-25	Basement	(7)
D	PW Str	15-20	Boiler Room	(7)
D	Boiler liner	50-55	Boiler Room	(1) (4)
D	PW Str	15-20	MPR Stage Attic	(7)
D	Duct Wrap	10-15	MPR Stage Attic West	(7)
D	PW Str	20-25	Stage Basement	(7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 19, 1996

SCHOOL Hooker Oak Elementary INSPECTOR Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	Mud Jnt	20-25	Boiler Room	(7)
D	T-O-C	1-5	Front of Stage MPR	(7)
D	T-O-C	1-5	Boiler Room	(7)
D	T-O-C	1-5	MP	(7)
D	Lino	5-10	Admin. Office	(1) (4) 3/4 carpeted
D	9" VFT	1-5	MPR	(7)
D	9" Red VFT	Assumed	Admin and Nurse's Closet Storage	(1) (4)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 5, 1996

SCHOOL Hooker Oak Elementary INSPECTOR Rob Peters *R.P.*

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Classrooms	(1) (4)
B	9" VFT	1-5	Classrooms	(7)
C	9" VFT	1-5	Classrooms	(7)
C	PW Str	20-25	Basement	(7)
B	9" VFT	1-5	Room 3	(1) (4)
B	PW Str	20-25	Basement	(7)
D	PW Str	15-20	Boiler Room	(7)
D	Boiler liner	50-55	Boiler Room	(1) (4)
D	PW Str	15-20	MPR Stage Attic	(7)
D	Duct Wrap	10-15	MPR Stage Attic West	(7)
D	PW Str	20-25	Stage Basement	(7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 5, 1996

SCHOOL Hooker Oak Elementary INSPECTOR Rob Peters

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS  
 BLDG. MAT.#

D	Mud Jnt	20-25	Boiler Room	(7)
D	T-O-C	1-5	Front of Stage MPR	(7)
D	T-O-C	1-5	Boiler Room	(7)
D	T-O-C	1-5	MP	(7)
D	Lino	5-10	Admin. Office	(1) (4) 3/4 carpeted
D	9" VFT	1-5	MPR	(7)
D	9" Red VFT	Assumed	Admin and Nurse's Closet Storage	(1) (4)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE January 2, 1996

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones *RJ*

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	9" VFT	1-5	Classrooms	(1) (4)
B	9" VFT	1-5	Classrooms	(7)
C	9" VFT	1-5	Classrooms	(7)
C	PW Str	20-25	Basement	(7)
B	9" VFT	1-5	Room 3	(1) (4)
B	PW Str	20-25	Basement	(7)
D	PW Str	15-20	Boiler Room	(7)
D	Boiler liner	50-55	Boiler Room	(1) (4)
D	PW Str	15-20	MPR Stage Attic	(7)
D	Duct Wrap	10-15	MPR Stage Attic West	(7)
D	PW Str	20-25	Stage Basement	(7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)



SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones *RJ*

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	Mud Jnt	20-25	Boiler Room	(7)
D	T-O-C	1-5	Front of Stage MPR	(7)
D	T-O-C	1-5	Boiler Room	(7)
D	T-O-C	1-5	MP	(7)
D	Lino	5-10	Admin. Office	(1) (4) 3/4 carpeted
D	9" VFT	1-5	MPR	(7)
D	9" Red VFT	Assumed	Admin and Nurse's Closet Storage	(1) (4)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)