

July 14, 1997

DISTRICT Chico Unified School District DATE January 2, 1996

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Classrooms	(1) (4)
B	9" VFT	1-5	Classrooms	(7)
C	9" VFT	1-5	Classrooms	(7)
C	PW Str	20-25	Basement	(7)
B	9" VFT	1-5	Room 3	(1) (4)
B	PW Str	20-25	Basement	(7)
D	PW Str	15-20	Boiler Room	(7)
D	Boiler liner	50-55	Boiler Room	(1) (4)
D	PW Str	15-20	MPR Stage Attic	(7)
D	Duct Wrap	10-15	MPR Stage Attic West	(7)
D	PW Str	20-25	Stage Basement	(7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

Page 2 of 2

DISTRICT Chico Unified School District DATE January 2, 1996 7-14-97

SCHOOL Hooker Oak Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	Mud Jnt	20-25	Boiler Room	(7)
D	T-O-C	1-5	Front of Stage MPR	(7)
D	T-O-C	1-5	Boiler Room	(7)
D	T-O-C	1-5	MP	(7)
D	Lino	5-10	Admin. Office	(1) (4) 3/4 carpeted
D	9" VFT	1-5	MPR	(7)
D	9" Red VFT	Assumed	Admin and Nurse's Closet Storage	(1) (4)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)