



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Bob Michael

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B058821
Date Received: 03/05/04
Date Analyzed: 03/08/04
Date Printed: 03/08/04
First Reported: 03/08/04

Job ID / Site: Hooker Oak Elementary School - Hallway

FASI Job ID: 2921-72

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
#1	10305283						
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		

Composite Values of Fibrous Components: Asbestos:(ND)
 Cellulose (10%) Fibrous Glass (55%)
 Comment: Bulk complex sample.

#2	10305284						
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		

Total Composite Values of Fibrous Components: Asbestos:(ND)
 Cellulose (10%) Fibrous Glass (55%)
 Comment: Bulk complex sample.

*Mary
Kip
Bob M.
Bundles (3)
file*

MAR 12 2004



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Bob Michael

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B058821
Date Received: 03/05/04
Date Analyzed: 03/08/04
Date Printed: 03/08/04
First Reported: 03/08/04

Job ID / Site: Hooker Oak Elementary School - Hallway

FASI Job ID: 2921-72

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
#3	10305285						
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (10%) Fibrous Glass (55%)
 Comment: Bulk complex sample.

#4	10305286						
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (10%) Fibrous Glass (55%)
 Comment: Bulk complex sample.



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Bob Michael

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B058821
Date Received: 03/05/04
Date Analyzed: 03/08/04
Date Printed: 03/08/04
First Reported: 03/08/04

Job ID / Site: Hooker Oak Elementary School - Hallway

FASI Job ID: 2921-72

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
#5	10305287						
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		

Composite Values of Fibrous Components: Asbestos:(ND)
 Cellulose (55%) Fibrous Glass (10%)
 Comment: Bulk complex sample.

#6	10305288						
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		
		Layer: Black Tar			ND		
		Layer: Black Felt			ND		

Total Composite Values of Fibrous Components: Asbestos:(ND)
 Cellulose (10%) Fibrous Glass (55%)
 Comment: Bulk complex sample.



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Bob Michael

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B058821
Date Received: 03/05/04
Date Analyzed: 03/08/04
Date Printed: 03/08/04
First Reported: 03/08/04

Job ID / Site: Hooker Oak Elementary School - Hallway

FASI Job ID: 2921-72

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
#7	10305289						
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (10%) Fibrous Glass (55%)
 Comment: Bulk complex sample.

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.

Forensic Analytical

Analysis Request Form

Client Name & Address: <u>Chico Unified School District</u> <u>2455 Carmichael Drive</u> <u>Chico, Ca 95928</u>		P.O. #: _____ Date: <u>3/4/04</u>	
Contact: <u>Bob Michael</u>		Turn Around Time: <u>24</u> hr / 12hr / <u>24hr</u> 48 hr / ext: _____	
Phone #: <u>530-891-3199</u> ext: _____		Due Date: / / Due Time: : am/pm	
Fax #: <u>530-891-3190</u>		<input checked="" type="checkbox"/> PLM <input type="checkbox"/> Standard / <input type="checkbox"/> Point Count <input type="checkbox"/> PCM: NIOSH 7400	
Site: <u>Hodder Oak Elementary</u>		<input type="checkbox"/> TEM Air: <input type="checkbox"/> AHERA / <input type="checkbox"/> Yamate2 / <input type="checkbox"/> NIOSH 7402	
Job: <u>Hall Roof</u>		<input type="checkbox"/> TEM Bulk: <input type="checkbox"/> Quantitative / <input type="checkbox"/> Qualitative / <input type="checkbox"/> Chatfield	
Comments:		<input type="checkbox"/> TEM Water: <input type="checkbox"/> Potable / <input type="checkbox"/> Non-Potable / <input type="checkbox"/> Wt %	
		<input type="checkbox"/> TEM Microvac	
		<input type="checkbox"/> Special Project:	
		<input type="checkbox"/> Metals Analysis: Method _____	
		Matrix: _____	
		Analytes: _____	

Sample ID	Date/Time	Sample Location/Description	FOR AIR SAMPLES ONLY				Sample Area or Air Volume
			Type	Time On/Off	Avg. LPM	Total Time	
#1		Hall Roof Near Kitchen	A P C				
#2		Hall Roof Near mPR	A P C				
#3		Hall Roof Near Rm 2	A P C				
#4		Hall Roof Near Rm 4	A P C				
#5		Hall Roof Near 905	A P C				
#6		Hall Roof Near Rm 18	A P C				
#7		Hall Roof Near Rm 8	A P C				
			A P C				
			A P C				
			A P C				

Sampled by: ROBERT Michael Date: 3/4/04 Time: 9:30 AM

Shipped via: Fed Ex Airborne UPS US Mail Courier Drop Off Other:

Relinquished by: Date / Time:	Relinquished by: Date / Time:	Relinquished by: Date / Time:
Received by: <u>Earl B. [Signature]</u> Date / Time: <u>3/6/04 11:28 am</u>	Received by: Date / Time:	Received by: Date / Time:
Condition Acceptable? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Condition Acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No	Condition Acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No

2921-72

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

March 4, 2004

FedEx Priority Overnight
Airbill #8358 1795 1282

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Hooker Oak Elementary School

To Whom It May Concern:

Please test the enclosed samples from the Hooker Oak Elementary School Hall Roof for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled:	Hooker Oak Elementary School
Location:	Hallway
Date Sampled:	March 4, 2004
Number of Samples:	Seven (7)
	#1 - Hall Roof Near Kitchen
	#2 - Hall Roof Near MPR
	#3 - Hall Roof Near Room 2
	#4 - Hall Roof Near Room 4
	#5 - Hall Roof Near Room 905
	#6 - Hall Roof Near Room 18
	#7 - Hall Roof Near Room 8

Thank you for your prompt response to this request.

Sincerely,



Robert Michael
Construction Supervisor

RM:dlg
Enclosures (7)

HMS, Inc.

HAZARD MANAGEMENT SERVICES, INC.

4200 Rocklin Rd., Ste. 11A
Rocklin, CA 95677-2860
(916) 632-6800 • (916) 632-6841 Fax

May 26, 2004

Mr. Kip Hansen
Chico Unified School District
1163 E. Seventh Street
Chico, CA 95928

RE: Fifth Triennial AHERA Three-Year Reinspection

Dear Mr. Hansen:

Enclosed is the data obtained from the fifth AHERA three-year reinspections Hazard Management Services, Inc. (HMS, Inc.) conducted between April 14 and May 4, 2004. The documents included with this letter are the "Three-Year Reinspection Homogeneous ACBM Material Records" covering all buildings known from the original inspection to contain ACBM. The sites enclosed are Chico Junior High, Chico Senior High, Hooker Oak Elementary, Pleasant Valley High, and Sierra View Elementary Schools.

You should review the updated Homogeneous Materials Reports to familiarize yourself with the current status of asbestos containing materials and identified suspect asbestos materials. It is the District's responsibility to assure that the school's site copy of the Management Plan is up to date and consistent with the District's Management Plan for that site. This is very important and if not done can cause the District to be penalized during an EPA site visit or investigation.

HMS, Inc. wants to remind you that materials containing "trace" amounts of asbestos must be considered in the event of renovations or demolitions. Although building materials containing trace amounts of asbestos (<1%) are not regulated under EPA, Cal/OSHA does regulate work practices with materials containing 0.1% asbestos. The original AHERA inspection contains information regarding materials with trace amounts of asbestos.

When you provide your annual notification to parents and staff, include information regarding this three-year reinspection. Enclosed is a suggested format for your notification letter. Please note that you must include in your Management Plans a description of the steps you take to notify. It is also important that your Management Plans be updated after any and all actions conducted which impact asbestos containing materials.

Please remember that HMS, Inc. did not inspect new buildings or portable classrooms which were placed on the District sites since the original EPA AHERA inspection. It is the District's responsibility to obtain letters of certification from the Architect, Construction Superintendent, or manufacturer of new building materials, indicating there is no asbestos in the new buildings (constructed after October 12, 1988) or new building materials. A copy of these certification letters must be included in your management plans, both at the school site and at the LEA Designees office site. It is still required of School Districts to send a copy of these certification letters to the US EPA AHERA unit, Region IX in San Francisco.

Mr. Kip Hansen
Chico Unified School District
May 26, 2004
Page Two

HMS, Inc. was unable to confirm new information found in the updated inspection reports provided by the District, which reported the removal of materials and sampling of materials performed by the District.

Since HMS, Inc. was not provided with the supporting documentation pertaining to the removal and sampling completed by the District, any and all changes from the last 3 year reinspections as to the removal of previously identified "assumed" or asbestos containing materials, or sample result changes are the sole responsibility of the District. By submitting this finalized report, HMS, Inc. is neither confirming or denying these changes.

It is not necessary to send a copy of the three-year reinspection to the OPSC or EPA. However, the report should be included in your Management Plan. I want to thank you for your cooperation. If you have any questions, please feel free to contact me at (916) 632-6800.

Sincerely,



John Angi
Certified Asbestos Consultant
CAC #03-3330

Enclosures

RECORD OF FRIABLE AND NONFRIABLE ACM
(FORM B)

Inspection Date(s) April 20, 2004

THREE-YEAR REINSPECTION

CDS CODE
04-61424-6003008

SCHOOL
Hooker Oak Elementary School

SCHOOL PHONE NUMBER
(530) 891-3119

ADDRESS
1238 Arbutus Avenue

(NUMBER)

(STREET)

(CITY)
Chico, CA

(ZIP)
95926

-IMPORTANT-

Each building and functional space with friable ACBM or friable assumed ACBM listed on this form requires completion of FORM C (PHYSICAL AND HAZARD ASSESSMENT OF FRIABLE ACBM OR FRIABLE ASSUMED ACBM). Indicate location of material on blueprint, diagram or narrative in square or linear feet, and attach a copy (Sec. 763.93).

LINE	BUILDING NAME & FUNCTIONAL SPACE <small>(Indicate Address if Different From Above)</small>	CHECK ONE			CHECK ONE			
		SUR- FACING	TSI	MISC	ACBM		ASSUMED ACBM	
					FRIABLE	NON- FRIABLE	FRIABLE	NON- FRIABLE
1.	A			X		X		X
2.	B			X				X
3.	C			X				X
4.	D			X		X		X
5.	E			X		X		X
6.	PORTABLE LIBRARY			X				X
7.	PORTABLE 18			X				X
8.	PORTABLES 19-21			X				X
9.								
10.								
11.								
12.								
13.								
14.								
15.								
16.								
17.								

See attached "Homogeneous Materials Records" for all materials and their locations by building. On Form B all buildings are listed, and a summary of all non-friable and friable material is provided. Friable materials and their locations are listed separately under each building on Form B.

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chicago Unified School District

Inspector: John Angi

School: Booker Oak Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Fiabile Yes/No
M	9" VFT GREEN	13	1-5%	2,880 S	CLASSROOMS 13-16	(1) (4)	N
M	9" VFT BRIGHT GREEN	97	ASSUMED	400 S	SINK ROOM	(1) (4)	N
M	12" ACT	98	ASSUMED	2,880 S	CLASSROOMS 13-16, SINK ROOM, AND RESTROOM	(2) SOME CRACKED AND BROKEN 12" ACT'S.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Crocker Oak Elementary School

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCPS	94	ASSUMED	4,500 S	CLASSROOMS 6-10	(7) REMOVED ACCORDING TO CHICO USD RECORDS.	N/A
M	12" ACT	95	ASSUMED	2,500 S	HALLWAY & STAFF ROOM	(7) REMOVED ACCORDING TO CHICO USD RECORDS.	N/A
M	12" VFT SALMON	96	ASSUMED	4,500 S	CLASSROOMS 6-10	(7) REMOVED ACCORDING TO CHICO USD RECORDS.	N/A
M	2' X 4' FCPS	107	ASSUMED	4,500 S	CLASSROOMS 6-10	(1) DISTRICT MUST CERTIFY.	N
M	12" ACT	108	ASSUMED	2,500 S	HALLWAY & STAFF ROOM	(1) DISTRICT MUST CERTIFY.	N
M	12" VFT SALMON	109	ASSUMED	4,500 S	CLASSROOMS 6-10	(1) DISTRICT MUST CERTIFY.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Hooker Oak Elementary School

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	FT ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP'S	94	ASSUMED	4,500 S	CLASSROOMS 1-5	(7) REMOVED ACCORDING TO CHICO USD RECORDS.	N/A
M	12" ACT	95	ASSUMED	2,500 S	HALLWAY	(7) REMOVED ACCORDING TO CHICO USD RECORDS.	N/A
M	12" VFT SALMON	96	ASSUMED	4,500 S	CLASSROOMS 1-5	(7) REMOVED ACCORDING TO CHICO USD RECORDS.	N/A
M	12" VFT GREEN	101	ASSUMED	2,200 S	HALLWAY	(1) DISTRICT MUST CERTIFY.	N
M	2' X 4' FCP'S	110	ASSUMED	4,500 S	CLASSROOMS 1-5	(1) DISTRICT MUST CERTIFY.	N
M	12" ACT	111	ASSUMED	2,500 S	HALLWAY	(1) DISTRICT MUST CERTIFY.	N
M	12" VFT SALMON	112	ASSUMED	4,500 S	CLASSROOMS 1-5	(1) DISTRICT MUST CERTIFY.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Hooker Oak Elementary School

Building: D

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	2	NONE DETECTED	350 S	MPR (NORTH WALL)	(13) SAMPLE HMS-HKR-02 COLLECTED ON 3-29-88.	N/A
M	LINOLEUM	17	5-10%	250 S	ADMINISTRATION OFFICE	(1) (4)	N
M	12" VFT GREEN-WHITE	93	ASSUMED	2,500 S	MPR	(1) (12) REPLACED 9" VFT.	N
M	12" VFT SALMON	96	ASSUMED	1,800 S	CLASSROOMS 11 & 12	(1) (4)	N
T	BOILER LINER	8	50-55%	210 S	BOILER ROOM	(1) (4)	N
M	9" VFT RED	100	ASSUMED	50 S	ADMINISTRATION STORAGE	(1)	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Hooker Oak Elementary School

Building: E

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	14	NONE DETECTED	1,200 S	CLASSROOM 17 (LIBRARY)	(13) SAMPLE HMS-HKR-14 COLLECTED ON 3-29-88.	N/A
M	12" VFT CREAM	99	ASSUMED	1,200 S	CLASSROOM 17 (LIBRARY)	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Hooker Oak Elementary

Building: Portable Library

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	104	ASSUMED	900 S	LIBRARY PORTABLE	(1) (4) MANUFACTURE DATE OF PORTABLE LIBRARY IS 6/95. I.D. #63260 DMSI CONSTRUCTION DISTRICT CERTIFICATION REQUIRED.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Hooker Oak Elementary School

Building: Portable 18

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' VFT	105	ASSUMED	900 S	PORTABLE CLASSROOM 18	(1) (4) SUN SERI CONSTRUCTION OSA #47175. MANUFACTURE DATE OF PORTABLE 18 IS 8/86.	N
M	12" VFT	106	ASSUMED	900 S	PORTABLE CLASSROOM 18	(1) (4) SUN SERI CONSTRUCTION OSA #47175. MANUFACTURE DATE OF PORTABLE 18 IS 8/86.	N

CONDITION CODE

- General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**THREE-YEAR REINSPECTION
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: April 20, 2004

District: Chico Unified School District

Inspector: John Angi

School: Hooker Oak Elementary

Building: Portables 19-21

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	101	ASSUMED	2,700 S	PORTABLES CLASSROOMS 19-21	(1) (4) MANUFACTURE DATE OF PORTABLES IS 6/97. DMSI CONSTRUCTION DISTRICT CERTIFICATION REQUIRED.	N
M	2' X 4' FCP	102	ASSUMED	2,700 S	PORTABLES CLASSROOMS 19-21	(1) (4) MANUFACTURE DATE OF PORTABLES IS 6/97. DMSI CONSTRUCTION DISTRICT CERTIFICATION REQUIRED.	N


CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

Hooker Oak Elementary

3 yr INSPECTION
[Signature]
 04/2004



EAST THIRD AVENUE

State of California
Division of Occupational Safety and Health
Certified Asbestos Consultant

John A. Angi



Name

Certification No. **03-3330**

Expires on **4/23/2005**

This certification was issued by the Division of Occupational Safety and Health as authorized by Sections 71.60 et seq. of the Business and Professions Code.

Hazard Management Services, Inc.

This is to confirm that

John A. Angi

has attended the eight-hour

***AHERA Refresher Course for Asbestos Inspectors and
Management Planners***

and has completed the requisite training for asbestos accreditation under TSCA Title II

September 10, 2003

Certificate number: 14

Valid until: September 10, 2004

Call/OSHA approval number: CA-025-06/CA-025-08



Tom Wangerin, MS, CAC

AHERA Training Director

Hazard Management Services, Inc.

367 Civic Drive, Suite 7

Pleasant Hill, CA 94523-1936

925-363-3442