

INSPECTION DOCUMENTS


LEA: CHICO UNIFIED SCHOOL DISTRICT

SCHOOL: LOMA VISTA SCHOOL

DATE OF INSPECTION: MARCH 30, 1988

INSPECTOR: JAMES E SHARP, SR.

ACCREDITATION: UC BERKELEY, P.A.I.C. #4

  
\*(name of inspector)

# UNIVERSITY OF CALIFORNIA

## BERKELEY

### UNIVERSITY EXTENSION

This is to certify that

*James E Sharp*

has attended and satisfactorily passed the exam  
for the course

Building Inspection and Management Planning for Asbestos

November 16-20, 1987

This certification is valid until:

November 20, 1988

November 18 and 20, 1987

Exam dates

4

Certificate number



*Vivian Sutcher*

Assistant Dean  
University Extension

*Debra M.*

Program Director  
Pacific Asbestos Information Center

# UNIVERSITY OF CALIFORNIA BERKELEY UNIVERSITY EXTENSION

This is to certify that

JAMES E. SHARP

has attended the refresher course  
for building inspectors and management planners,

**Advanced Topics in Building Inspection and Management Planning**

**December 13, 1988**

Certificate number: 4

Valid until: December 13, 1989



*Verina Satchar*  
Assistant Dean  
University Extension

*Deborah D. L.*  
Program Director  
Pacific Asbestos Information Center

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7277

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810567

Sample Number: LVS-01-6

Site: Loma Vista - Chico Unified School District.

Analyst: MF

Location: Unit "6" - Room #1/Office, 2x4 ceiling panel.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous ceiling tile.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	10-15	%	60-70	%
Mineral Wool	50-55	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	%	30-40	%
Perlite	25-30	%		

Analyst:

*Michelle Fox*

Supervisor:

*DE*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:  
Hazard Management Services, Inc.

P.O. Box 7012  
Modesto, CA 95355

Client Number: 146  
Report Number: 7277  
Date Received: 04/09/88  
Date Examined: 04/15/88

Lab Number: 8810568  
Sample Number: LVS-02-6  
Site: Loma Vista - Chico Unified School District

Analyst: MF

Location: Unit #6 - Multi-Purpose Room/Kitchen, 12" vinyl floor  
tile, white marble.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white floor tile associated with a black  
tar adhesive (asbestos in both).

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	10-15	%	10-15	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	85-90	%	85-90	%
		%		
		%		
		%		

Analyst:

*Michelle Fox*

Supervisor:

*JD*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7277

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810569

Sample Number: LVS-03A-6

Site: Loma Vista - Chico Unified School District.

Analyst: MF

Location: Unit #6 - Shop Storage, drywall plaster.

P.O.: Loma Vista - Chico Unified School District

Gross Description: White drywall.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	10-15	%	15-25	%
Mineral Wool	5-10	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	25-30	%	75-85	%
Gypsum	50-55	%		

Analyst:

*Michelle Fox*

Supervisor:

*de*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7277

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810570

Sample Number: LVS-03B-6

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Unit #6 - Shop Work Room, drywall plaster.

P.O.: Loma Vista - Chico Unified School District

Gross Description: White drywall.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	10-15	%	15-25	%
Mineral Wool	5-10	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	75-85	%	75-85	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle Fay*

Supervisor:

*de*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7277

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810572

Sample Number: LVS-04-6

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Unit #6 - Multi-Purpose Room, 12" acoustic tile.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous ceiling tile.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	85-90	%	90-95	%
Mineral Wool	1-5	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	%	5-10	%
--------------------------	------	---	------	---

Analyst:

*Michelle J. Fox*

Supervisor:

*[Signature]*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

3777 Depot Road, Suite 408, Hayward, CA 94545 • (415) 887-8828



# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7277

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810571

Sample Number: LVS-05-6

Site: Loma Vista - Chico Unified School District.

Analyst: MF

Location: Unit #6 - Boiler Room, mudded joints.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white semi-fibrous material.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	5-10	%	65-70	%
Mineral Wool	55-60	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	30-35	%	30-35	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle Fox*

Supervisor: *DO*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

Client:  
Hazard Management Services, Inc.

P.O. Box 7012  
Modesto, CA 95355

Client Number: 146  
Report Number: 7277  
Date Received: 04/09/88  
Date Examined: 04/15/88

Lab Number: 8810573  
Sample Number: LVS-06-6  
Site: Loma Vista - Chico Unified School District.

Analyst: MF

Location: Unit #6 - Boiler Room/Boiler, boiler liner.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Gray semi-fibrous material.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	10-15	%	10-15	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	85-90	%	85-90	%
		%		
		%		
		%		

Analyst:

*Michelle Fox*

Supervisor:

*[Signature]*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

Client:  
Hazard Management Services, Inc.

P.O. Box 7012  
Modesto, CA 95355

FOR

Client Number: 146  
Report Number: 7277  
Date Received: 04/09/88  
Date Examined: 04/15/88

Analyst: MF

Lab Number: 8810574  
Sample Number: LVS-03C-6  
Site: Loma Vista - Chico Unified School District.

Location: Unit #6 - Multi-Purpose Room, drywall plaster.

P.O.: Loma Vista - Chico Unified School District

Gross Description: White wall plaster.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose		%	10-20	%
Mineral Wool	5-10	%		
Polyethylene	5-10	%		
	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates		%	80-90	%
Gypsum	35-40	%		
	45-50	%		

Analyst: Michelle Fox

Supervisor: MF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

3777 Depot Road, Suite 408, Hayward, CA 94545 • (415) 887-8828

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810575

Analyst: MF

Sample Number: LVS-01

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Main Entrance - Hallway/Room #10, 9"  
off-white vinyl floor tile and backing.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white floor tile associated with a black  
tar adhesive (asbestos in both).

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle Fox*

Supervisor:

*X*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810576

Analyst: MF

Sample Number: LVS-02

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Conference Room/Room #2, 1'x1' acoustic ceiling tile.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous ceiling material.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile

<1 %

Amosite

<1 %

Crocidolite

<1 %

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

95-99 %

Cellulose

95-99 %

Mineral Wool

Trace %

Polyethylene

<1 %

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

1-5 %

Unspecified Particulates

1-5 %

Analyst:

*Michelle Fay*

Supervisor:

*DE*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810577

Sample Number: LVS-03A

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Bath Room & Room #13, plaster ceiling (soft plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White plaster ceiling powder.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle J. Fox*

Supervisor:

*DO*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810578

Analyst: MF

Sample Number: LVS-03B

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #13/Bath Tub Room, plaster ceiling  
(soft plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White plaster ceiling powder.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
		%		
		%		
		%		

Analyst:

*Michelle J. Fox*

Supervisor:

*De*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810579

Sample Number: LVS-05A

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #13/Bath Room, plaster wall (hard plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White wall plaster.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	98-99	%
--------------------------	-------	---

Analyst:

*Michelle A. Fox*

Supervisor:

*DC*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.



# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810580

Analyst: MF

Sample Number: LVS-03C

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Bath Room #13, plaster ceiling (soft plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White ceiling plaster.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%
Amosite	<1	%
Crocidolite	<1	%

1-5 %

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%
Mineral Wool	<1	%
Polyethylene	<1	%

<1 %

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%
--------------------------	-------	---

95-99 %

Analyst: Michelle Fox

Supervisor: [Signature]

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810581

Analyst: MF

Sample Number: LVS-05B

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #7/Supply Room, plaster wall (hard plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White wall plaster.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
		%		
		%		
		%		

Analyst:

*Michelle Fox*

Supervisor:

*DC*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810582

Analyst: MF

Sample Number: LVS-03D

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #11/Boy's Bath Room, plaster ceiling  
(soft plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White ceiling plaster.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle [Signature]*

Supervisor:

*[Signature]*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810583

Analyst: MF

Sample Number: LVS-03E

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #11/Girl's Bath Room, plaster ceiling  
(soft plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White ceiling plaster.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%
Amosite	<1	%
Crocidolite	<1	%

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%
Mineral Wool	<1	%
Polyethylene	<1	%

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%
--------------------------	-------	---

Analyst:

*Michelle Fox*

Supervisor:

*de*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810584

Analyst: MF

Sample Number: LVS-05C

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #8/Men's Bathroom, plaster wall (hard plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White plaster powder.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%
Other Fibers	1-5	%

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%
--------------------------	-------	---

Analyst: Michelle Fox

Supervisor: X

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810585

Analyst: MF

Sample Number: LVS-05D

Site: Loma Vista - Chico Unified School District.

Location: Unit #2 - Room #6/Women's Bathroom, plaster wall (hard plaster).

P.O.: Loma Vista - Chico Unified School District

Gross Description: White plaster powder.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile

<1 %

Amosite

<1 %

Crocidolite

<1 %

%

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Trace %

Cellulose

Trace %

Mineral Wool

<1 %

Polyethylene

<1 %

%

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

98-99 %

Unspecified Particulates

65-70 %

Perlite

25-30 %

%

%

Analyst:

*Michael Fox*

Supervisor:

*DE*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810586

Sample Number: LVS-04A

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Attic of Hallway - Outside Room #8, straight pipe wrap (TSI).

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous insulation.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile		55-60	%
Amosite	<1		%
Crocidolite	55-60		%
	<1		%

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose		Trace	%
Mineral Wool	Trace		%
Polyethylene	<1		%
	<1		%

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates		40-45	%
	40-45		%

Analyst:

*Michelle Fox*

Supervisor:

*DC*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810587

Analyst: MF

Sample Number: LVS-04B

Site: Loma Vista - Chico Unified School District.

Location: Attic of Hallway - Outside of Room #3, pw debris (TSI).

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous insulation.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	60-65	%	60-65	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%	1-5	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	30-35	%	30-35	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle J. Fox*

Supervisor:

*DC*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.



# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810588

Sample Number: LVS-04C

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Room #9 - Boiler Room, pw straight (TSI).

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous insulation.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	70-75	%	70-75	%
Amosite	<1	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	25-30	%	25-30	%
--------------------------	-------	---	-------	---

Analyst:

*Michelle Fox*

Supervisor:

*De*

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810589

Sample Number: LVS-06

Analyst: MF

Site: Loma Vista - Chico Unified School District.

Location: Room #9 - Boiler Room, mudded joint (TSI).

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous material.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	5-10	%
Amosite	1-5	%		
Crocidolite	<1	%		

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%	55-65	%
Mineral Wool	55-60	%		
Polyethylene	<1	%		

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	30-35	%	30-35	%
--------------------------	-------	---	-------	---

Analyst: Michelle J. Far

Supervisor: DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

# Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

## BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7278

Date Received: 04/09/88

Date Examined: 04/15/88

Lab Number: 8810590

Analyst: MF

Sample Number: LVS-07

Site: Loma Vista - Chico Unified School District.

Location: Trail - 1'x 8' Cellulose, acoustic ceiling panel.

P.O.: Loma Vista - Chico Unified School District

Gross Description: Off-white fibrous ceiling panel.

### MICROSCOPIC DESCRIPTION:

#### TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile

<1 %

Amosite

<1 %

Crocidolite

<1 %

#### TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

90-95 %

Cellulose

85-90 %

Mineral Wool

1-5 %

Polyethylene

<1 %

#### TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

5-10 %

Unspecified Particulates

5-10 %

Analyst:



Supervisor:



COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

3777 Depot Rd: Suite 408 Hayward, Ca. 94545 (415) 887-8828 Page 1 of 1

HAZARD MANAGEMENT SERVICES, INC. PHILIP UNIFIED SCHOOL DIST.  
 Bill To: District or Business  
 P.O. Box 7012, Modesto, Ca 95355  
 Billing Address: School Loma Vista  
 OR  
 Bldg JES Date 4/26/88

Reported Results Date/Time/By R.B. Date 3/30/88 Sent to Lab by: JES date 4/26/88  
 LAB Request: % Asbestos By PLM

Sample #HMS-	Sample I - 1 page No	MATERIALS/LOCATION	% Asbestos
LVS-01		M: VFT - 9" - Off-White & backing L: Hallway-main Entrance - room #10 (unit 2)	1-5
LVS-02		M: acoustic Ceiling Tile 1'x1' L: room #22 - (conference room) unit 2	<1
LVS-03A		M: Plaster Ceiling (soft Plaster) L: Bathroom & <del>plaster</del> room #13	1-5
LVS-04		M: ceiling Panels 2'x4' (grey in color) L: main office unit 6 (room #11)	Not A sample
LVS-03B		M: Plaster Ceiling (soft Plaster) L: Bath tub room - room #13 (unit 2)	1-5
LVS-05A		M: Plaster Wall (Hard Plaster) L: Bathroom - room #13 unit 2	<1
LVS-03C		M: Plaster Ceiling (soft Plaster) L: Bathroom #13 unit 2	1-5
LVS-05B		M: Plaster Wall (Hard Plaster) L: Supply room - unit 2 - room #7	1-5
LVS-03D		M: Plaster Ceiling (soft Plaster) L: room #16 unit 2 (Boys Bathroom)	1-5
LVS-03E		M: Plaster Ceiling (soft Plaster) L: room #16 unit 2 (Girls bathroom)	1-5

# BULK SAMPLES

FORENSIC ANALYTICAL SPECIALTIES INC. - ASBESTOS ANALYSIS LABORATORY REQUEST FORM

3777 Depot Rd: Suite 408

Hayward, Ca. 94545

(415) 887-8828

Page 2 of 2

Client Number		Report Number		HAZARD MANAGEMENT SERVICES, INC		CHICO UNIFIED SCHOOL DIST.	
Received By		Date Rec'd		Bill To:		District or Business	
Reported Results		Date/Time/By		P.O. Box 7012, Modesto, Ca 95355		School Loma Vista	
Sample #HMS-		I page No		Billing Address:		OR	
FAS Lab#				Collected by: R.B.		Bldg	
				Date 3/30/88		Sent to Lab by: JES	
				LAB Request: % Asbestos By PLM		Date 4/9/88	
				MATERIALS/LOCATION		% Asbestos	
LVS-05C				M: Plaster Wall (Hard Plaster)		<1	
LVS-05D				L: Unit 2 - room # 8 (mens Bathroom)		<1	
LVS-04A				M: Plaster Wall (Hard Plaster)		55-60	
LVS-04B				L: Unit 2 - room # 6 (womens Bathroom)		60-65	
LVS-04C				M: Pipe Wrap - Straight (TSI)		70-75	
LVS-06				L: AHJ of Hallway - (outside room # 8)		5-10	
LVS-07				M: TSI - Plw <del>str</del> Debris		21	
LVS-				L: AHJ of Hallway - (outside of room # 3)			
LVS-				M: TSI - Plw Straight			
LVS-				L: Room # 9 - Boiler Room			
LVS-				M: TSI - Muddled joint			
LVS-				L: Room # 9 - Boiler Room			
LVS-				M: acoustic ceiling Panel 1'x8' - cellulose			
LVS-				L: Trailer			
LVS-				M:			
LVS-				L:			
LVS-				M:			
LVS-				L:			

**BULK SAMPLES**

FORENSIC ANALYTICAL SPECIALTIES INC. - ASBESTOS ANALYSIS LABORATORY REQUEST FORM

3777 Depot Rd: Suite 408 Hayward, Ca. 94545 (415) 887-8828 Page 1 of 1

Client Number	Report Number	HAZARD MANAGEMENT SERVICES, INC.	CHICO UNIFIED SCHOOL DIST.
Received By	Date Rec'd	Bill To:	District or Business
		P.O. Box 7012, Modesto, Ca 95355	School <u>Santa Rita</u>
		Billing Address:	OR
			Bldg
Reported Results	Date/Time/By	Collected by: <u>JES</u>	Date <u>3/20/88</u>
		LAB Request: % Asbestos By PLM	Sent to Lab by: <u>JES</u>
			date <u>3/24/88</u>

FAI Lab#	Sample #HMS-	I - I page No	MATERIALS/LOCATION	% Asbestos
	LV5-01-6		M: Ceiling Panel 2F4 L: Rm 1. 'Appl' Unit 6"	<1
	LV5-02-6		M: 12" VFT-7 white marble L: Kitchen - MPC Unit 6	10-15
	LV5-03A-6		M: Drywall plaster L: Shop storage - Unit 6	<1
	LV5-03B-6		M: Drywall plaster L: Shop Unit Room - Unit 6	<1
	LV5-04-6		M: Mudded Joint L: Boiler Room - Unit 6	<1
	LV5-05-6		M: 1/2" acoustic tile L: MPC - Unit 6	<1
	LV5-06-6		M: Boiler Lines L: Unit 6 - Boiler Room boiler	10-15
	LV5-03C-6		M: Drywall plaster L: MPC - Unit 6	<1
			M:	
			L:	
			M:	
			L:	

LOMA VISTA TMR SCHOOL  
CHICO UNIFIED SCHOOL DISTRICT  
CHICO, BUTTE CO., CALIFORNIA

DIAGRAM OF BUILDING AREA

☒ EXISTING (1-A)  
☐ BASIC PLANS (2-A)  
☐ FINAL PLANS (3-A)

UNIT "6"

1	OFFICE	13.25 x 21.5	284.88
2	ENC. CORRIDOR	14.08 x 59.66 + 9.08 x 4.33	879.33
3	TEACHER	23.22 x 10.75	250.79
4	TOILET	23.33 x 21.25	495.76
5	CLASSROOMS (2)	30.25 x 44.66 - 5.33 x 9.33	1,301.24
6	OBSERVATION	9.42 x 9.33	87.89
7	CLASSROOMS (2)	44.66 x 27.33 - 8.66 x 4.66	1,180.20
8	OBSERVATION	8.66 x 8.00	69.28
9	ENC. CORRIDOR	13.33 x 23.33	310.99
10	CLASSROOM	23.00 x 27.33	628.59
11	OBSERVATION	7.42 x 7.66	56.84
12	TOILET	23.00 x 12.25	281.75
13	ISOLATION	6.00 x 12.25	73.50
14	SPECIAL CLASSROOM	32.33 x 29.0 + 7.5 x 6.5	986.32
15	STORAGE	15.0 x 9.0	135.00
16	MECHANICAL	15.0 x 20.17	302.55
17	ENC. CORRIDOR	15.0 x 10.0	150.00
18	WORK ROOM	15.0 x 10.33	154.95
19	STORAGE	15.0 x 12.83	192.45
20	EXERCISE ROOM	32.17 x 26.00	836.42
21	KITCHEN	9.0 x 26.00	234.00
22	SPECIAL PURPOSE ROOM	59.42 x 39.5	2,347.09
23	SHOP	22.66 x 27.66	626.78

ABOVE IS MEASURED IN ACCORDANCE WITH ART. 2022  
SUBCHAPTER 8, TITLE 5, CALIF. ADMIN. CODE  
*Paul J. Smith*  
ARCHITECT

DATE: 1-24-87 SHEET 10 OF 12  
OFFICE OF THE STATE ARCHITECT

LOMA VISTA TMR SCHOOL  
CHICO UNIFIED SCHOOL DISTRICT  
CHICO, BUTTE CO., CALIFORNIA

DIAGRAM OF BUILDING AREA

☒ EXISTING (1-A)  
☐ BASIC PLANS (2-A)  
☐ FINAL PLANS (3-A)

UNIT "6" CONT.

24	CLASSROOMS (2)	22.66 x 27.66 - 8.66 x 4.66	586.42
25	OBSERVATION	8.66 x 8.66	75.00
26	JANITOR	11.00 x 4.0	44.00
27	ENC. CORRIDOR	11.00 x 5.0	<u>55.00</u>
		SUB-TOTAL	12,627.02
A	COV. CORRIDOR	7.33 x 4.0 x .33	9.68
B	COV. CORRIDOR	6.66 x 4.0 x .33	8.79
C	COV. CORRIDOR	7.33 x 9.33 x .33	22.5
D	COV. CORRIDOR	6.66 x 7.33 x .33	16.11
E	COV. CORRIDOR	13.33 x 8.0 x .33	35.19
F	COV. CORRIDOR	4.0 x 4.0 x .33	5.28
G	COV. CORRIDOR	10.66 x 10.66 x .33	37.5
H	COV. CORRIDOR	4.0 x 3.33 x .33	<u>4.4</u>
		SUB-TOTAL	139.52
		TOTAL	12766.54

ABOVE IS MEASURED IN ACCORDANCE WITH ART. 2022  
SUBCHAPTER 8, TITLE 5, CALIF. ADMIN. CODE  
*Paul Bonhake*  
ARCHITECT

DATE. 3-24-87 SHEET 11 OF 12  
OFFICE OF THE STATE ARCHITECT



SUMMARY OF AREA

<u>UNIT</u>	<u>TOTAL AREA</u>
UNIT 1	6,442.00
COVERED CORRIDOR @ 1/3	488.56
UNIT 2	7,706.93—
COVERED CORRIDOR @ 1/3	1,452.94
UNIT 3	2,090.57
COVERED CORRIDOR @ 1/3	652.87
UNIT 4	4,507.84
COVERED CORRIDOR @ 1/3	917.74
UNIT 5	4,349.43
COVERED CORRIDOR @ 1/3	588.22
UNIT 6	12,627.02—
COVERED CORRIDOR @ 1/3	139.52
TOTAL . .	41,963.24 #1

PROJECT SP 1-A

ADDRESS  
SCHOOL MARIGOLD & LOMA VISTA ELEM.

10-1-88 SIGNATURE \_\_\_\_\_ DATE \_\_\_\_\_

APPLICATION NO.

### SITE SUMMARY

#### GRADES SERVED AT THIS SCHOOL

[illegible]

PREPARED BY: THOMSON & HENDRICKS /ARCHITECTS & PLANNERS/ (916) 342-5669 234 WEST THIRD STREET CHICO, CALIF. 95928

NORTH

LOMA VISTA SCHOOL PLAN

