

SIX-MONTH SURVEILLANCE

July 14, 1997

DISTRICT Chico Unified School District DATE January 12, 1996

SCHOOL Loma Vista Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
2	9" VFT	1-5	Hall, Rms 15,17,14,11,12	1-4
2	Hard plas	1-5	Rm 13 RR, Rm 16 RR, Rm 6 Women's RR, Rms 7,8,14, Boiler Room	1-4
2	Soft plas	1-5	Rm 13 RR, Rm 8 Men's RR, Rm 7,16,17	1-4
2	Soft plas	1-5	Rm 3 RR	2-4 RR has plaster chipping on sq. wall <5%
2	PW Str & Debris	55-65	Attic	2-4
2	PW Str	70-75	Boiler Room	1-4
2	PW Cnr	5-10	Boiler Room	1-4
All	Drywall	1-5 skim coat	All Non-plaster Walls and Ceilings	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE January 12, 1996

7-11-97

SCHOOL Loma Vista Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
6	12" Vft	10-15	MPR, RR, Kitchen, Classrooms, open areas, special purpose	1-4
6	Mud Jnts	Assumed	B/R room	1-4 1 Jnt P.W. around valve
6	PW Str	70-75	Attic	11
6	Tran panl	Assumed	Above all doors and B/R	1-4
6	Duct box	Assumed	B/R room	1-4
6	Boil linr	10-15	Boiler room	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)