

**BUTTE
COUNTY**
**OFFICE OF
EDUCATION**

JERRY McGUIRE
SUPERINTENDENT

Kirby L. White
Maintenance
Operations/Facilities
Supervisor
530-532-5600
FAX 530-538-5759
email:
kwhite@edison.
bcoe.butte.k12.ca.us

Board of
Education


*Bessie Hironimus
Barbara Johnson
Charles Larsen
Brenda J. McLaughlin
Robert W. Purvis
Pat Matthews Spear
Betty Vassar*

Administrative Services
1859 Bird Street
Oroville, CA 95965
(530) 538-7227
FAX: (530) 538-7218

Equal Opportunity
Employer

MEMORANDUM

TO: Marigold Portable Room 10
Corin Meester (Please distribute to the correct person at the site.)

FROM: Kirby L. White 

DATE: November 17, 2000

SUBJECT: AHERA Six - Month Surveillance

Please find attached the most recent AHERA Six-Month Surveillance for your site. The inspections were completed in November. Please review it and keep it in your site AHERA (Asbestos) file that is at or on your site.

Should you have any questions, please do not hesitate to contact me. Thank you.

SS
MO36001

cc: AHERA Site Files

Attachments



**BUTTE COUNTY OFFICE OF EDUCATION
 MARIGOLD PORTABLE ROOM 10**
 2446 Marigold Avenue Chico
 original inspection 5/89

Inspector: *Tom Smith*
 Date: *11-13-00*

LOCATION	MATERIAL	MATERIAL CLASSIFICATION	HOMOGENEOUS MATERIAL #	PERCENTAGE ASBESTOS	AMOUNT Sq. Ft./L.I. Ft.	CONDITION: CODE & COMMENT	FRIABLE YES NO
Throughout	12" vinyl floor tile	Misc		99 assumed	960 sq. ft.	(under carpeting) / - 4	YES NO

Condition Code:
 General Condition (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition (4) No (5) Yes, (If yes explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible (12) Other (explain under comments)

Must be typed and submitted with each school management plan
 (See reverse for clarification of terms)

Local Education Agency Butte County Office of Education		County Butte	
School Name Butte Co. Office of Education Portable Classroom- DSA file 4-56 DSA APPL. 02-102031 @ Shasta Elementary School			School Phone Number 530.891.3141
Address 169 Leora Court, Chico			
CDS Code 04-10041-6069256	School Enrollment ~10	Number of School Employees 1	Number of Buildings at the School 1

LEA AHERA DESIGNEE

Name Kirby L. White	Phone Number (530) 532-5600
Address 1859 Bird Street, Oroville, CA 95965	

Training Courses and Date(s) U. C. Berkeley Extension – Contractor Supervisor 93/94/95/96/97/98/99 Project Designer 93/94/95/96/97/98/99 Building Inspection 90/91/92/93/94/95/96/97/98/99 Building Inspection Mgmt. Planner 92/93/94/95/96/97/98/99	Total Training Hours 300+
--	------------------------------

MANAGEMENT PLANNER

Name Kirby L. White	Phone Number (530) 532-5600
Address 1859 Bird Street, Oroville, Ca 95965	

Application Number 15-000002006	Training Agency U. C. Berkeley Extension
------------------------------------	---




Documents Attached (Check appropriate boxes)

Record of Friable and Non-friable ACM (Form B) Physical and Hazard Assessment Friable ACM or Friable Assumed ACM (Form C)

Operations and Maintenance Program (Form D) Periodic Surveillance Plan (Form E) Re-inspection Form (Form F)

Parent/Employee Notification Plan (Form G) Resources Needed (Form H)

We certify that the general Local Education Agency (LEA) responsibilities, as stipulated by 40CFR Part 763 have been met or will be met and that this submittal includes all buildings at this school.

Management Planner Signature 	Date 8-1-00
LEA Designee Signature 	Date 8-1-00
LEA Superintendent Signature 	Date 8-1-2000

OFFICE OF LOCAL ASSISTANCE USE ONLY

Date Returned (Reasons stated below)	Date Resubmittal Received	Date Stamp
Reasons for Return		
Printed Name of Reviewer	Date	
Reviewer's Signature		

DISTRICT Chico Unified School District

DATE 8/15/00

SCHOOL Loma Vista Elementary

INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
2	9" VFT	1-5	Hall, Rms 15,17,14,11,12	1-4
2	Hard plas	1-5	Rm 13 RR, Rm 16 RR, Rm 6 Women's RR, Rms 7,8,14, Boiler Room	2-5 Boiler Room Holes Drilled (2/00) 5-1 Holes filled 1-4
2	Soft plas	1-5	Rm 13 RR, Rm 8 Men's RR, Rm 7,16,17	1-4
2	Soft plas	1-5	Rm 3 RR	2-4 RR has plaster chipping on So. wall <5% (5) (6)
2	PW Str & Debris	55-65	Attic	1-4
2	PW Str	70-75	Boiler Room	1-4
2	PW Cnr	5-10	Boiler Room	1-4 (5) (2) REPAIR ELBOW
All	Drywall	1-5 skim coat	All Non-plaster Walls and Ceilings	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE 8/15/00

SCHOOL Loma Vista Elementary INSPECTOR Robert Peters

BLDG.	HOMOG.	ASBESTOS	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
6	12" Vft	10-15		MPR, RR, Kitchen, Classrooms, open areas, special purpose	1-4
6	Mud Jnts	Assumed		B/R room	1-4 1 Jnt P.W. around valve
6	PW Str	70-75		Attic	11
6	Tran panl	Assumed		Above all doors and B/R	1-4
6	Duct box	Assumed		B/R room	1-4
6	Boil linr	10-15		Boiler room	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE February 10, 2000

SCHOOL Loma Vista Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
2	9" VFT	1-5	Hall, Rms 15,17,14,11,12	1-4
2	Hard plas	1-5	Rm 13 RR, Rm 16 RR, Rm 6 Women's RR, Rms 7,8,14, Boiler Room	2-5 Boiler Room Holes Drilled (2/00) 5-1
2	Soft plas	1-5	Rm 13 RR, Rm 8 Men's RR, Rm7,16,17	1-4
2	Soft plas	1-5	Rm 3 RR	2-4 RR has plaster chipping on So. wall <5%
2	PW Str & Debris	55-65	Attic	1-4
2	PW Str	70-75	Boiler Room	1-4
2	PW Cnr	5-10	Boiler Room	1-4
All	Drywall	1-5 skim coat	All Non-plaster Walls and Ceilings	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE February 10, 2000

SCHOOL Loma Vista Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
6	12" Vft	10-15	MPR, RR, Kitchen, Classrooms, open areas, special purpose	1-4
6	Mud Jnts	Assumed	B/R room	1-4 1 Jnt P.W. around valve
6	PW Str	70-75	Attic	11
6	Tran panl	Assumed	Above all doors and B/R	1-4
6	Duct box	Assumed	B/R room	1-4
6	Boil linr	10-15	Boiler room	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)