

**BUTTE
COUNTY**
**OFFICE OF
EDUCATION**

JERRY McGUIRE
SUPERINTENDENT

Kirby White
Maintenance & Operations
Facilities Planner
(916) 538-2084


Board of
Education

*Brenda J. Brimhall
Frank Gladen
Bessie Hironimus
Erwin M. Howlett
James F. Lindsey
Brent Moore
Betty Vassar*

Business Services
1859 Bird Street
Oroville, CA 95965
(916) 538-7227
FAX: (916) 538-7218
*An Equal Opportunity
Employer*

MEMORANDUM

To: ~~Sally Bonavito~~
Marigold Portable, Room 10

From: Kirby L. White 

Date: December 2, 1994

Subject: 6 Month AHERA Surveillance Report

Please find attached the most recent 6 month AHERA surveillance report for your site. Please include this in the rear most section of your AHERA Inspection and Management Plan.

Thank you for your assistance and have a happy holiday season !!

jm
AA11945

cc: AHERA Master File

BUTTE COUNTY OFFICE OF EDUCATION
 MARIGOLD PORTABLE ROOM 10
 2446 MARIGOLD AVENUE CHICO CA.

INSPECTOR: *Tom Smith*
 DATE OF INSPECTION: *11-30-94*

12-13-94

LOCATION	MATERIAL	MATERIAL CLASSIFICATION	HOMOGENEOUS MATERIAL #	PERCENTAGE ASBESTOS ASSUMED	AMOUNT Sq. Ft./11 Ft. 960 SQ. Ft.	CONDITION: CODE & COMMENT	FRIABLE YES NO
THROUGHOUT	12" VINYL FLOOR TILE	MISC	99			(UNDER CARPETING) / 4	

CONDITION CODE:
 General Condition:
 Change in Condition:
 Abated:
 Miscellaneous:

(1) Good
 (4) No
 (6) Repaired
 (11) Inaccessible, no inspection data

(2) Damaged
 (5) Yes, (if Yes, explain under comments)
 (7) Removed
 (12) Other (explain under comments)

(3) Significantly Damaged (25% or More)
 (8) Encapsulated
 (9) Enclosed
 (10) Isolated & Restricted


NF

BUTTE
COUNTY
OFFICE OF
EDUCATION

JERRY McGUIRE
SUPERINTENDENT

MEMORANDUM

To: Corin Meester
Marigold Portable - Room 10

From: Kirby L. White 

Date: May 19, 1994

Subject: 6 Month AHERA Surveillance Report

Please find attached the most recent 6 month AHERA surveillance report for your site. Please include this in the rear-most section of your AHERA inspection and management plan.

Thank you for your assistance.

jm
AA21934

Attachment

cc: AHERA Master File

Kirby White
Maintenance & Operations
Facilities Planner
(916) 538-2084

Board of
Education

Brenda J. Brimhall
Frank Gladen
Bessie Hironimus
Erwin M. Howlett
James F. Lindsey
Brent Moore
Betty Vassar

Business Services
1859 Bird Street
Oroville, CA 95965
(916) 538-7227
FAX: (916) 538-7218
*An Equal Opportunity
Employer*

BUTTE COUNTY OFFICE OF EDUCATION INSPECTOR: Top Smith
 MARIGOLD PORTABLE ROOM 10 DATE OF INSPECTION: 5-18-94
 2446 MARIGOLD AVENUE CHICO CA.

LOCATION	MATERIAL	MATERIAL CLASSIFICATION	HOMOGENEOUS MATERIAL #	PERCENTAGE ASBESTOS ASSUMED	AMOUNT Sq. Ft./ LI. FL. 960 SQ. FT.	CONDITION: CODE & COMMENT	FRIABLE YES NO
THROUGHOUT	12" VINYL FLOOR TILE	MISC	99	ASSUMED		(UNDER CARPETING) /	1

CONDITION CODE:
 General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or More)
 Change in Condition: (4) No (5) Yes, (if Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection da(12) Other (explain under comments)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 20, 1994

SCHOOL Marigold Elementary INSPECTOR Ron Jones

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
1	Tran panl	Assumed	Both boilers in Main B/R	1-4
1	9" VFT	1-5%	Room 12 & rest of wing	1-4
1	PW Str	60-65%	B/R Room	1-4
3	9" VFT	1-5%	Room 17 & rest of unit	1-4
3	Tran panl	Assumed	Above glass panels	1-4
4	9" VFT	1-5%	Lib/staff & classrooms	1-4 Carpeted
5	9" VFT	1-5%	Kit, MPR, AV store	1-4
5	Cold box ceiling	30-35%	Cold Box	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 1, 1994

SCHOOL Marigold Elementary INSPECTOR Ron Jones

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
1	Tran panl	Assumed	Both boilers in Main B/R	1-4
1	9" VFT	1-5%	Room 12 & rest of wing	1-4
1	PW Str	60-65%	B/R Room	1-4
3	9" VFT	1-5%	Room 17 & rest of unit	1-4
3	Tran panl	Assumed	Above glass panels	1-4
4	9" VFT	1-5%	Lib/staff & classrooms	1-4 Carpeted
5	9" VFT	1-5%	Kit, MPR, AV store	1-4
5	Cold box ceiling	30-35%	Cold Box	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)