

July 16, 1997
~~January 4, 1996~~

DISTRICT Chico Unified School District DATE July 16, 1997

SCHOOL Marigold Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
1	Tran panl	Assumed	Both boilers in Main B/R	1-4
1	9" VFT	1-5%	Room 12 & rest of wing	1-4
1	PW Str	60-65%	B/R Room	1-4
3	9" VFT	1-5%	Room 17 & rest of unit	1-4
3	Tran panl	Assumed	Above glass panels	1-4
4	Tran panl	Assumed	Above windows	1-4
4	9" VFT	1-5%	Lib/staff & classrooms	1-4 Carpeted
5	9" VFT	1-5%	Kit, MPR, AV store, Fac. RR	1-4
5	Cold box ceiling	30-35%	Cold Box	1-4
5	Plaster	Assumed	Kitchen & Restroom	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)
 SIX-MONTH SURVEILLANCE Page 2 of 2

DISTRICT Chico Unified School District DATE January 4, 1996 7-11-97

SCHOOL Marigold Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
All	Drywall	1-5 skim coat	All Non-Plaster Walls and Ceilings	1-4
Port	12" VFTs	Assumed	All Non-Certified Portables	1-4
Port	Linoleum	Assumed	Restroom Portables	1-4
Port	Drywall	Assumed	All Non-Certified Portables (behind tagboard)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 5, 1997

SCHOOL Marigold Elementary INSPECTOR Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
All	Drywall	1-5 skim coat	All Non-Plaster Walls and Ceilings	1-4
Port	12" VFTs	Assumed	All Non-Certified Portables	1-4
Port	Linoleum	Assumed	Restroom Portables	1-4
Port	Drywall	Assumed	All Non-Certified Portables (behind tagboard)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)