

BUTTE
COUNTY
OFFICE OF
EDUCATION

JERRY McGUIRE
SUPERINTENDENT

Kirby L. White
Maintenance
Operations/Facilities
Supervisor
530-538-2084
FAX 530-538-7218
email:
kwhite@edison.
coe.butte.k12.ca.us

Board of
Education

Bessie Hironimus
Barbara Johnson
Charles Larsen
Brenda J. McLaughlin
Robert W. Purvis
Pat Matthews Spear
Betty Vassar

Administrative Services
1859 Bird Street
Oroville, CA 95965
(530) 538-7227
FAX: (530) 538-7218

Equal Opportunity
Employer

MEMORANDUM

TO: Corin Meester & Sondra Wesner, Marigold Port
FROM: Kirby L. White
DATE: November 17, 1999
SUBJECT: AHERA Six-Month Surveillance

Please find attached the most recent AHERA Six-Month Surveillance for your site. The inspections were completed in November. Please review it and keep it in your site AHERA (Asbestos) file.

Should you have any questions, please do not hesitate to contact me. Thank you.

lh
MO38990

cc: AHERA Site Files

Attachments

**BUTTE
COUNTY
OFFICE OF
EDUCATION**

**JERRY McGUIRE
SUPERINTENDENT**

Kirby L. White
Maintenance
Operations/Facilities
Supervisor
916-538-2084
FAX 916-538-7218
email:
kwhite@ben.
bcoe.butte.k12.ca.us

Board of
Education


*Bessie Hironimus
Barbara Johnson
Charles Larsen
Brenda J. McLaughlin
Robert W. Purvis
Pat Matthews Spear
Betty Vassar*

Administrative Services
1859 Bird Street
Oroville, CA 95965
(530) 538-7227
FAX: (530) 538-7218

Equal Opportunity
Employer

Don't
11-22-99
**LOMA VISTA SCHOOL
Corin Meester
Sondra Wesner**

MEMORANDUM

TO: All Cabinet, Principals and Site Supervisors
FROM: Kirby L. White 
DATE: August 13, 1999
SUBJECT: AHERA Annual Notification

Please find attached the "AHERA Annual Notification". It is required that this notice be provided to inform workers, building occupants, and parents of the items required in the "Asbestos Hazard Emergency Response Act". Please distribute this notice to all parents, staff, and building occupants. After distribution, retain a copy of this letter and the notification in the management plan that you retain on site. Also, please post this notice in a visible location.

Should you have any questions, please do not hesitate to contact me. Thank you for your assistance.

cc: AHERA Master File

ss

MO7990

Attachment

**BUTTE
COUNTY
OFFICE OF
EDUCATION**

**JERRY McGUIRE
SUPERINTENDENT**

Kirby L. White
Maintenance
Operations/Facilities
Supervisor
916-538-2084
FAX 916-538-7218
email:
kwhite@ben.
bcoe.butte.k12.ca.us

Board of
Education

*Bessie Hironimus
Barbara Johnson
Charles Larsen
Brenda J. McLaughlin
Robert W. Purvis
Pat Matthews Spear
Betty Vassar*

Administrative Services
1859 Bird Street
Oroville, CA 95965
(530) 538-7227
FAX: (530) 538-7218

Equal Opportunity
Employer

MEMORANDUM

TO: Parents, PTA, Teachers and Staff
FROM: Kirby L. White (9)
DATE: August 13, 1999
SUBJECT: Site Asbestos Inspections and Management Plans To
Comply With The Asbestos Hazard Emergency Response
Act (AHERA).

Pursuant to the EPA's Asbestos Hazard Emergency Response Act (AHERA), all Butte County Office of Education facilities have been inspected for asbestos containing materials and management plans for the control of asbestos have been developed. The management plan includes the inspections, response actions, post response actions activities, periodic re-inspections, and operations/maintenance activities.

Also included are the names of the inspector, the management planner, forms in the management plan required by the Office of Local Assistance (now the Office of Public School Construction) and the documentation of all significant events including any fiber release episodes. All data relating to asbestos activities will be entered into the management plan within 30 days of the event.

A copy of the entire plan is available in the county office and at the office of the designee. Individual plans are available at the office at each site. Annual notifications will be made in the Fall of each year.

The management plan(s) will be available for review during regular business hours. A nominal duplicating fee may be charged for those who wish to obtain copies of the plans.

The last periodic (six-month) surveillance was performed during May and June of this year and another is scheduled for November. A small asbestos repair project took place in the Maintenance, Operation/Facilities Office, 1859 Bird Street, Oroville, in December to repair a very small damaged section of asbestos containing pipe insulation. Small sections of asbestos may be removed throughout the year on regular maintenance and operations projects as necessary.

ss
MO8990

cc: AHERA Master File

DISTRICT Chico Unified School District DATE August 11, 1999

SCHOOL Marigold Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
1	Tran panl	Assumed	Both boilers in Main B/R	1-4
1	9" VFT	1-5%	Room 12 & rest of wing	1-4
1	PW Str	60-65%	B/R Room	1-4
3	9" VFT	1-5%	Room 17 & rest of unit	1-4
3	Tran panl	Assumed	Above glass panels	1-4
4	Tran panl	Assumed	Above windows	1-4
4	9" VFT	1-5%	Lib/staff & classrooms	1-4 Carpeted
5	9" VFT	1-5%	Kit, MPR, AV store, Fac. RR	1-4
5	Cold box ceiling	30-35%	Cold Box	1-4
5	Plaster	Assumed	Kitchen & Restroom	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE August 11, 1999

SCHOOL Marigold Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
All	Drywall	1-5 skim coat	All Non-Plaster Walls and Ceilings	1-4
Port	12" VFTs	Assumed	All Non-Certified Portables	1-4
Port	Linoleum	Assumed	Restroom Portables	1-4
Port	Drywall	Assumed	All Non-Certified Portables (behind tagboard)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE 2/24/99

SCHOOL Marigold Elementary INSPECTOR Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
1	Tran panl	Assumed	Both boilers in Main B/R	1-4
1	9" VFT	1-5%	Room 12 & rest of wing	1-4
1	PW Str	60-65%	B/R Room	1-4
3	9" VFT	1-5%	Room 17 & rest of unit	1-4
3	Tran panl	Assumed	Above glass panels	1-4
4	Tran panl	Assumed	Above windows	1-4
4	9" VFT	1-5%	Lib/staff & classrooms	1-4 Carpeted
5	9" VFT	1-5%	Kit, MPR, AV store, Fac. RR	1-4
5	Cold box ceiling	30-35%	Cold Box	1-4
5	Plaster	Assumed	Kitchen & Restroom	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

POSTED
Ward 08

DISTRICT Chico Unified School District

DATE

2/24/99

SCHOOL Marigold Elementary

INSPECTOR Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
All	Drywall	1-5 skim coat	All Non-Plaster Walls and Ceilings	1-4
Port	12" VFTs	Assumed	All Non-Certified Portables	1-4
Port	Linoleum	Assumed	Restroom Portables	1-4
Port	Drywall	Assumed	All Non-Certified Portables (behind tagboard)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)