

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 21, 1994

SCHOOL McManus Elementary INSPECTOR Ron Jones *RJ*

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	Wall plas	5-10	Kitchen, Admin., halls	7 July '93
A	9" VFT	5-10	Hall, Kitchen, MPR	7 July '93
A	TOC	1-5	Admin. office, hall, kitchen, attic	7 July '93
A	PW & Debr	10-15	Admin attic above men's rr	7 July '93
A	PW Str	40-45	Kitchen attic	7 July '93
A	Air cell	Assumed	Custodial closet	7 July '93
A	Tran pipe	Assumed	Custodial closet & attic	7
B	Wall plas	5-10	RR, hall area, boiler room	7 July '93
B	TOC	1-5	Custodial room & hall	7
B	Mud Jnt	25-30	Main boiler room	7
B	Counter-top lino	1-5	Classroom areas	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 21, 1994

SCHOOL McManus Elementary INSPECTOR Ron Jones

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	9" VFT	1-5	Rm 9 & rest of wing	7 July '93
B	Air Cell	Assumed	Main B/R room, custodial room attic	1-4
B	Tank Wrap	Assumed	Main B/R room	7 July '93
B	B/R air cell	Assumed	Main B/R room	1-4
C	Duct wrap	70-75	Sm B/R room, attic	7 July '93
C	Wall plas	5-10	Old RR, B/R room	Retested - no asbestos
C	9" VFT	5-10	Rm 2 and rest of wing	7 July '93
D	Wall plas	5-10	Cust. rm, hall, RR area	1-4
D	9" VFT	5-10	Hall, classroom areas	1-4
D	TOC	1-5	Hall & custodial room	1-4
D	PW	20-25	Custodial room	1-4 PW Str-fiber., PW Cnr-ACM

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 6, 1994
 SCHOOL McManus Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	Wall plas	5-10	Kitchen, Admin., halls	7 July '93
A	9" VFT	5-10	Hall, Kitchen, MPR	7 July '93
A	TOC	1-5	Admin. office, hall, kitchen, attic	7 July '93
A	PW & Debr	10-15	Admin attic above men's rr	7 July '93
A	PW Str	40-45	Kitchen attic	7 July '93
A	Air cell	Assumed	Custodial closet	7 July '93
A	Tran pipe	Assumed	Custodial closet & attic	7
B	Wall plas	5-10	RR, hall area, boiler room	7 July '93
B	TOC	1-5	Custodial room & hall	7
B	Mud Jnt	25-30	Main boiler room	7
B	Counter-top lino	1-5	Classroom areas	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 6, 1994

SCHOOL McManus Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	9" VFT	1-5	Rm 9 & rest of wing	7 July '93
B	Air Cell	Assumed	Main B/R room, custodial room attic	1-4
B	Tank Wrap	Assumed	Main B/R room	7 July '93
B	B/R air cell	Assumed	Main B/R room	1-4
C	Duct wrap	70-75	Sm B/R room, attic	7 July '93
C	Wall plas	5-10	Old RR, B/R room	Retested - no asbestos
C	9" VFT	5-10	Rm 2 and rest of wing	7 July '93
D	Wall plas	5-10	Cust. rm, hall, RR area	1-4
D	9" VFT	5-10	Hall, classroom areas	1-4
D	TOC	1-5	Hall & custodial room	1-4
D	PW	20-25	Custodial room	1-4 PW Str-fiber., PW Cnr-ACM

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)