



Forensic Analytical
Analytical Report

Final FAX

Bulk Asbestos Analysis

(EPA Method 600/R-93-116)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B052339
Date Received: 07/03/03
Date Analyzed: 07/07/03
Date Printed: 07/07/03

Job ID / Site: Marsh Junior High School

FA SI Job ID: 2921-67

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
MJ-1	10248248						
		Layer: White Non-Fibrous Material			ND		
		Layer: Yellow Mastic			ND		

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (Trace%) Fibrous Glass (40%)

MJ-1	10248249						
		Layer: Off-White Tile			ND		
		Layer: Yellow Mastic			ND		

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (Trace%)

*C: Mary
Kip
Bob M.
Rob
bindles (3)
dill*

Jim Flores

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.

2921-67

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

July 2, 2003

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Marsh Junior High School

To Whom It May Concern:

Please test the enclosed wall cover and mastic sample and the floor tile and mastic sample from Marsh Junior High School for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Marsh Junior High School
Location: Room 20, Wall Cover & Mastic
Date Sampled: July 2, 2003
Number of Samples: One (#MJ-1)

Location: Room 20, Floor Tile & Mastic
Date Sampled: July 2, 2003
Number of Samples: One (#MJ-2)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures



BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE: 7/2/03
	Circle the Method and Turn Around Time	Results Needed:
	24 hr/12hr/24hr/48hr/Ext	
	PLM: Standard / Point Count	Gravimetry Prep
CONTACT: ROIS PETERS		TEM: QUAL. / QUANT. / WATER
P.O.#	JOB #	AA/Flame AA/Furnace ICP
SITE: MARSH JR.		METALS:

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
MJ-1	7/2	WALL COVER + MASTIC RM 30
MJ-2	7/2	FLOOR TILE + MASTIC RM 30

Sampled by: ROIS PETERS	Date: 7/2/03	Time: 12:25
Relinquished by:	Received By:	
Date/Time:	Date/Time:	
	Sealed Condition (circle one) YES / NO	
Relinquished by:	Received By: [Signature] 7/3/03 11:00am	
Date/Time:	Date/Time:	
	Sealed Condition (circle one) YES / NO	



Forensic Analytical

BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE: 7/2/03
	Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	
	PLM: <u>Standard</u> / Point Count	Results Needed: Gravimetry Prep
CONTACT: <u>ROB PETERS</u>		TEM: QUAL / QUANT. / WATER
P.O.#	JOB #	AA/Flame AA/Furnace ICP
SITE: <u>TRASH JR.</u>		METALS:

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
MS-1	7/2	WALL COVER + MASTIC RT 20
MS-2	7/2	FLOOR TILE + MASTIC RT 20

Sampled by: <u>ROB PETERS</u>	Date: <u>7/2/03</u> Time: <u>12:25</u>
Relinquished by:	Received By:
Date/Time:	Date/Time:
Inquished by:	Received By: <u>[Signature]</u> <u>7/3/03 11:00am</u>
Date/Time:	Date/Time:
Sealed Condition (circle one) YES / NO	Sealed Condition (circle one) YES / NO

2921-67

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

July 2, 2003

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Marsh Junior High School

To Whom It May Concern:

Please test the enclosed wall cover and mastic sample and the floor tile and mastic sample from Marsh Junior High School for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Marsh Junior High School
Location: Room 20, Wall Cover & Mastic
Date Sampled: July 2, 2003
Number of Samples: One (#MJ-1)

Location: Room 20, Floor Tile & Mastic
Date Sampled: July 2, 2003
Number of Samples: One (#MJ-2)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B052339
Date Received: 07/03/03
Date Analyzed: 07/07/03
Date Printed: 07/07/03
First Reported: 07/07/03

Job ID / Site: Marsh Junior High School

FASI Job ID: 2921-67

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------


MJ-1	10248248						
Layer: White Non-Fibrous Material							ND
Layer: Yellow Mastic							ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (Trace%) Fibrous Glass (40%)
 Comment: Collected on 07/02/2003

MJ-2	10248249						
Layer: Off-White Tile							ND
Layer: Yellow Mastic							ND

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (Trace%)
 Comment: Collected on 07/02/2003

*C: Mary
Kip
Rob
Bob M.
Smiley (3)
Aler*



Jim Flores

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

All analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Kip Hansen

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B061346
Date Received: 05/19/04
Date Analyzed: 05/20/04
Date Printed: 05/20/04
First Reported: 05/20/04

Job ID/Site: Marsh Jr. High School - Relo 26, East Wall, North End

FASI Job ID: 2921-73

Sample ID	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
1	10324651						
Layer: White Drywall			ND				

Total Composite Values of Fibrous Components: Asbestos (ND)
 Cellulose (20 %) Fibrous Glass (5 %)
 Comment: Collected on 05/18/2004

*Mary Beary
 C. Kip Hansen
 Bob Michael
 Sanchez (3)
 JEL*

Jim Flores

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.