

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE Dec. 5, 1990

SCHOOL Neal Dow Elementary INSPECTOR Robert Peters R.P.

BLDG.	HOMOG. MAT. #	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Admin. area	5 carpeted
			Classrooms & Hallway	1 - 4
A	Lino	5-10	Nurses Office RR	1 - 4
A	TSI	25-30	Admin. Attic	1 (needs label) 4
A	PW Cnr	25-30	Admin. Attic Hallway	5 - 2 (1 piece cut out, open end, & small amt of debris
A	PW Str	35-40	Admin. Attic Hallway	1 - 4
A	Large PW Str	35-40	Boiler Room	1 - 4
A	Small PW Str	30-55	Boiler Room	1 - 4
A	Breeching	20-30	Boiler Room	1 - 4
A	Fire Door	Assumed	Boiler Room	1 - 4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE Dec. 5, 1990

SCHOOL Neal Dow Elementary INSPECTOR Robert Peters

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS  
 BLDG. MAT.#

B	2x4 FCP	5-10	Round House Quad	(2) (5) 3 missing/1 broken in half, 7 water damaged
B	T-O-C	1-5	Round House Quad Center	1 - 4
B	Mud Jnt	25-30	Attic	1 - 4
C	9" VFT	1-5	Kindergarten	1 - 4
C	T-O-C	1-5	Center of Building	1 - 4
All	Tran panl	Assumed	Above Windows	1 - 4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE July 6, 1990

SCHOOL Neal Dow Elementary INSPECTOR Robert Peters R.P.

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Admin. area	1
			Classrooms & Hallway	1
A	Lino	5-10	Nurses Office RR	1
A	TSI	25-30	Admin. Attic	1 (needs label)
A	PW Cnr	25-30	Admin. Attic Hallway	1
A	PW Str	35-40	Admin. Attic Hallway	1
A	Large PW Str	35-40	Boiler Room	1
A	Small PW Str	30-55	Boiler Room	1
A	Breeching	20-30	Boiler Room	1
A	Fire Door	Assumed	Boiler Room	1

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE July 6, 1990

SCHOOL Neal Dow Elementary INSPECTOR Robert Peters *R.P.*

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
B	2x4 FCP	5-10	Round House Quad	(2) 3 missing/1 broken in half, 5 water damaged
B	T-O-C	1-5	Round House Quad Center	(1)
B	Mud Jnt	25-30	Attic	(1)
C	9" VFT	1-5	Kindergarten	(1)
C	T-O-C	1-5	Center of Building	(1)
All	Tran panl	Assumed	Above Windows	(1)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED  
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)