

July 14, 1997

DISTRICT Chico Unified School District DATE January 6, 1996

SCHOOL Neal Dow Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT	1-5	Admin. area	1 - 4 carpeted
A	9" VFT	1-5	Classrooms & Hallway	1 - 4
A	Lino	5-10	Nurses Office RR	1 - 4
A	TSI	25-30	Admin. Attic	1 (needs label) 4
A	PW Cnr	25-30	Admin. Attic Hallway	1 - 4
A	PW Str	35-40	Admin. Attic Hallway	1 - 4
A	Large PW Str	35-40	Boiler Room	1 - 4
A	Small PW Str	30-55	Boiler Room	1 - 4
A	Breeching	20-30	Boiler Room	1 - 4
A	Fire Door	Assumed	Boiler Room	1 - 4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)  
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)  
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED



ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)