

DISTRICT Chico Unified School District DATE August 11, 1999

SCHOOL Nord Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT Bn	1-5	Rooms 3 & 4	(7) Removed
A	PW Cnrs TS1	35-45	Boiler room	(7) Removed
A	Pipewrap	35-45	Boiler room	(7) Removed
B	9" VFT Dark Grey	1-5	MPR & room 3	(1) (4)
B	PW. Str	50-60	Boiler/Storage #2	(7) Removed
B	Mud Jnt	35-45	Boiler/Storage #2	(7) Removed
B	Wall plas	1-5	Boiler/Storage #2	(1) (4)
B	Wall plas	1-5	Kitchen	(2)(4) around door casing (8/99) 5-1 Repaired
(P)			Portable	No letter

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE 2/22/99

SCHOOL Nord Elementary INSPECTOR Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT Bn	1-5	Rooms 3 & 4	(7) Removed
A	PW Cnrs TS1	35-45	Boiler room	(7) Removed
A	Pipewrap	35-45	Boiler room	(7) Removed
B	9" VFT Dark Grey	1-5	MFR & room 3	(1) (4)
B	PW. Str	50-60	Boiler/Storage #2	(7) Removed
B	Mud Jnt	35-45	Boiler/Storage #2	(7) Removed
B	Wall plas	1-5	Boiler/Storage #2	(1) (4)
B	Wall plas	1-5	Kitchen	(2) (4) around door casing
(P)			Portable	No letter

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

