



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones


2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B022457
Date Received: 08/21/00
Date Analyzed: 08/21/00
Date Printed: 08/21/00
First Reported: 08/21/00

Job ID / Site: Various Sites, Window Putty Samples

FASI Job ID: 2921-27

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
1	10043379						
Layer: Off-White Non-Fibrous Material					ND		
Total Composite Values of Fibrous Components:		Asbestos:(ND)		Cellulose (Trace%)		Fibrous Glass (ND)	
Comment: Collected on 8/15/00							
2	10043380						
Layer: Beige Non-Fibrous Material					ND		
Layer: Paint					ND		
Total Composite Values of Fibrous Components:		Asbestos:(ND)		Cellulose (Trace%)		Fibrous Glass (ND)	
Comment: Collected on 8/15/00							
3	10043381						
Layer: Grey Non-Fibrous Material					ND		
Layer: Paint					ND		
Total Composite Values of Fibrous Components:		Asbestos:(ND)		Cellulose (Trace%)		Fibrous Glass (ND)	
Comment: Collected on 8/15/00							
4	10043382						
Layer: Green Non-Fibrous Material		Chrysotile			5 %		
Layer: Paint					ND		
Total Composite Values of Fibrous Components:		Asbestos:(5%)		Cellulose (Trace%)		Fibrous Glass (ND)	
Comment: Collected on 8/14/00							
5	10043383						
Layer: Tan Non-Fibrous Material					ND		
Layer: Paint					ND		
Total Composite Values of Fibrous Components:		Asbestos:(ND)		Cellulose (Trace%)		Fibrous Glass (ND)	
Comment: Collected on 8/14/00							
6	10043384						
Layer: Tan Non-Fibrous Material		Chrysotile			3 %		
Layer: Paint					ND		
Total Composite Values of Fibrous Components:		Asbestos:(3%)		Cellulose (Trace%)		Fibrous Glass (ND)	
Comment: Collected on 8/14/00							





Forensic Analytical

San Francisco • Los Angeles • Minneapolis / St. Paul

Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Ron Jones

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B022457
Date Received: 08/21/00
Date Analyzed: 08/21/00
Date Printed: 08/21/00
First Reported: 08/21/00

Job ID / Site: Various Sites, Window Putty Samples

FASI Job ID: 2921-27

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
7	10043385						
		Chrysotile	3 %				
			ND				

Total Composite Values of Fibrous Components: **Asbestos:(3%)** Cellulose (Trace%) Fibrous Glass (ND)
Comment: Collected on 8/14/00

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from the client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

2921-217

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3095
Fax: (530) 891-3190

Chico Unified School District

August 17, 2000

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Window Putty Samples Listed Below

To Whom It May Concern:

Please test the enclosed window putty samples from the sites listed above for asbestos and lead. Please fax the results to me as soon as soon as they are available. My fax number is (530) 891-3190.

Site Sampled: Stock Window Putty
Location: Warehouse
Date Sampled: August 15, 2000
Number of Samples: One

Site Sampled: Sierra View Elementary
Location: Unit B Window Putty
Date Sampled: August 14, 2000
Number of Samples: One

Site Sampled: McManus Elementary School
Location: Unit C Window Putty
Date Sampled: August 15, 2000
Number of Samples: One

Site Sampled: Rosedale Elementary
Location: Unit A Window Putty
Date Sampled: August 10, 2000
Number of Samples: One

Site Sampled: Nord Elementary School
Location: Unit A Window Putty
Date Sampled: August 15, 2000
Number of Samples: One

Site Sampled: Parkview Elementary
Location: Unit B Window Putty
Date Sampled: August 14, 2000
Number of Samples: One

Site Sampled: Chapman Elementary School
Location: Unit B Window Putty
Date Sampled: August 14, 2000
Number of Samples: One

All samples taken by Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg

BULK SAMPLE REQUEST FORM



CLIENT NAME & ADDRESS: Chico Unified School District Maintenance & Operations 2455 Carmichael Drive Chico, CA 95928		PHONE: 530 891-3195	DATE: 8/17
		Circle the Method and Turn Around Time ___hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM: Standard / Point Count	Gravimetry Prep
CONTACT: Rob Peters		TEM: QUAL / QUANT. / WATER	
P.O.#	JOB #	AA/Flame AA/Furnace ICP	
		METALS: _____	
SITE: Various - See Below			
SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION	
1	8/15	WINDOW PUTTY FROM STOCK	
2	8/15	MCMANUS UNITS WINDOW PUTTY	
3	8/15	NOIRD UNITS WINDOW PUTTY	
4	8/14	CHAPMAN UNITS WINDOW PUTTY	
5	8/14	SIERRA VIEW UNITS WINDOW PUTTY	
6	8/10	ROSEDALE UNITS WINDOW PUTTY	
7	8/14	PARKVIEW UNITS WINDOW PUTTY	
Please test all samples for both LEAD and ASBESTOS			
Sampled by: ROBERT PETERS		Date:	Time:
Relinquished by:		Received By: Vanessa M. Thomas	
Date/Time:		Date/Time: 8-21-00 9:48am	
		Sealed Condition (circle one) YES / NO	
Relinquished by:		Received By:	
Date/Time:		Date/Time:	
		Sealed Condition (circle one) YES / NO	

DISTRICT Chico Unified School District

DATE 8/10/00

SCHOOL Nord Elementary

INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT Bn	1-5	Rooms 3 & 4	(7) Removed
A	PW Cnrs TS1	35-45	Boiler room	(7) Removed
A	Pipewrap	35-45	Boiler room	(7) Removed
B	9" VFT Dark Grey	1-5	MPR & room 3	(1) (4)
B	PW. Str	50-60	Boiler/Storage #2	(7) Removed
B	Mud Jnt	35-45	Boiler/Storage #2	(7) Removed
B	Wall plas	1-5	Boiler/Storage #2	(1) (4)
B	Wall plas	1-5	Kitchen	(2)(4) around door casing (8/99) 5-1 Repaired (1)(4)
(P)			Portable	No letter

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE February 3, 2000

SCHOOL Nord Elementary INSPECTOR Robert Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	9" VFT Bn	1-5	Rooms 3 & 4	(7) Removed
A	PW Cnrs TS1	35-45	Boiler room	(7) Removed
A	Pipewrap	35-45	Boiler room	(7) Removed
B	9" VFT Dark Grey	1-5	MPR & room 3	(1) (4)
B	PW. Str	50-60	Boiler/Storage #2	(7) Removed
B	Mud Jnt	35-45	Boiler/Storage #2	(7) Removed
B	Wall plas	1-5	Boiler/Storage #2	(1) (4)
B	Wall plas	1-5	Kitchen	(2)(4) around door casing (8/99) 5-1 Repaired
(P)			Portable	No letter

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)