



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Robert Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B040512
Date Received: 06/11/02
Date Analyzed: 06/12/02
Date Printed: 06/12/02
First Reported: 06/12/02

Job ID / Site: JOB: Nord Elementary School

FASI Job ID: 2921-43

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
1	10164885	Layer: Stones	ND	Layer: Black Tar	ND	Layer: Black Felt	ND


Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (40%)
 Comment: Collected on 06/10/2002

2	10164886	Layer: Black Tar with Stones	ND	Layer: Black Felt	ND	Layer: Black Tar	ND	Layer: Black Felt	ND	Layer: Black Tar	ND	Layer: Black Felt	ND
---	----------	------------------------------	----	-------------------	----	------------------	----	-------------------	----	------------------	----	-------------------	----

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (15%) Fibrous Glass (45%)
 Comment: Bulk complex sample. Collected on 06/10/2002

3	10164887	Layer: Black Tar with Stones	ND	Layer: Black Felt	ND	Layer: Black Tar	ND	Layer: Black Felt	ND	Layer: Black Tar	ND	Layer: Black Felt	ND	Layer: Black Tar	ND	Layer: Black Felt	ND
---	----------	------------------------------	----	-------------------	----	------------------	----	-------------------	----	------------------	----	-------------------	----	------------------	----	-------------------	----

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (15%) Fibrous Glass (45%)
 Comment: Bulk complex sample. Collected on 06/10/2002





Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Robert Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B040512
Date Received: 06/11/02
Date Analyzed: 06/12/02
Date Printed: 06/12/02
First Reported: 06/12/02

Job ID / Site: JOB: Nord Elementary School

FASI Job ID: 2921-43

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

All results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on the report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

June 10, 2002

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Pleasant Valley High School Auto Shop Roof Samples
Bidwell Junior High Office Roof Samples
Nord Elementary Room 4 Roof Samples

To Whom It May Concern:

Please test the enclosed roof samples from the aforementioned schools for asbestos. We would like a 24-hour turn around on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Pleasant Valley High School
Location: Auto Shop Roof
Date Sampled: June 10, 2002
Number of Samples: Five (5)


Site Sampled: Bidwell Junior High School
Location: Office Roof
Date Sampled: June 10, 2002
Number of Samples: Three (3)

Site Sampled: Nord Elementary School
Location: Room 4
Date Sampled: June 10, 2002
Number of Samples: Three (3)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Robert Peters

RP:dlg
Enclosures





BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 2921 ⁴³ Chlco Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE:
	Circle the Method and Turn Around Time ___hr/12hr/24hr/48hr/Ext	Results Needed:
	PLM: Standard / Point Count	Gravimetry Prep
	TEM: QUAL. / QUANT. / WATER	
CONTACT: ROIS P	P.O.#	JOB #
SITE: NO 12 D.	AA/Flame AA/Furnace ICP METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1	6/10	WEST BAY OF ROOF
2	6/10	MIDDLE BAY OF ROOF
3	6/10	EAST BAY OF ROOF

Sampled by:	Date:	Time:
Relinquished by: ROIS P	Received By:	Date/Time:
Date/Time: 6/10 2:30	Sealed Condition (circle one) YES / NO	1040 a
Relinquished by:	Received By:	Date/Time:
Date/Time:	Sealed Condition (circle one) YES / NO	



Bulk Asbestos Analysis

(EPA Method 600/R-93-116)

Chico Unified School Dist
Robert Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B040512
Date Received: 06/11/02
Date Analyzed: 06/12/02
Date Printed: 06/12/02

Job ID / Site: JCB: Nord Elementary School

FASI Job ID: 2921-43

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
1	10164885						
		Layer: Stones	ND				
		Layer: Black Tar	ND				
		Layer: Black Felt	ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (40%)

2	10164886						
		Layer: Black Tar with Stones	ND				
		Layer: Black Felt	ND				
		Layer: Black Tar	ND				
		Layer: Black Felt	ND				
		Layer: Black Tar	ND				
		Layer: Black Felt	ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (15%) Fibrous Glass (45%)

3	10164887						
		Layer: Black Tar with Stones	ND				
		Layer: Black Felt	ND				
		Layer: Black Tar	ND				
		Layer: Black Felt	ND				
		Layer: Black Tar	ND				
		Layer: Black Felt	ND				
		Layer: Black Tar	ND				
		Layer: Black Felt	ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (15%) Fibrous Glass (45%)



Bulk Asbestos Analysis

(EPA Method 600/R-93-116)

Chico Unified School Dist
Robert Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B040512
Date Received: 06/11/02
Date Analyzed: 06/12/02
Date Printed: 06/12/02

Job ID / Site: JCB: Nord Elementary School

FASI Job ID: 2921-43

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
---------------	------------	---------------	------------------	---------------	------------------	---------------	------------------

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification (LOQ) = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

All results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

June 10, 2002

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Pleasant Valley High School Auto Shop Roof Samples
Bidwell Junior High Office Roof Samples
Nord Elementary Room 4 Roof Samples

To Whom It May Concern:

Please test the enclosed roof samples from the aforementioned schools for asbestos. We would like a 24-hour turn around on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Pleasant Valley High School
Location: Auto Shop Roof
Date Sampled: June 10, 2002
Number of Samples: Five (5)


Site Sampled: Bidwell Junior High School
Location: Office Roof
Date Sampled: June 10, 2002
Number of Samples: Three (3)

Site Sampled: XXXXXXXXXXXXXXXXXXXX
Location: Room 4
Date Sampled: June 10, 2002
Number of Samples: Three (3)

Samples Taken by: Rob Peters


Thank you for your prompt response to this request.

Sincerely,



Robert Peters

RP:djg
Enclosures





IT NAME & ADDRESS: 2921 ⁴³ Chico Unified School District 2455 Carmichael Drive Chico, CA 95628		PHONE: (916) 891- FAX: (916) 891-3190	DATE:
		Circle the Method and Turn Around Time ___ hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM: Standard / Point Count	Gravimetry Prep
CONTACT: <u>ROB P.</u>		TEM: QUAL / QUANT. / WATER	
P.O.#	JOB #	AA/Flame AWFurnace ICP	
SITE: <u>NO 12 D.</u>		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1	6/10	WEST BAY OF ROOF
2	6/10	MIDDLE BAY OF ROOF
3	6/10	EAST BAY OF ROOF

Sampled by:	Date:	Time:
Relinquished by: <u>ROB P.</u>	Received By: <u>[Signature]</u>	
Date/Time: <u>6/10 2:30.</u>	Date/Time: <u>6/10 10:40 am</u>	
	Sealed Condition (circle one) YES / NO	
Inquished by:	Received By:	
Date/Time:	Date/Time:	
	Sealed Condition (circle one) YES / NO	

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

June 10, 2002

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Pleasant Valley High School Auto Shop Roof Samples
Bidwell Junior High Office Roof Samples
Nord Elementary Room 4 Roof Samples

To Whom It May Concern:

Please test the enclosed roof samples from the aforementioned schools for asbestos. We would like a 24-hour turn around on the samples. Please fax the results to us as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Pleasant Valley High School
Location: Auto Shop Roof
Date Sampled: June 10, 2002
Number of Samples: Five (5)


Site Sampled: Bidwell Junior High School
Location: Office Roof
Date Sampled: June 10, 2002
Number of Samples: Three (3)

Site Sampled: Nord Elementary School
Location: Room 4
Date Sampled: June 10, 2002
Number of Samples: Three (3)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Robert Peters

RP:dlg
Enclosures

IT NAME & ADDRESS: 21 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE:
	Circle the Method and Turn Around Time	Results Needed:
	_____hr/12hr/24hr/48hr/Ext	
	PLM: Standard / Point Count	Gravimetry Prep
CONTACT: ROB PLETTERS	TEM: QUAL. / QUANT. / WATER	
P.O.#	JOB #	AA/Flame AA/Furnace ICP
SITE: PV, AUTO SHOP		METALS:

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1	6/10	GUTTER AREA WHITE ROLLED
2.	6/10	WHITE ROLLED ROOFING
3.	6/10	CORP ROOFING.
4.	6/10	GUTTER AREA ROLLED
(S-7)	6/10	GUTTER AREA FLAT ROOF

Sampled by:	Date:	Time:
Relinquished by: ROB P	Received By:	
Date/Time: 6/13/02 12:30.	Date/Time:	
	Sealed Condition (circle one) YES / NO	
Inquished by:	Received By:	
Date/Time:	Date/Time:	
	Sealed Condition (circle one) YES / NO	



BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS: 21 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928		PHONE: (916) 891- FAX: (916) 891-3190	DATE:
		Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	Results Needed:
		PLM: Standard Point Count	Gravimetry Prep
CONTACT: ROBERT		TEM: QUAL. / QUANT. / WATER	
P.O.#	JOB #	AA/Flame	AA/Furnace ICP
SITE: BLOWER OFFICE ROOF		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
(1.)	6/10	N/W ROOF.
(2.)		S/E' 10' FROM AC UNIT.
(3.)		N/E 3' FROM AC UNIT.

Sampled by:	Date:	Time:
Relinquished by: ROBERT	Received By:	
Date/Time: 6/10/02 1:30.	Date/Time:	Sealed Condition (circle one) YES / NO
Relinquished by:	Received By:	
Date/Time:	Date/Time:	Sealed Condition (circle one) YES / NO



BULK SAMPLE REQUEST FORM

IT NAME & ADDRESS:		PHONE: (916) 891- FAX: (916) 891-3190	DATE:
21	Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	Circle the Method and Turn Around Time	Results Needed:
		____ hr/12hr/24hr/48hr/Ext	
		PLM: Standard / Point Count	Gravimetry Prep
CONTACT: ROBA		TEM: QUAL. / QUANT. / WATER	
P.O.#	JOB #	AA/Flame	AA/Furnace ICP
SITE: NO 1210		METALS:	

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
1	6/10	WEST BAY OF ROOF
2	6/10	MIDDLE BAY OF ROOF
3	6/10	EAST BAY OF ROOF

Sampled by:	Date:	Time:
Relinquished by: ROBA	Received By:	
Date/Time: 6/10 2:30	Date/Time:	Sealed Condition (circle one) YES / NO
Inquished by:	Received By:	
Date/Time:	Date/Time:	Sealed Condition (circle one) YES / NO

FedEx USA Airbill

Express

FedEx Tracking Number

8317 8006 1385

SAC12

0215

Sender's Copy

1 From *Please print and press hard.*
 Date 6/10/02 Sender's FedEx Account Number 1391-8807-1
 Sender's Name Robert Peters Phone (530) 891-3195
 Company CHICO UNIFIED SCHOOL DISTRICT
 Address 2455 CARMICHAEL DR Dept./Floor/Suite/Room
 City CHICO State CA ZIP 95928
2 Your Internal Billing Reference
 First 24 characters will appear on invoice.
3 To
 Recipient's Name _____ Phone () _____
 Company Forensic Analytical Specialties, Inc.
 Address 3777 Depot Road, Suite 409
 To "HOLD" at FedEx location, print FedEx address.
 City Hayward State CA ZIP 94545
 Dept./Floor/Suite/Room _____

4 Express Package Service
 Delivery commitment may be later in some areas.
 FedEx Priority Overnight Next business morning
 FedEx Standard Overnight Next business afternoon
 FedEx Express Saver Third business day
 FedEx 2Day Second business day
 FedEx Extra Hours Late drop-off with next business afternoon delivery for select locations
4b Express Freight Service
 Delivery commitment may be later in some areas.
 FedEx 1Day Freight* Next business day
 FedEx 2Day Freight Second business day
 FedEx 3Day Freight Third business day
 * Call for Confirmation.
5 Packaging
 FedEx Envelope*
 FedEx Pak* Includes FedEx Pak, FedEx Envelope, and FedEx Shipping Pak.
 Other Pkg Includes FedEx Box, FedEx Tube, and Customer Pkg.
6 Special Handling
 Include FedEx address in Section 3.
 SATURDAY Delivery Available ONLY for FedEx Priority Overnight and FedEx 2Day. FedEx Priority Overnight and FedEx 2Day are subject to ZIP codes.
 HOLD Weekday at FedEx Location NOT Available for FedEx Priority Overnight and FedEx 2Day.
 HOLD Saturday at FedEx Location Available ONLY for FedEx Priority Overnight and FedEx 2Day to select locations.
 Does this shipment contain dangerous goods?
 No Yes Yes Shipper's Declaration not required
 (Dangerous goods listed. Dry Ice cannot be shipped in FedEx packaging or with FedEx Priority Overnight service.)
 Dry Ice Dry Ice 1, UN 1845
 Cargo Aircraft Only
7 Payment Bill to:
 Sender Enter FedEx Acct. No. or Credit Card No. below.
 Recipient
 Third Party
 Credit Card
 Cash/Check
 FedEx Acct. No. _____
 Credit Card No. _____
 Exp. Date _____
 Total Packages 1 Total Weight _____ Total Declared Value* \$ _____
 FedEx Use Only
 * Your liability is limited to \$100 unless you declare a higher value. See back for details.
8 Release Signature Sign to authorize delivery without obtaining signature.
 By signing you authorize us to deliver this shipment without obtaining a signature and agree to indemnify and hold us harmless from any resulting claims.
 SP • Fee: Rate 7/01 • Fax: 1-800-438-3339 • ©1994-2001 FedEx • PRINTED IN U.S.A.

Try online shipping at fedex.com

By using this Airbill you agree to the service conditions on the back of this Airbill and in our current Service Guide, including terms that limit our liability.

Questions? Visit our Web site at fedex.com
 or call 1.800.Go.FedEx® 800.463.3339.

447

0203134818

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/12/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Nord Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	2,500 S	OFFICE & CLASSROOMS 1 & 2	(13) SAMPLE HMS-NES-01 COLLECTED ON 3-29-88. SAME 11/12/02	N/A
M	9" VFT BROWN	2	1-5%	2,400 S	OFFICE & CLASSROOMS 1 & 2	REPLACED WITH CARPET. SAME 11/12/02	N/A
M	9" VFT TAN	3	TRACE	100 S	OFFICE	REPLACED WITH CARPET. SAME 11/12/02	N/A
S	WALL PLASTER	4	TRACE	2,950 S	OFFICE, BOYS & GIRLS RESTROOMS, & BOILER ROOM	(1) (4) Same 11/12/02	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/12/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Nord Elementary School

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	1,300 S	MPR	(13) REPRESENTED BY SAMPLE HMS-NES-01 COLLECTED ON 3-29-01.	N/A
S	WALL PLASTER	9	1-5%	1,000 S	STORAGE ROOM & KITCHEN	(1) (4) CRACKS REPAIRED AROUND DOOR CASING 5-1-00.	N
M	9" VFT DARK GRAY	10	1-5%	1,600 S	MPR & KITCHEN	(1) (4) Same	N
M	9" VFT OLIVE	11	TRACE	100 S	MPR (EASTERN SIDE)	(1) (4) Same	N

School: Nord Elementary School

Building: Portables 3 & 4

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	100	ASSUMED	900 F	PORTABLE 3	(1) (12) THIS PORTABLE WAS BROUGHT FROM FOREST RANCH. (NO I.D.)	N
					PORTABLE 4	(12) THIS PORTABLE HAS BEEN CERTIFIED BY THE DISTRICT. HMS DOES NOT CURRENTLY HAVE A COPY OF THE CERTIFICATION LETTER ON FILE.	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS XCBM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Nord Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ff ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	2,500 S	OFFICE & CLASSROOMS 1 & 2	(13) SAMPLE HMS-NES-01 COLLECTED ON 3-29-88.	N/A
M	9" VFT BROWN	2	1-5%	2,400 S	OFFICE & CLASSROOMS 1 & 2	(7) REPLACED WITH CARPET.	N/A
M	9" VFT TAN	3	TRACE	100 S	OFFICE	(7) REPLACED WITH CARPET.	N/A
S	WALL PLASTER	4	TRACE	2,950 S	OFFICE, BOYS & GIRLS RESTROOMS, & BOILER ROOM	(1) (4) Same	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS XCBM RECORDS**

Date of Inspection: 12/27/200

District: Chico Unified School District

Inspector: Robert Peters

School: Nord Elementary School

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	1,300 S	MPR	(13) REPRESENTED BY SAMPLE HMS-NES-01 COLLECTED ON 3-29-01.	N/A
S	WALL PLASTER	9	1-5%	1,000 S	STORAGE ROOM & KITCHEN	(1) (4) CRACKS REPAIRED AROUND DOOR CASING 5-1-00.	N
M	9" VFT DARK GRAY	10	1-5%	1,600 S	MPR & KITCHEN	(1) (4) Same	N
M	9" VFT OLIVE	11	TRACE	100 S	MPR (EASTERN SIDE)	(1) (4)	N

School: Nord Elementary School

Building: Portables 3 & 4

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	100	ASSUMED	900 F	PORTABLE 3	(1) (12) THIS PORTABLE WAS BROUGHT FROM FOREST RANCH. (NO I.D.)	N
					PORTABLE 4	(12) THIS PORTABLE HAS BEEN CERTIFIED BY THE DISTRICT. HMS DOES NOT CURRENTLY HAVE A COPY OF THE CERTIFICATION LETTER ON FILE.	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS