

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12-01-2003

District: Chico Unified School District

Inspector: Robert Baughman

School: Nord Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	2,500 S	OFFICE & CLASSROOMS 1 & 2	(13) SAMPLE HMS-NES-01 COLLECTED ON 3-29-88. SAME 12/01/03	N/A
M	9" VFT BROWN	2	1-5% ABATED	2,400 S	OFFICE & CLASSROOMS 1 & 2	REPLACED WITH CARPET. ABATED DURING RECONSTRUCTION SAME 12/01/03	N/A
M	9" VFT TAN	3	TRACE	100 S	OFFICE	REPLACED WITH CARPET. SAME 12/01/03	N/A
S	WALL PLASTER	4	TRACE	2,950 S	OFFICE, BOYS & GIRLS RESTROOMS, & BOILER ROOM	(1) (4) Same 5/12/03	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12-01-2003

District: Chico Unified School District
 School: Nord Elementary School
 Inspector: Robert Baughman
 Building: B

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	1,300 S	MPR	(13) REPRESENTED BY SAMPLE HMS-NES-01 COLLECTED ON 3-29-01.	N/A
S	WALL PLASTER	9	1-5%	1,000 S	STORAGE ROOM & KITCHEN	2) (5) Cracks 12/01/03	N
M	9" VFT DARK GRAY	10	1-5%	1,600 S	MPR & KITCHEN	(1) (4) Same 12/01/03	N
M	9" VFT OLIVE	11	TRACE	100 S	MPR (EASTERN SIDE)	(1) (4) Same 12/01/03	N

Building: Portables 3 & 4

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	100	ASSUMED	900 F	PORTABLE 3	(1) (12) THIS PORTABLE WAS BROUGHT FROM FOREST RANCH. (NO I.D.)	N
					PORTABLE 4	(12) THIS PORTABLE HAS BEEN CERTIFIED BY THE DISTRICT. HMS DOES NOT CURRENTLY HAVE A COPY OF THE CERTIFICATION LETTER ON FILE.	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 5/12/2003

District: Chico Unified School District

Inspector: Robert Peters

School: Nord Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	2,500 S	OFFICE & CLASSROOMS 1 & 2	(13) SAMPLE HMS-NES-01 COLLECTED ON 3-29-88. SAME 5/12/03	N/A
M	9" VFT BROWN	2	4-6% ABATED	2,400 S	OFFICE & CLASSROOMS 1 & 2	REPLACED WITH CARPET. ABATED DURING RECONSTRUCTION SAME 5/12/03	N/A
M	9" VFT TAN	3	TRACE	100 S	OFFICE	(7) REPLACED WITH CARPET. SAME 5/12/03	N/A
S	WALL PLASTER	4	TRACE	2,950 S	OFFICE, BOYS & GIRLS RESTROOMS, & BOILER ROOM	(1) (4) Same 5/12/03	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 5/12/2003

District: Chico Unified School District

Inspector: Robert Peters

School: Nord Elementary School

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	1	NONE DETECTED	1,300 S	MPR	(13) REPRESENTED BY SAMPLE HMS-NES-01 COLLECTED ON 3-29-01.	N/A
S	WALL PLASTER	9	1-5%	1,000 S	STORAGE ROOM & KITCHEN	(1) (4) CRACKS REPAIRED AROUND DOOR CASING 5-1-00. SAME 5/12/03	N
M	9" VFT DARK GRAY	10	1-5%	1,600 S	MPR & KITCHEN	(1) (4) Same 5/12/03	N
M	9" VFT OLIVE	11	TRACE	100 S	MPR (EASTERN SIDE)	(1) (4) Same 5/12/03	N

School: Nord Elementary School

Building: Portables 3 & 4

Material Class	Material	Homo. Mat. #	% Asb.	F ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP	100	ASSUMED	900 F	PORTABLE 3	(1) (12) THIS PORTABLE WAS BROUGHT FROM FOREST RANCH. (NO I.D.)	N
					PORTABLE 4	(12) THIS PORTABLE HAS BEEN CERTIFIED BY THE DISTRICT. HMS DOES NOT CURRENTLY HAVE A COPY OF THE CERTIFICATION LETTER ON FILE.	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS