

INSPECTION DOCUMENTS

LEA: CHICO UNIFIED SCHOOL DISTRICT

SCHOOL: PARKVIEW ELEMENTARY SCHOOL

DATE OF INSPECTION: MARCH 31, 1988

INSPECTOR: JAMES E SHARP, SR.

ACCREDITATION: U.C. BERKELEY, P.A.I.C. #4


*(name of inspector)

UNIVERSITY OF CALIFORNIA BERKELEY UNIVERSITY EXTENSION

This is to certify that

James E Sharp

has attended and satisfactorily passed the exam
for the course

Building Inspection and Management Planning for Asbestos

November 16-20, 1987



This certification is valid until:

November 20, 1988

November 18 and 20, 1987

Exam dates

4

Certificate number

Vivian Sutcher

Assistant Dean
University Extension

Deborah D.

Program Director
Pacific Asbestos Information Center

UNIVERSITY OF CALIFORNIA BERKELEY UNIVERSITY EXTENSION

This is to certify that

JAMES E. SHARP

has attended the refresher course
for building inspectors and management planners,

Advanced Topics in Building Inspection and Management Planning
December 13, 1988

Certificate number: 4

Valid until: December 13, 1989



Verina Sutcher
Assistant Dean
University Extension

Deborah D.
Program Director
Pacific Asbestos Information Center

SUMMARY OF FRIABLE AND NON-FRIABLE ACBM BY BUILDING

GIS CODE

04 61424 6003073

SC-SCL

PARKVIEW ELEMENTARY SCHOOL

SCHOOL PHONE NUMBER

(916) 891-3114

ADDRESS

(Number)

(Street)

(City)

(Zip Code)

1770 EAST 8th STREET

CHICO

95926

NUMBER OF BUILDINGS

10

LINE	BUILDING NAME (Indicate Address if Different From Above)	CHECK ONE				
		ACBM		ASSUMED ACBM		
		NONE	FRIABLE	NON-FRIABLE	FRIABLE	NON-FRIABLE
1.	UNIT A			X		
2.	UNIT B			X		X
3.	UNIT C			X		X
4.	UNIT D			X		
5.	UNIT E			X		X
6.	UNIT F			X		
7.	UNIT G			X		
8.	UNIT H			X		X
9.	PORTABLE	X				
10.	NEW PORTABLE (2)	X				
11.						
12.						
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/08/88

Date Examined: 04/11/88

Lab Number: 8808284

Analyst: BB

Sample Number: PKV-01

Site: Parkview

Location: Main Heater Room, Unit D - small diameter, mudded joint.

P.O.: Chico Unified School District.

Gross Description: Fibrous, white powder (one sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

15-18 %

Chrysotile	1-5	1
Amosite	10-15	2
Crocidolite	<1	1

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Trace

Cellulose	Trace	1
Mineral Wool	<1	1
Polyethylene	<1	1

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

30-35 %

Unspecified Particulates	30-35	1
--------------------------	-------	---

Analyst:

Michelle J. Fox for BB

Supervisor:

DE

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as "asbestos in the sample".

3777 Depot Road, Suite 408, Hayward, CA 94545 • (415) 887-8828

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95353

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809385

Sample Number: PKV-02

Site: Parkview

Analyst: BB

Location: Main Heater Room, Unit D - large diameter, mudded joint.

P.O.: Chico Unified School District.

Gross Description: Fibrous, off-white powder (core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	5-10	%
Amosite	10-15	%
Crocidolite	<1	%

20-25 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%

Trace %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	75-80	%
--------------------------	-------	---

75-80 %

Analyst:

Robert Beahm

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809386

Analyst: BB

Sample Number: PKV-03A

Site: Parkview

Location: Main Heater Room, Unit D - wall plaster.

P.O.: Chico Unified School District.

Gross Description: Off-white plaster (core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%

Trace %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	98-99	%
--------------------------	-------	---

98-99 %

Analyst:

Brent Bealnell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809387

Analyst: BB

Sample Number: PKV-03B

Site: Parkview

Location: Girl's RR, Unit D, East - wall plaster.

P.O.: Chico Unified School District.

Gross Description: Off-white aggregate (plaster core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile

<1 %

Amosite

<1 %

Crocidolite

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Trace %

Cellulose

Trace %

Mineral Wool

<1 %

Polyethylene

<1 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

98-99 %

Unspecified Particulates

60-65 %

Silica

35-40 %

Analyst:

Brent Beadnell

Supervisor:

[Signature]

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 3809382

Sample Number: PKV-03C

Site: Parkview

Analyst: BE

Location: Custodial Room, Unit D - wall plaster.

P.O.: Chico Unified School District.

Gross Description: Off-white aggregate (core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	75-80	%	98-99	%
Silica	20-25	%		

Analyst:

Brent Beadnell

Supervisor:

DO

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809389

Analyst: BB

Sample Number: PKV-03E

Site: Parkview

Location: Storage Room, Unit A - wall plaster.

P.O.: Chico Unified School District.

Gross Description: Crushed aggregate (plaster core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Trace %

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%
Other Fibers	Trace	%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

98-99 %

Unspecified Particulates	60-65	%
Silica	35-40	%

Analyst:

Brent Bealwell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809390

Sample Number: PKV-04A

Site: Parkview

Analyst: BB

Location: Boy's RR, Unit D, East - acoustic ceiling plaster.

P.O.: Chico Unified School District.

Gross Description: Off-white material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
		%		
		%		
		%		

Analyst:

Brent Beadnell

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809391

Sample Number: PKV-04C

Site: Parkview

Analyst: BB

Location: Girl's RR, Unit D, East - acoustic ceiling plaster.

P.O.: Chico Unified School District.

Gross Description: Crushed aggregate (plaster).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	Trace	%	Trace	3
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	1
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	98-99	%	98-99	3
		%		
		%		
		%		

Analyst:

Brent Beednell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809392

Analyst: BB

Sample Number: PKV-04B

Site: Parkview

Location: Boy's RR, Unit D, East - acoustic ceiling plaster.

P.O.: Chico Unified School District.

Gross Description: Off-white material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	3	1-5	3
Amosite	<1	3		
Crocidolite	<1	3		
		3		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	3	Trace	3
Mineral Wool	<1	3		
Polyethylene	<1	3		
		3		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	3	95-99	3
		3		
		3		
		3		

Analyst:

Brent Beednell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/11/88

Lab Number: 8809393

Sample Number: PKV-05

Site: Parkview

Analyst: BB

Location: Room 8, Unit C, Classroom - 9" VFT, white/green.

P.O.: Chico Unified School District.

Gross Description: Off-white, floor tile and mastic (asbestos in both).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
		%		
		%		
		%		

Analyst:

Brent Bealnell

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts..

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809394

Sample Number: PKV-06

Site: Parkview

Analyst: BB

Location: Room 8, Unit C, Classroom - 12" acoustic ceiling tile.

P.O.: Chico Unified School District.

Gross Description: Golden brown, fibrous, ceiling tile (core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	90-95	%	90-95	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	%	5-10	%
		%		
		%		
		%		

Analyst:

Brent Beadwell

Supervisor:

DD

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809395

Sample Number: PKV-07A

Site: Parkview

Analyst: BB

Location: MPR, Unit H, East Side - acoustic ceiling T-O-C.

P.O.: Parkview School, Chico Unified School District.

Gross Description: Off-white, ceiling material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
		%		
		%		
		%		

Analyst:

Brent Beadnell

Supervisor:

de

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809396

Sample Number: PKV-07B

Site: Parkview

Analyst: BB

Location: MPR, Unit H, West Side - acoustic ceiling T-O-C.

P.O.: Chico Unified School District.

Gross Description: Off-white ceiling material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
		%		
		%		
		%		

Analyst:

Brent Bealnell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

Client:

Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

FOR

Client Number: 146
Report Number: 7101
Date Received: 04/05/88
Date Examined: 04/12/88

Lab Number: 8809397
Sample Number: PKV-07C
Site: Parkview

Analyst: BB

Location: MPR, Unit H, North - acoustic ceiling T-O-C.

P.O.: Chico Unified School District.

Gross Description: Off-white ceiling material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	%
--------------------------	-------	---	-------	---

Analyst:

Brent Bealnell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809398

Sample Number: PKV-08

Site: Parkview

Analyst: EB

Location: MPR, Unit H - 9" VFT, brown (lite).

P.O.: Chico Unified School District.

Gross Description: Off-white tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%	1-5	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	90-95	%	90-95	%
--------------------------	-------	---	-------	---

Analyst:

Brent Beahm

Supervisor:

DE

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA Bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809399

Analyst: BB

Sample Number: PKV-09

Site: Parkview

Location: Kitchen MPR, Unit H - 12" VFT, red.

P.O.: Parkview School, Chico Unified School District.

Gross Description: Red tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%
Amosite	<1	%
Crocidolite	<1	%

1-5 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%
Mineral Wool	<1	%
Polyethylene	<1	%

1-5 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	90-95	%
--------------------------	-------	---

90-95 %

Analyst:

Brent Beadnell

Supervisor:

DE

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809400

Analyst: BB

Sample Number: PKV-10

Site: Parkview

Location: MPR Stage West, Unit H - pw straight.

P.O.: Chico Unified School District.

Gross Description: Fibrous, white material (core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	10-15	%	10-15	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	1-5	%
Mineral Wool	1-5	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	80-90	%	80-90	%
		%		
		%		
		%		

Analyst:

Brent Rednell

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809401

Sample Number: PKV-03D

Site: Parkview

Analyst: BB

Location: Custodial Closet, Unit A - plaster ceiling T-O-C.

P.O.: Chico Unified School District.

Gross Description: Crushed, off-white aggregate.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%

Trace %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	85-90	%
Silica	10-15	%

98-99 %

Analyst: Brent Beadnell

Supervisor: DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809402

Analyst: BB

Sample Number: PKV-04D

Site: Parkview

Location: Nurse's Room, Unit A - ceiling plaster T-O-C acoustic.

P.O.: Parkview School, Chico Unified School District.

Gross Description: Off-white ceiling material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	3
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%	<1	3
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%	95-99	3
		%		
		%		
		%		

Analyst:

Brent Rednell

Supervisor:

DE

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809403

Sample Number: PKV-04E

Site: Parkview

Analyst: SB

Location: Staff Lounge, Unit A - T-O-C acoustic.

P.O.: Chico Unified School District.

Gross Description: Off-white ceiling material.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	Trace	%
Amosite	<1	%
Crocidolite	<1	%
		%

Trace %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	<1	%
Polyethylene	<1	%
		%

Trace %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	98-99	%
		%
		%
		%

98-99 %

Analyst: Brent Bealhill

Supervisor: de

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809404

Sample Number: PKV-11

Site: Parkview

Analyst: BB

Location: Library Workroom, Unit F - 12" acoustic ceiling tile.

P.O.: Chico Unified School District.

Gross Description: Golden brown, fibrous ceiling tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	90-95	%	90-95	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	%	5-10	%
		%		
		%		
		%		

Analyst:

Brent Bealwell

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809405

Sample Number: PKV-12

Site: Parkview

Analyst: BB

Location: Library, Unit F - 2 x 4 ceiling panel.

P.O.: Chico Unified School District.

Gross Description: Off-white, fibrous, ceiling panel.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	15-20	%
Mineral Wool	55-60	%
Polyethylene	<1	%

75-80 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	20-25	%
--------------------------	-------	---

20-25 %

Analyst:

Brent Beal

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809406

Analyst: BB

Sample Number: PKV-13

Site: Parkview

Location: Library Workroom, Unit F - 9" VFT.

P.O.: Chico Unified School District.

Gross Description: Beige tile and mastic (5-10 asbestos in mastic).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%	1-5	%
Amosite	<1	%		
Crocidolite	<1	%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%	1-5	%
Mineral Wool	<1	%		
Polyethylene	<1	%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	90-95	%	90-95	%
--------------------------	-------	---	-------	---

Analyst:

Brent Beednell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809407

Sample Number: PKV-03F

Site: Parkview

Analyst: BB

Location: Storage Room, Unit A - wall plaster.

P.O.: Chico Unified School District.

Gross Description: Off-white aggregate.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	80-85	%	98-99	%
Silica	15-20	%		
		%		
		%		

Analyst:

Brent Beal

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809408

Sample Number: PKV-14

Site: Parkview

Analyst: BE

Location: Staff Lounge - 12" VFT, white.

P.O.: Chico Unified School District.

Gross Description: Off-white tile and glue.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	1-5	%
Mineral Wool	Trace	%
Polyethylene	<1	%

1-5 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	95-99	%
--------------------------	-------	---

95-99 %

Analyst:

Brent Bealwell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809409

Sample Number: PKV-15

Site: Parkview

Analyst: BB

Location: RR Attic, Unit F - pw corner.

P.O.: Chico Unified School District.

Gross Description: Fibrous, off-white powder.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	1-5	%
Amosite	<1	%
Crocidolite	<1	%
		%

1-5 3

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%
Mineral Wool	20-25	%
Polyethylene	<1	%
		%

20-25 3

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	70-80	%
		%
		%
		%

70-80 3

Analyst:

Brent Beadell

Supervisor:

SC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809410

Sample Number: PKV-16

Site: Parkview

Analyst: BB

Location: Room 18, Unit G, Classroom - 12" VET, 2 tone brown.

P.O.: Chico Unified School District.

Gross Description: Off-white tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	%	<1	%
Amosite	<1	%		
Crocidolite	<1	%		
		%		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	%	Trace	%
Mineral Wool	<1	%		
Polyethylene	<1	%		
		%		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	98-99	%	98-99	%
		%		
		%		
		%		

Analyst:

Brent Beadell

Supervisor:

DC

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809411

Sample Number: PKV-17

Site: Parkview

Analyst: BB

Location: Room 18, Unit G, Classroom - 2 x 4 ceiling panel.

P.O.: Chico Unified School District.

Gross Description: Dark yellow to off-white, fibrous, ceiling panel.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	<1	2	<1	%
Amosite	<1	2		
Crocidolite	<1	2		
		2		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	20-25	2	90-95	%
Mineral Wool	65-70	2		
Polyethylene	<1	2		
		2		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	5-10	2	5-10	%
		2		
		2		
		2		

Analyst:

Burt Beahm

Supervisor:

De

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7101

Date Received: 04/05/88

Date Examined: 04/12/88

Lab Number: 8809412

Sample Number: PKV-18

Site: Parkview

Analyst: BB

Location: Room 12, Unit G, ceiling above false ceiling - mudded joint.

P.O.: Chico Unified School District.

Gross Description: Fibrous, off-white material (core sample).

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	5-10	3	5-10	3
Amosite	<1	3		
Crocidolite	<1	3		
		3		

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	Trace	3	20-25	3
Mineral Wool	20-25	3		
Polyethylene	<1	3		
		3		

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	65-75	3	65-75	3
		3		
		3		
		3		

Analyst:

Brent Bealnel

Supervisor:

BB

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

HAZARD MANAGEMENT SERVICES, INC.

Inspection Form I-1

DISTRICT _____

Page _____ of _____

SCHOOL PARKVIEWDate 3/31/88Building UNIT EInspector JESLocation BOILER RM
(functional area)HMS# -01Material: Surfacing TSI Misc. _____ % Asbestos 15-20
Description SM, DIA. CORNERAmount of Material (NF / F) 14 / 0 (ft² / lf) Assumed ACM: Y / N # of samples 1CONDITION: % damaged: _____ Extent of damage: _____
0% <1% 1-10% 11-25% >25% none local distributed

Type damage: air; deterioration; water; physical; flaking

DESCRIPTION: _____

POTENTIAL FOR DISTURBANCE:

PREVENTATIVE MEASURES:

Accessibility: H (M) L
Vibration : H M (L)
Air Erosion : H M (L)
Water : H M (L)

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact

COMMENTS: _____

REMEDIAL ACTIONS

isolate/restrict repair/cleanup


enclose

encapsulate

remove

O&M

ACBM Condition - Assessment



HAZARD MANAGEMENT SERVICES, INC.

Inspection Form I-1

DISTRICT _____
 SCHOOL PARKVIEW
 Building UNIT D
 Location BOLLER RM
 (functional area)

Page _____ of _____

Date 3/21/88Inspector JLSHMS-PRV-02

Material: Surfacing TSD Misc. _____ % Asbestos 20-25
 Description LG. DIA. CORNERS

Amount of Material (NF / F) 25/0 (ft / lf) Assumed ACM: Y / N # of samples 1

CONDITION: % damaged: Extent of damage:

0% <1% 1-10% 11-25% >25% none local distributed

Type damage: air; deterioration; water; physical; flaking

DESCRIPTION:

No damage.

POTENTIAL FOR DISTURBANCE:

Accessibility: H M L
 Vibration : H M L
 Air Erosion : H M L
 Water : H M L

PREVENTATIVE MEASURES:

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact

COMMENTS:

REMEDIAL ACTIONS

isolate/restrict repair/cleanup

enclose

encapsulate

remove

O&M

ACBM Condition - Assessment

Poor
(Significant damage)

Hazard
Rank 1

Fair

(Damaged)

Good
(little or no damage)

Potential Disturbance

Potential Damage

High
Potential
Significant
Damage

Hazard
Rank 2

Moderate
Potential
Damage

Hazard
Rank 3

Low

Hazard
Rank 4

High
Potential
Significant
Damage

Hazard
Rank 5

Moderate
Potential
Damage

Hazard
Rank 6

Low

Hazard
Rank 7