

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: A

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
WHITE 9" VFT	1	RMS1,2,5,6,7,8,9	00-01 TRACE	5000 S	N
1 X 2 ACT	2	RMS 7-12	00-00	5500 S	N
PLASTER/DRY	3	ALL ROOMS	00-00	10000 S	N
ACT	4	OFFICE AREAS/HALLS	00-00	3000 S	N
PW CNR	5	ATTIC AREA	10-15	25 J	N
C. TOWER DBRS	6	ATTIC OF COOLING TWR	00-00	2 S	Y
DUCT TAPE	7	ATTIC AREA	00-00	100 S	N
HARD PLASTER	8	OFFICE RRS	00-00	300 S	N
PLASTER	9	COVERED WALKS	01-05	1921 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: B

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFT	1	CLS B-1,4,5,6,7,8,10	00-01 TRACE	5900 S	N
1 X 2 ACT	2	ALL ROOMS	00-00	8000 S	N
PLASTER/DRY	3	ALL AREAS	00-00	10000 S	N
PW CNR	5	ATTIC AREA	10-15	22 J	Y
PLASTER	9	COVERED WALK	01-05	1921 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: C

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFT	1	RMS 20,21,22,& 24-28	00-01 TRACE	7300 S	N
1 X 2 ACT	2	RMS 20,21,22,& 24-28	00-00	7300 S	N
PW CNR	5	ATTIC AREA	10-15	23 L	N
DUCT WRAP	7	ATTIC AREA	00-00	100 S	N
HARD PLASTER	8	RM 18,DARK RM,MEN RR	00-00	250 S	N
PLASTER	9	COVERED WALK	01-05	10236 S	N
MLD BLK TABLE	99	RM 20	99-99 ASSUMED	0 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: D

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
9" VFT	1	RMS 30,33,34, RR	00-01 TRACE	3750 S	N
9" VFT	1	WOOD SHOP/HM CLST	00-00	3678 S	N
1 X 2 ACT	2	RM 30,33,STRG,WDSHOP	00-00	7266 S	N
PLASTER/DRY	3	ALL AREAS	00-00	10000 S	N
PW CNR	5	ATTIC AREA	01-10	38 J	N
DUCT TAPE	7	ATTIC AREA	00-00	150 S	N
PLASTER	9	COVERED WALKS	01-05	1921 S	N
WHITE 12" VFT	14	RM 35, WDSHOP SHELF	00-00	925 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: E

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable?
1 X 2 ACT	2	CAFETERIA	00-00	2020 S	N
PW CNR	5	ATTIC OVER RADIO STA	01-10	10 L	N
HARD PLASTER	8	RM 37, RRs	00-00	800 S	N
PLASTER	9	COVERED WALKS	01-05	1104 S	N
ACT	19	RM 39 MUSIC	00-00	1600 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: F

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
ACT	2	RM 51 OFFICES	00-00	400 S	N
PLASTER/DRY	3	ALL AREAS	00-00	10000 S	N
PW JNTs	5	SMALL GYM	01-10	12 J	N
PW JNTs	5	STOREROOM	01-10	16 J	N
HARD PLASTER	8	LOCKER ROOMS	00-00	3200 S	N
PLASTER	9	COVERED WALKS	01-05	2500 S	N
PLASTER	9	POPCORN RM	01-05	110 S	N
PW STR	16	BLR RM	40-60	12 L	N
PW STR	16	STOREROOM	40-60	20 L	Y
TANK WRAP	17	BLR RM	35-45	282 S	N
PW CNR & DBRS	18	ATTIC	15-20	223 S	Y

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: G

Material	Homog. Mat. #	Locations	% Asb	Footage	Friable? Y or N
PW CNR	5	GYM	01-10	17 J	Y
PW CNR	5	LOCKER ROOMS	01-10	45 J	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: H

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
PLASTER	9	COVERED WALK	01-05	355 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: I

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
PLASTER	9	COVERED WALKS	01-05	1026 S	N
FCP	12	DRAFTING ROOM	00-00	812 S	N
12" VFT	15	RM 3 DRAFTING	01-05	812 S	N
TRNS WALL BRD	98	METAL SHOP (WLD BTH)	99-99 ASSUMED	350 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

Homogeneous Materials Record

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: J

Material	Homog. Mat. #	Locations	% Asb	Footage Y or N	Friable? Y or N
PLASTER/DRY	3	ALL AREAS	00-00	10000 S	N
LINO (YELLOW)	10	ALL OF UNIT J	30-35	706 S	N
LINO (YELLOW)	10	RM 1 STUDENT SNK BAR	30-35	180 S	N
ACT	11	RM 1 S.A. SNACK BAR	00-00	180 S	N
FCP	12	MANAGER'S OFFICE	00-00	70 S	N
LINO (BROWN)	13	ACTIVITIES ROOM	25-30	300 S	N
LINO (BROWN)	13	STEREO STOREROOM	25-30	50 S	N

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

HOMOGENEOUS MATERIAL RECORDS

DISTRICT Chico SCHOOL Pleasant Valley High
 ADDRESS _____

BLDG. CLASS.		HAT. CLASS.		HOMOG. MAT. #		SAMPLE NUMBER		LOCATION	ASBESTOS	FOOTAGE FT ² OF LF	FRIABLE	
											YES	NO
A	wise	off white 9" OFT	01	01				Room 7 Conference Rm	TRACE	200 ft ²	X	
								Room 6 Admin offices		2,312 ft ²	X	
								Room 2 Corridor		162 ft ²	X	
								Room 8 Language		790 ft ²	X	
								Room 5 1/2 wk Rms		599 ft ²	X	
								Room 1 Storage		82 ft ²	X	
								Room 9 Cls Rm		796 ft ²	X	
										790 ft ²	X	
A	wise	1 1/2" ACT	02	02				Room 7	< 1	790 ft ²	X	
								Room 8		3000 ft ²	X	
								Rooms 9 and 10		800 ft ²	X	
								Rooms 11 and 12				
										1,000 ft ²	X	
A	surf	flat rock & PLASTER	03	03A-G				Room 7	< 1	over 10,000 ft ²	X	
								Rest of wing				
								Room 6 office lobby	< 1	150 ft ²	X	
								Secretary's office		200 ft ²	X	
A	wise	1 1/2" ACT	04	04				Principals office		400 ft ²	X	
								Rm 2 corridor		162 ft ²	X	

Pleasant Valley High

DISTRICT Chico

SCHOOL, _____
ADDRESS _____

[illegible]

HOMOGENEOUS MATERIAL RECORD

SCHOOL. Pleasant Valley High

DISTRICT Chico

ADDRESS _____

ERIDIAN
YES NO

FOOTAGE
FT OF LF

%
ASBESTOS

HOMOG. SAMPLE
MAT. # NUMBER

LOCATION

BLDG. CLASS. MAT. CLASS.

MATERIAL

Wise

01

01

C/S Dms B-1, 4, 5, 6, 7, 8, and 10

TRACE

5900 ft

X

Wise

02

02

All Rooms

8000 ft

X

Surf

03

03A-6

All Areas

over
10,000

X

T&F

05

05B

Attic Areas

22 JNTS

10-15

X

Surf

09

09A-6

Covered Walk (outdoors)

1921 ft

1-5

X

Pleasant Valley High

BC11001.

DISTRICT Chico

References

ADDRESS		% ASBESTOS		FOOTAGE FT ² OF LF		FRIABLE YES NO	
BUILDG. CLASS.	HAT. CLASS.	HAT. #	SAMPLE NUMBER	LOCATION			
C	MISC.	01	01	Rms 24, 25, 26, 27, 28, 20, 21, 22	TRACE	7300 ft ²	X
C	MISC.	02	02	Rms 24, 25, 26, 27, 28, 20, 21, 22		7300 ft ²	X
C	Surf	03	03A-G	All Areas	<1	over 10,000 ft ²	X
C	TSE	05	05C	Attic Area	1-5	23 INTS	X
C	MISC.	99	N/S	Room 20	Assumed	Multiple	X
C	TSE	07	07	Attic Area	<1	7100 ft ²	X
C	Surf	08	08C	Pw 18 Dork Pw & men's R	<1	250 ft ²	X
C	Surf	09	09A-G	Covered Walk (outdoor)	1-5	10,236 ft ²	X

HOIOGENEQUE MATERIAL RECORDS

SCHOOL Pleasant Valley High

DISTRICT Chico

ADDRESS _____

BLDG.	HAT. CLASS.	HAT.	MATERIAL	HOIOG. HAT.	SAMPLE NUMBER	LOCATION	ASBESTOS %	FOOTAGE FT ² OF LF	FRIABLE	
									YES	NO
A	misc.	01	off white 9" VET	01	01	Rms 30, 33	TRACE	3500 ft ²		X
						wood shop		3566 ft ²		X
						Home making closet		112 ft ²		X
						RR (Rm 31)		27 ft ²		X
						Rm 34		1182 ft ²		X
						Rm 30, 33, 34	<1	3500 ft ²		X
D	misc	02	1x2 ACT	02	02	Storage		200 ft ²		X
						wood shop		3566 ft ²		X
								OVER 10,000 ft ²		X
D	surf	03	Sheet Rock + PLASTER	03	03A-G	All Areas				
						Attic Area	1-10	38 JOTS	X	
D	T&E	05	PW CNR	05	05A-C	Attic Area				
						Attic Area		7150 ft ²		X
D	T&E	07	Duct wrap	07	07					
						Covered walk (outdoors)		1921		X
D	surf.	09	PLASTER	09	09A-G					
						Room 35	TRACE	625 ft ²		X
D	misc	14	white 12" VET	14	14	wood shop shelf Area		300 ft ²		X

Pleasant Valley High

DISTRICT Chico

School.

Answers

[illegible]

HOMOGENEOUS MATERIAL RECORDS

DISTRICT Chico SCHOOL Pleasant Valley High

ADDRESS

BLDG. CLASS.	HAT.	HAT. CLASS.	HAT. NO.	HOMOG. SAMPLE NUMBER	LOCATION	% ASBESTOS	FOOTAGE FT ² OF LF	TRIANGLE YES NO
F	misc	ACT	02	02	Rm 51 offices	<1	400 ft ²	X
F	surf	Sheet Rock PLASTER	03	03A-G	All Areas	<1	over 10,000 ft ²	X
F	surf	Hard PLASTER	08	08E	Rm 49 men's locker rooms	<1	1600 ft ²	X
F	surf	Hard PLASTER	08	08D4G	Rm 49 women's locker rooms	<1	1600 ft ²	X
F/G	surf	PLASTER	09	09A-G	Covered walk (outdoors) and popcorn rm	1-5	2610 ft ²	X
F	ISI	PW STR	16	16A-C	Room 55 BIR Rm	40-60	12 LF	X
F	ISI	TABLE WRAP	17	17	Rm 54 storeroom	40-60	20 LF	X
F	ISI	Debris & PW CATE	18	18	BIR Rm	35-45	282 ft ²	X
F	ISI	WOOD JOINT	05	05A-C	Attic	15-20	Debris 2000 ft ² JNTS 23	X
F	ISI	WOOD JOINT	05	05A-C	Room 54 Storage	1-10	16 JNTS	X
G	ISI	WOOD JOINT	05	05A-C	Small 6' x 6'	1-10	12 JNTS	X
G	ISI	WOOD JOINT	05	05A-C	6' x 6' locker rms	1-10	17 JNTS	X
G	ISI	WOOD JOINT	05	05A-C			45 JNTS	X

HOMOGENEOUS MATERIAL RECORDS

SCHOOL Pleasant Valley High

DISTRICT Chico

ADDRESS _____

FRIABLE
YES NO

FOOTAGE
FT² OF LF

%
ASBESTOS

LOCATION

HOMOG. SAMPLE
MAT. # NUMBER

MAT. MATERIAL

BLDG. CLASS.

H

Surf

PLASTER

09

09A-6

Covered Walk (outdoors)

1-5

355 ft²

X

HOMOGENEOUS MATERIAL RECORDS

SCHOOL Pleasant Valley High

DISTRICT Chico

ADDRESS _____

FRINDLE
YES NO

FOOTAGE
FT² OF LF

*
ASBESTOS

X

1026 ft²

1-5

Covered walk (outside)

099-6

09

PLASTER

I

I

I

X

812 ft²

51

Drafting Rm

12

12

FCP

I

I

I

X

350 ft²

Assumed

Room 1 metal shop at working

N/S

98

transite
wall board

I

I

I

X

812 ft²

1-5

Room 7 Drafting

15

15

off white
12" VET

I

I

I

school: Pleasant valley High

DISTRICT Waco

BC11001.

Answers

[illegible]

HMS, INC.
HAZARD MANAGEMENT SERVICES, INC.

CHICO UNIFIED SCHOOL DISTRICT
PLEASANT VALLEY SENIOR HIGH SCHOOL
AHRA THREE-YEAR REINSPECTION SUMMARY
APRIL, 1992

Attached you will find a computer print-out of your original "Homogeneous Materials Record Sheets". You will find these sheets easier to read than the original copies. If additional samples were collected at this site, the results are listed at the end of the new "homogeneous" sheets. A comment on drywall sampling and lab accreditation sheets are added as appropriate.

At this site all previously or currently identified asbestos-containing materials were in good condition, i.e., non-friable.

We have given you a new index to insert into your management plan to account for new sections VIII and IX. We have added section VIII in which you should include results of your six-month inspections. We have also included a sheet on drywall sampling with recommendations on handling drywall. We also want to remind you that new buildings or portables must either be inspected or exempted by letter by your architect or builder.

AHERA THREE YEAR REINSPECTION

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **PLEASANT VALLEY HIGH**

BUILDING: A

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
-----------------	--------------------------	------------------	--------------	----------------	--------------

PW CNR	5	ATTIC AREA	10-15	25 J	1-4
--------	---	------------	-------	------	-----

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? NO **Abated?** NO

Comments:

PLASTER	9	COVERED WALKS	01-05	1921 S	1-4
---------	---	---------------	-------	--------	-----

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? NO **Abated?** NO

Comments:

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
 (I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

AHERA THREE YEAR REINSPECTION

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: B

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
----------	------------------	-----------	-------	---------	-------

PW CNR	5	ATTIC AREA	10-15	22 J	1-5
--------	---	------------	-------	------	-----

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? YES Abated? REPAIRED

Comments:

PLASTER	9	COVERED WALK	01-05	1921 S	1-4
---------	---	--------------	-------	--------	-----

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? NO Abated? NO

Comments:

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
(I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

AHERA THREE YEAR REINSPECTION

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: C

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
PW CNR	5	ATTIC AREA	10-15	23 L	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
PLASTER	9	COVERED WALK	01-05	10236 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
MLD BLK TABLE	99	RM 20	01-99 (ASSUMED)	0 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
 Change in Condition: (N or 4) No (Y) Yes (Please explain)
 Abated: (R) Repaired (M) Removed (E) Enclsd
 (I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

AHERA THREE YEAR REINSPECTION

School Dist: **Chico USD**
Date Inspected: **04/14/92**

School: **PLEASANT VALLEY HIGH**

BUILDING: **D**

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
<hr/>					
PW CNR	5	ATTIC AREA	01-10	38 J	1-4
3 Year Inspection Notes:					
Condition of Material: GOOD					
Change in Condition? NO Abated? NO					
Comments:					
<hr/>					
PLASTER	9	COVERED WALKS	01-05	1921 S	1-4
3 Year Inspection Notes:					
Condition of Material: GOOD					
Change in Condition? NO Abated? NO					
Comments:					

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
(I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

AHERA THREE YEAR REINSPECTION

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **PLEASANT VALLEY HIGH**

BUILDING: J

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
<hr/>					
LINO (YELLOW)	10	ALL OF UNIT J	30-35	706 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
<hr/>					
LINO (YELLOW)	10	RM 1 STUDENT SNK BAR	30-35	180 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
<hr/>					
LINO (BROWN)	13	ACTIVITIES ROOM	25-30	300 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
<hr/>					
LINO (BROWN)	13	STEREO STOREROOM	25-30	50 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
 (I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

AHERA THREE YEAR REINSPECTION

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: E

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
----------	------------------	-----------	-------	---------	-------

PW CNR	5	ATTIC OVER RADIO STA	01-10	10 L	1-4
--------	---	----------------------	-------	------	-----

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? NO Abated? NO

Comments:

PLASTER	9	COVERED WALKS	01-05	1104 S	1-4
---------	---	---------------	-------	--------	-----

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? NO Abated? NO

Comments:

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
(I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

AHERA THREE YEAR REINSPECTION

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **PLEASANT VALLEY HIGH**

BUILDING: **F**

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
PW JNTs	5	SMALL GYM	01-10	12 J	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
PW JNTs	5	STOREROOM	01-10	16 J	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
PLASTER	9	COVERED WALKS	01-05	2500 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
PLASTER	9	POPCORN RM	01-05	110 S	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
PW STR	16	BLR RM	40-60	12 L	1-4
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? NO Abated? NO Comments:					
PW STR	16	STOREROOM	40-60	20 L	1-5
3 Year Inspection Notes: Condition of Material: GOOD Change in Condition? YES Abated? REPAIRED Comments: Friable section has been repaired					

AHERA THREE YEAR REINSPECTION

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **PLEASANT VALLEY HIGH**

BUILDING: **F**

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
TANK WRAP	17	BLR RM	35-45	282 S	1-4

3 Year Inspection Notes:

Condition of Material: **GOOD**

Change in Condition? **NO** Abated? **NO**

Comments:

PW CNR & DBRS	18	ATTIC	15-20	223 S	1-5
---------------	----	-------	-------	-------	-----

3 Year Inspection Notes:

Condition of Material: **GOOD**

Change in Condition? **YES** Abated? **NO**

Comments: **Damaged section not found, yet no signs of repairs seen.**

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
 Change in Condition: (N or 4) No (Y) Yes (Please explain)
 Abated: (R) Repaired (M) Removed (E) Enclsd
 (I) Isolated and Restricted

Inspected By: **Mike Sharp**

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

AHERA THREE YEAR REINSPECTION

School Dist: **Chico USD**
 Date Inspected: **04/14/92**

School: **PLEASANT VALLEY HIGH**

BUILDING: G

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
PW CNR	5	GYM	01-10	17 J	1-5

3 Year Inspection Notes:
Condition of Material: GOOD
Change in Condition? YES **Abated?** REPAIRED
Comments:

PW CNR	5	LOCKER ROOMS	01-10	45 J	1-4
--------	---	--------------	-------	------	-----

3 Year Inspection Notes:
Condition of Material: GOOD
Change in Condition? NO **Abated?** NO
Comments:

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
 (I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

AHERA THREE YEAR REINSPECTION

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: H

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
PLASTER	9	COVERED WALK	01-05	355 S	1-4

3 Year Inspection Notes:

Condition of Material: GOOD

Change in Condition? NO Abated? NO

Comments:

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
(I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRs.

AHERA THREE YEAR REINSPECTION

School Dist: Chico USD
Date Inspected: 04/14/92

School: PLEASANT VALLEY HIGH

BUILDING: I

Material	Homog. Mat. #	Locations	% Asb	Footage	Codes
PLASTER	9	COVERED WALKS	01-05	1026 S	1-4
3 Year Inspection Notes:					
Condition of Material: GOOD					
Change in Condition? NO Abated? NO					
Comments:					
12" VFT	15	RM 3 DRAFTING	01-05	812 S	1-4
3 Year Inspection Notes:					
Condition of Material: GOOD					
Change in Condition? NO Abated? NO					
Comments:					
TRNS WALL BRD	98	METAL SHOP (WLD BTH)	01-99 (ASSUMED)	350 S	1-4
3 Year Inspection Notes:					
Condition of Material: GOOD					
Change in Condition? NO Abated? NO					
Comments:					

Codes:

General Condition: (1) Good (2) Damaged (3) Sig. Damaged
Change in Condition: (N or 4) No (Y) Yes (Please explain)
Abated: (R) Repaired (M) Removed (E) Enclsd
(I) Isolated and Restricted

Inspected By: Mike Sharp

These Reports should be placed in your AHERA file. Do not throw away old HMRS.

UNIVERSITY OF CALIFORNIA BERKELEY UNIVERSITY EXTENSION

This is to certify that

MICHAEL C. SHARP

has attended the

AHERA Refresher Course for Asbestos Inspectors and
Management Planners
November 26, 1991

Certificate number:

1428

Valid until: November 26, 1992



Deloral DA.
Chair
Programs in Environmental Hazard
Management

UNIVERSITY OF CALIFORNIA BERKELEY UNIVERSITY EXTENSION

This is to certify that

MICHAEL C. SHARP

has attended the

AHERA Refresher Course for Asbestos Abatement Project Designers
October 22, 1991

Certificate number:

Valid until: October 22, 1992



Deloral DA.
Chair
Programs in Environmental Hazard
Management

SIX-MONTH SURVEILLANCE

Page 1 of 3

DISTRICT Chico Unified School District DATE December 22, 1992

SCHOOL Pleasant Valley High INSPECTOR Michael Fender

BLDG.	HOMOG.	ASBESTOS	MAT.#	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15			Attic area	6-4
A	Plaster	1-5			Covered walk (outdoors)	1-4 (partial removal)
B	PW Cnr	10-15			Attic area	6-4 >50%
B	Plaster	1-5			Covered walk (outdoors)	1-4 (partial removal)
C	PW Cnr	1-5			Attic area	2-4
C	Molded blk tabletops	Assumed			Room 20	1-4
C	Plaster	1-5			Covered walk (outdoors)	1-4 (partial removal)
D	PW Cnr	1-10			Attic area	6-4
D	Plaster	1-5			Covered walk (outdoors)	1-4 (partial removal)
E	PW Cnr	1-10			Attic over radio station	7
E	Plaster	1-5			Covered walk (outside)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

Page 2 of 3

DISTRICT Chico Unified School District DATE December 22, 1992SCHOOL Pleasant Valley Senior INSPECTOR Michael Fender *MF*

BLDG.	HOMOG.	ASBESTOS	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
	MAT.#				

F/G	Plaster	1-5		Covered walk (outdoors)	1-4
F	PW Str	40-60		Rm 55 B/R room	5-4
F	PW Str	40-60		Rm 54 storeroom	1-4
F	Tank wrap	35-45		B/R room	1-4
F	Debris & PW Cnr	15-20		Attic	2-4
F	Mud jnt	1-10		Room 54 storage	1-4
F	12 jnts	1-10		Small gym	1-4
G	Mud Jnt	1-10		Gym	1-4
H	Plaster	1-5		Covered Walk (outdoors)	1-4
I	Plaster	1-5		Covered Walk (outside)	1-4
I	Trans Wallboard	Assumed		Room 1 - Metal Shop	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

