

PRECISION MICRO-ANALYSIS

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

Bulk Sample Analysis (PLM) Report

Report # 93287007

Ron Jones
Chico Unified School District
2455 Carmichael Drive
Chico, CA 95969

Date Collected: 10/13/93
Date Received: 10/14/93
Date Analyzed: 10/14/93

Phone: (916) 891-3095

Job Information:
PVHS-Boiler Room


Sample Number	Sample Location	Sample Description	Analytical Results
1 Lab # 93-112845	PW, straight	Golden foam with white cloth	No asbestos detected 10-15% Cellulose fibers
2 Lab # 93-112846	PW, straight	Golden foam with white cloth and grey fine grained material	No asbestos detected 10-15% Cellulose fibers
3 Lab # 93-112847	PW, straight	Yellow foam with grey cloth	No asbestos detected 10-15% Cellulose fibers
4 Lab # 93-112848	PW, straight	Yellow foam with white cloth and tan fine grained material	No asbestos detected 10-15% Cellulose fibers
5 Lab # 93-112849	PW, straight	Yellow fibrous material with white cloth and tan fine grained material	No asbestos detected 10-15% Cellulose fibers
6 Lab # 93-112850	PW, straight	Golden foam with white cloth and tan fine grained material	No asbestos detected

OFFICIAL NOTICE: After 45 days, samples are disposed of at a licensed waste disposal site unless client requests their return, identifying samples by our laboratory identification #'s. Charges for sample returns are a \$5.00 retrieval fee plus \$2.00 per sample to cover costs of retrieval, handling, and shipping.

Total Number of Samples: 23
Supervisor Ron Jones

Analyst McGee Page 1 of 4

Note: The test result findings are made to the methodologies and parameters described on the reverse of this page.



PRECISION
MICRO-ANALYSIS

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

Bulk Sample Analysis (PLM) Report

Report # 93287007

Ron Jones
Chico Unified School District
2455 Carmichael Drive
Chico, CA 95969-

Date Collected: 10/13/93
Date Received: 10/14/93
Date Analyzed: 10/14/93

Phone: (916) 891-3095

Job Information:
PVHS-Boiler Room


Sample Number	Sample Location	Sample Description	Analytical Results
7 Lab # 93-112851	PW, straight	Yellow foam with grey cloth	No asbestos detected
8 Lab # 93-112852	Boiler tank wrap	White fibrous material, white cloth and tan fine grained material	10-15% Amosite asbestos 20-25% Chrysotile asbestos
9 Lab # 93-112853	PW, straight	Yellow fibrous material with tan fine grained material	No asbestos detected
10A Lab # 93-112854	Duct wrap, left	Yellow fibrous material with white cloth	No asbestos detected 60-65% Fibrous glass 30-35% Cellulose fibers
10 Lab # 93-112855	PW, straight, left	Yellow foam with grey cloth and grey fine grained material	No asbestos detected 10-15% Cellulose fibers
11 Lab # 93-112856	PW, straight, left	Grey insulation with gold foam and blue fibrous material	No asbestos detected 20-25% Cellulose fibers 30-35% Fibrous glass

OFFICIAL NOTICE: After 45 days, samples are disposed of at a licensed waste disposal site unless client requests their return, identifying samples by our laboratory identification #'s. Charges for sample returns are a \$5.00 retrieval fee plus \$2.00 per sample to cover costs of retrieval, handling, and shipping.

Total Number of Samples: 23
Supervisor Ron Jones

Page 2 of 4
Analyst [Signature]

Note: The test result findings are made to the methodologies and parameters described on the reverse of this page.



**PRECISION
MICRO-ANALYSIS**

SPECIALISTS IN ASBESTOS-RELATED ANALYSIS

Bulk Sample Analysis (PLM) Report

Report # 93287007

Ron Jones
Chico Unified School District
2455 Carmichael Drive
Chico, CA 95969-

Date Collected: 10/13/93
Date Received: 10/14/93
Date Analyzed: 10/14/93

Phone: (916) 891-3095

Job Information:
PVHS-Boiler Room


Sample Number	Sample Location	Sample Description	Analytical Results
12 Lab # 93-112857	PW, straight, left	White fibrous material with gold foam	No asbestos detected 15-20% Cellulose fibers
13 Lab # 93-112858	PW, straight, left	Gold foam with white fibrous material	No asbestos detected 15-20% Cellulose fibers
14 Lab # 93-112859	PW, straight, left	White fibrous material with gold foam	No asbestos detected 30-35% Cellulose fibers 10-15% Fibrous glass
15 Lab # 93-112860	PW, straight, left	White fibrous material with gold foam	No asbestos detected 30-35% Cellulose fibers
16 Lab # 93-112861	PW, straight, left	White fibrous material with gold foam	No asbestos detected 30-35% Cellulose fibers
17 Lab # 93-112862	PW, straight, left	Off-white fibrous material with gold foam	No asbestos detected 30-35% Cellulose fibers

OFFICIAL NOTICE: After 45 days, samples are disposed of at a licensed waste disposal site unless client requests their return, identifying samples by our laboratory identification #'s. Charges for sample returns are a \$5.00 retrieval fee plus \$2.00 per sample to cover costs of retrieval, handling, and shipping.

Total Number of Samples: 23
Supervisor *[Signature]*

Page 3 of 4
Analyst *[Signature]*

Note: The test result findings are made to the methodologies and parameters described on the reverse of this page.



PRECISION MICRO-ANALYSIS

SPECIALISTS IN ASBESTOS RELATED ANALYSIS

Bulk Sample Analysis (PLM) Report

Report # 93287007

Ron Jones
Chico Unified School District
2455 Carmichael Drive
Chico, CA 95969-

Date Collected: 10/13/93
Date Received: 10/14/93
Date Analyzed: 10/14/93

Phone: (916) 891-3095

Job Information:
PVHS-Boiler Room

Sample Number	Sample Location	Sample Description	Analytical Results
18 Lab # 93-112863	PW, straight overhead beam , LONG	Off-white fibrous material with gold foam	1-5% Amosite asbestos Trace (<1%) Chrysotile asbestos 30-35% Cellulose fibers
19 Lab # 93-112864	PW, straight overhead beam , right	Gold foam with white fibrous material	No asbestos detected 15-20% Fibrous glass
20 Lab # 93-112865	PW, straight overhead beam , right	Gold foam material with green fibrous material	No asbestos detected 30-35% Cellulose fibers
21 Lab # 93-112866	PW, straight overhead beam , right	Gold foam	No asbestos detected
22 Lab # 93-112867	Duct wrap, right	Yellow fibrous material with white material	No asbestos detected 60-65% Fibrous glass 10-15% Cellulose fibers

OFFICIAL NOTICE: After 45 days, samples are disposed of at a licensed waste disposal site unless client requests their return, identifying samples by our laboratory identification #'s. Charges for sample returns are a \$5.00 retrieval fee plus \$2.00 per sample to cover costs of retrieval, handling, and shipping.

Total Number of Samples: 23
Supervisor Ron Jones

Page 4 of 4
Analyst Ron Jones

Note: The test result findings are made to the methodologies and parameters described on the reverse of this page.

North ↑

F Building

Room 54 (Storage Area)
Sample #'s match Location

Room
48
Toilets

Room
48
(Toilets)

22

- 19
- 20
- 21

18

- 101
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 10A

Room 55
Mechanical

Room 49
Shower Room -
Boys


Room 49
Shower Room
Girls

- 8
- 1
- 5
- 6
- 4
- 9

3

Boiler 1

2



HAZARD MANAGEMENT SERVICES, INC.
 P.O. BOX 576848
 MODESTO, CA 95357-6848

TELECOPIER COPY LETTER

DATE: 3-29-93

TIME: 10:15 A

PLEASE DELIVER THE FOLLOWING PAGES TO:

NAME:

~~BOB PETERS~~ MIKE WEISSEN BORN

COMPANY:

Chico Unified

FROM:

Jim Sharp

WE ARE TRANSMITTING 3 PAGES (INCLUDING THIS COVER LETTER) FROM A TOSHIBA TF251.

ANY PROBLEMS RECEIVING, PLEASE CALL (209) 551-2000.

OUR FAX NUMBER IS: (209) 551-2005

THE SUBJECT OF THIS TRANSMISSION IS:

PV Results

① According to AHERA regs there is no asbestos at PV - not greater than 1%.

② OSHA regs require abatement when levels exceed 0.1%. Since trace levels are only noted as "less than 1%" it is impossible to say if they are less than 0.1%. It is likely over 0.1% and further analysis would not help.

IF YOU DO NOT RECEIVE ALL OF THE PAGES, PLEASE CALL US AS SOON AS POSSIBLE.

BULK Material Analysis Request:

P.O. BOX 576848
 MODESTO, CA 95357-6848
 (209) 551-2000
 FAX (209) 551-2006

P.O. BOX 7548
 CITRUS HEIGHTS, CA 95521-7548
 (916) 723-4350
 FAX (916) 723-8917

P.O. BOX 2547A
 FRESNO, CA 93729
 (209) 434-6163
 FAX (209) 434-6163

Date: 3/25/93

Contact: J.E. SHARP

Special Instructions: _____

Analysis Requested:

- PLM with Dispersion Staining
 _____ 2 Hr; _____ 24; _____ 48 Hr; _____ Extended
 TEM Water (5 Day)
 TEM BULK (5 Day)

Collected by: JES

Date collected: 3/25/93

Job ID: CHICO UNIFIED

Job Site: PLEASANT VALLEY HIGH SCHOOL **NEED BY 3/29/93 10AM**

Sample #	Results	Material Description/ Location
MHS- CUSD- PI-93-64- 1001	TRACE	WALL PLASTER BOY'S LKR RM SOUTH HALLWAY
1002	TRACE	WALL PLASTER BOY'S LKR-RM S. WALL BY SHOWERS
1003	TRACE	WALL PLASTER BOY'S LKR-RM S.WALL MIDWAY
1004	⊖	CEILING PLASTER BOY'S LKR RM ABOVE SOUTH DOOR
1005	⊖	CEILING PLASTER BOY'S LKR RM LIGHTS NEAR SHOWER
1006	⊖	WALL PLASTER GIRL'S LKR RM SOUTH EXIT
1007	⊖	WALL PLASTER GIRL'S LKR RM MID-WALL
1008	⊖	WALL PLASTER OFFICE - SOUTH WALL
1009	⊖	CEILING PLASTER GIRL'S LKR RM AT SHOWERS
1010	⊖	CEILING PLASTER GIRL'S LKR RM LIGHTS AT S. DOOR

FORENSIC ANALYTICAL

FAX TRANSMISSION
Summary of Results
Polarized Light Microscopy

To: Jim Sharp Date/Time: 3/29/93 - 9:55
Hazard Management Services, Inc.

Project : Chico Unified
Report #: 193187

Attn: Jim Sender: lhl

If you do not receive all pages, please contact Sender at (510) 887-8828

C: Chrysotile Cr: Crocidolite
A: Amosite ND: No Asbestos detected

Sample Number	Asbestos %	Asb. Type(s)	Notes
HMSCUSDPV93641001	Trace	C	
HMSCUSDPV93641002	Trace	C	
HMSCUSDPV93641003	Trace	C	
HMSCUSDPV93641004	ND		
HMSCUSDPV93641005	ND		
HMSCUSDPV93641006	ND		
HMSCUSDPV93641007	ND		
HMSCUSDPV93641008	ND		
HMSCUSDPV93641009	ND		
HMSCUSDPV93641010	ND		

Rob

On the south wall (in the Boys' Locker Room only) trace levels of asbestos were found in the plaster - 3 out of 3 samples. The wall in the Girls Locker Room and all ceilings were negative.

FAXED TO: (209) 551-2005

These results are preliminary. Hard copy will follow in the mail.

Supervisor Approval: lhl

CLEANING/REPAIR REPORT - AHERA

40 CFR 763.91(c) (INITIAL CLEANING) Unless the building has been cleaned using equivalent methods within the previous 6 months, all areas of a school building where friable ACBM, damaged or significantly damaged thermal system insulation ACM, or friable suspected ACBM assumed to be ACM are present shall be cleaned at least once after the completion of the inspection ... and before the initiation of any response action, other than O & M activities or repair, according to the following procedures:

(i) HEPA-vacuum or steam-clean all carpets. (ii) HEPA-vacuum or wet-clean all other horizontal surfaces. (iii) Dispose of all debris, filters, mopheads, and cloths in sealed, leak-tight containers.

CLEANING

REPAIR

Date of cleaning/repair: 10-13-93

Person performing the cleaning/repair Mike Fender and Tim Brown

Location of cleaning/repair: Boiler Room work order #36694

4 joints due to boiler line repair PV

Method of cleaning/repair: Glove bag, HEPA vacuum, repair ends with
wettable cloth


Signature, Title of Authorizing Person

40 CFR 763.91(c)(2) (ADDITIONAL CLEANING) The accredited management planner shall make a written recommendation to the local education agency whether additional cleaning is needed, and if so, the method and frequency of such cleaning.

Date of cleaning/repair: _____

Person performing the cleaning/repair: _____

Location of cleaning/repair: _____

Method of cleaning/repair: _____

Signature, Title of Authorizing Person



1111 MARAUDER STREET • CHICO, CA 95926 • (916) 343-5488 • (916) 343-4356 FAX • Lic. #442414

January 7, 1994

HAZARD MANAGEMENT SERVICES, INC.
P.O. Box 7548
Citrus Heights, CA 95621-7548

Attn: Ms. Terri Busch

Re: PV High School Job
Job Number J-93-087


Dear Ms. Busch:

I apologize for the delay in getting the appropriate forms to you regarding the above-mentioned job. I hope this transmission will get you a little bit closer to closing this file.

I am including a FIT test for Steve Easter and manifests for disposal of asbestos. The daily login sheets will be forwarded to you later this afternoon, as the person that I need to get them from is out of the office until then. Also, I have been informed that there are no MSDS sheets for product used on the site, as we used amended water (water with Dove dishsoap) at the site.

If you have further questions or problems, please do not hesitate to call; however, today is my last day due to maternity leave. Jim Rich could help you if you need anything after today. Take Care!

Thank You,


Sharyn Fields,
Administrative Assistant

/sjf
enclosure

cc: ~~File - Hazard Management Services, Inc.~~

WORKER RESPIRATOR TRAINING ACKNOWLEDGEMENT

This certifies that Steve K. Easter has been made aware of the hazards involved in working with asbestos and has received training in and understands the care and use of the following respirator(s) to be used on the job:

- Dual Cartridge Negative Pressure Respirator
- Powered Air Purifying Respirator
- Type C, Supplied Air Respirator

The following respirator was assigned:

Brand: MSA
Model: Comflo
Size: L
Number: #16

The following fit testing procedures were used in the selection of the assigned respirator:

QUALITATIVE Fit Test Protocols

- Isoamyl Acetate
- Saccharin Solution Aerosol
- Irritant Fume

QUANTITATIVE Fit Test Procedures

- Positive Pressure
- Negative Pressure

The "Rainbow Passage" was or was not used in test.

The following issues were discussed and understood:

- Cleaning and storage
- Maintenance and repair
- Filter change policy
- Medical questionnaire and examination

Respirator training was conducted by the following:

Name: Don C. Hays
Signed: Don C. Hays
Date: 9/23/93
Time: 10:30 A to 11:30 A

I have been fitted with the correct size respirator, and a respirator leak test has been performed.

Name: Steve Easter
Signed: Steve Easter
Date: 9/23/93



1111 MARAUDER STREET CHICO, CA 95926

Air Resources Board
ATTN: Frances Mateo
Compliance Division
P.O. Box 2815
Sacramento, CA 95812



1111 MARAUDER STREET CHICO, CA 95926

Division of Occupational Safety & Health
381 Hemsted Drive
Redding, CA 96002



1111 MARAUDER STREET CHICO, CA 95926

USA - EPA, Region 9
Air & toxics Division/Enforcement Section (A-3-3)
San Francisco, CA 94105



1111 MARAUDER STREET CHICO, CA 95926

Butte County APCD
9287 Midway, Suite 1A
Durham, CA 95938

Please print or type. Form designed for use on elite (12-pitch typewriter).

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No. CADDFR11V157138	Manifest Document No. 215138V	2. Page 1 of 1	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address Chico Unified School Dist 2955 Spruick Rd, Chico, CA 95928		A. State Manifest Document Number 91025891	
4. Generator's Phone 916 289-3174	6. US EPA ID Number CADDFR11V157138	B. State Generator's ID HVHDFB160278019	
5. Transporter 1 Company Name M/C Industrial Services	8. US EPA ID Number CADDFR11V157138	C. State Transporter's ID 401084	
7. Transporter 2 Company Name	8. US EPA ID Number	D. Transporter's Phone (916) 285-5488	
9. Designated Facility Name and Site Address Anderson Solid Waste, Inc 18703 Cambridge Rd Anderson, CA 96007	10. US EPA ID Number CADDFR11V157138	E. State Transporter's ID	
		F. Transporter's Phone	
		G. State Facility's ID UHFDFR11V157138	
		H. Facility's Phone (916) 342-5236	

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)	12. Containers No.	13. Total Quantity	14. Unit Wt/Vol	Waste No.
				State EPA/Other
a. R.O. Hazardous Substance, solid, 1105 (Asbestos) ORM-E NA-918X	001	DT 2000210	Y	State 15 EPA/Other
b.				State EPA/Other
c.				State EPA/Other
d.				State EPA/Other

J. Additional Descriptions for Materials Listed Above 2 Non-Ferrous Roofing Felt from Pleasant Valley High School	K. Handling Codes for Wastes Listed Above A. 02 B. C. D.
---	---

15. Special Handling Instructions and Additional Information
7 more boxes when handling
Emergency Contact Robert Kimball (916) 343-5488

16. **Emergency Contact Robert Kimball (916) 343-5488**

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name ROBERT YETTS	Signature <i>Robert Yetts</i>	Month Day Year 01/12/93
17. Transporter 1 Acknowledgement of Receipt of Materials		
Printed/Typed Name	Signature <i>[Signature]</i>	Month Day Year 01/12/93
18. Transporter 2 Acknowledgement of Receipt of Materials		
Printed/Typed Name	Signature	Month Day Year
19. Discrepancy Indication Space		
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in item 19.		
Printed/Typed Name R. Robert	Signature <i>[Signature]</i>	Month Day Year 01/12/93

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8902; WITHIN CALIFORNIA CALL 1-800-952-7550

GENERATOR TRANSPORTER FACILITY

Do Not Write Below This Line

Yellow: TSDf SENDS THIS COPY TO GENERATOR WITHIN 30 DAYS

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No. **CA001278135121314** Manifest Document No. **212107V**

2. Page 1 of 1 Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address
San Gabriel School Dist
435 San Gabriel Drive, Azusa CA 91702

4. Generator's Phone **(916) 291-3174**

5. Transporter 1 Company Name **W.C. Industrial Services** 6. US EPA ID Number **CA001278135121314**

7. Transporter 2 Company Name 8. US EPA ID Number

9. Designated Facility Name and Site Address
San Gabriel School Dist
12005 San Gabriel Rd
Azusa CA 91702 10. US EPA ID Number **CA001278135121314**

A. State Manifest Document Number **91025591**

B. State Generator's ID **HYWR-13160278019**

C. State Transporter's ID **401084**

D. Transporter's Phone **(916) 361-2923**

E. State Transporter's ID

F. Transporter's Phone

G. State Facility's ID

H. Facility's Phone **(916) 347-5236**

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)	12. Containers No.	13. Total Quantity	14. Unit Wt/Vol	15. Waste No.	
				State	EPA/Other
a. 20 Boxes Solvent, etc. (Waste) 211 = 20 2183	20	20	20	151	211
b.					
c.					
d.					

J. Additional Descriptions for Materials Listed Above
7. Next Facility: Pooling Fall
Home Pleasant Valley High School

K. Handling Codes for Wastes Listed Above

15. Special Handling Instructions and Additional Information
Emergency Contact
Robert Peters
(710) 343-5988

16. **GENERATOR'S CERTIFICATION:** I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable International and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name **ROBERT PETERS** Signature **Robert Peters** Month Day Year **12/12/15**

17. Transporter 1 Acknowledgement of Receipt of Materials
Printed/Typed Name _____ Signature _____ Month Day Year **12/12/15**

18. Transporter 2 Acknowledgement of Receipt of Materials
Printed/Typed Name _____ Signature _____ Month Day Year _____

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.
Printed/Typed Name _____ Signature _____ Month Day Year _____

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-9802; WITHIN CALIFORNIA CALL 1-800-852-7555

GENERATOR

TRANSPORTER

FACILITY

Do Not Write Below This Line

YELLOW: GENERATOR RETAINS

PV

IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-852-7550

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.		Manifest Document No.		2. Page 1 of		Information in the shaded areas is not required by Federal law.	
3. Generator's Name and Mailing Address City of... 2155... Elizabet, CA 95020						A. State Manifest Document Number 92479104			
4. Generator's Phone (916) 941-3194						B. State Generator's ID H Y H D B B B B B B B B B B			
5. Transporter 1 Company Name INDUSTRIAL SERVICES CORP			6. US EPA ID Number			C. State Transporter's ID			
7. Transporter 2 Company Name						D. Transporter's Phone (916) 343-5400			
9. Designated Facility Name and Site Address ALBERQUIL SOLID WASTE, INC. 10709 Cambridge Road Anderson, CA 96007						E. State Facility's ID E A T T O O O B B B B B B B B			
10. US EPA ID Number						F. Facility's Phone (916) 347-5295			
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers		13. Total Quantity	14. Unit Wt/Vol	1. Waste Number			
		No.	Type			State	EPA/Other	State	EPA/Other
a. HAZARDOUS SUBSTANCE, SOLID, FLUO... HAZARD, Containing Asbestos (R1)		023 "		0101011 "		151 EPA/Other			
b.						State EPA/Other			
c.						State EPA/Other			
d.						State EPA/Other			
15. Special Handling Instructions and Additional Information Heavy protection when handling see attached E.P. Guidebook ppR 31. HAZARDOUS WASTE - 20163 343 5400 EMERGENCY CONTACT - Robert Kibrell						E. Handling Codes for Wastes Listed Above a. 09 b.			
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable federal, state and international laws. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.									
Printed/Typed Name Max Otto			Signature <i>Max Otto</i>			Month Day Year 17 09 83			
17. Transporter 1 Acknowledgement of Receipt of Materials Printed/Typed Name James M. Rich			Signature <i>James M. Rich</i>			Month Day Year 07 18 93			
18. Transporter 2 Acknowledgement of Receipt of Materials Printed/Typed Name			Signature			Month Day Year			
19. Discrepancy Indication Space None									
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19. Printed/Typed Name Ron Robert			Signature <i>Ron Robert</i>			Month Day Year 07 23 93			

DO NOT WRITE BELOW THIS LINE.

Yellow: TSDF SENDS THIS COPY TO GENERATOR WITHIN 30 DAYS.
 (Generators who submit hazardous waste for transport out-of-state, produce completed copy of this copy and send to DTSC within 30 days.)

IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-852-7550

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.		Manifest Document No.		2. Page 1 of 1		Information in the shaded areas is not required by Federal law.			
3. Generator's Name and Mailing Address: MAYFIELD INDUSTRIES, INC. 14000 S. GARDEN AVENUE CITY OF GARDEN, CA 91703						A. State Manifest Document Number 92479104					
4. Generator's Phone (916) 931-0101						B. State Generator's ID HYH03E029809					
5. Transporter 1 Company Name UNIVERSITY TRANSPORTS CORP			6. US EPA ID Number			C. State Transporter's ID					
7. Transporter 2 Company Name						D. Transporter's Phone (916) 343-5488					
9. Designated Facility Name and Site Address UNIVERSITY OF THE PACIFIC THE OFFICE Building, 600 Lundy Ave., CA 95620						E. State Facility's ID EP1000646117					
10. US EPA ID Number						F. Facility's Phone (916) 347-3236					
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)						12. Containers		13. Total Quantity	14. Unit Wt/Vol	1. Waste Number	
						No.	Type				
a. HAZARDOUS WASTE CONTAINING COATING OILS						023		001011		State 151 EPA/Other	
b.										State EPA/Other	
c.										State EPA/Other	
d.										State EPA/Other	
15. Special Handling Instructions and Additional Information Hazardous Waste Containing Coating Oils						K. Handling Codes for Wastes Listed Above a. b. c. d.					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable federal, state and international laws. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.											
Printed/Typed Name MAYFIELD			Signature <i>[Signature]</i>			Month 11		Day 15		Year 1985	
17. Transporter 1 Acknowledgement of Receipt of Materials Printed/Typed Name James A. Baker			Signature <i>[Signature]</i>			Month 11		Day 18		Year 1985	
18. Transporter 2 Acknowledgement of Receipt of Materials Printed/Typed Name			Signature <i>[Signature]</i>			Month		Day		Year	
19. Discrepancy Indication Space											
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19. Printed/Typed Name			Signature			Month		Day		Year	

DO NOT WRITE BELOW THIS LINE.